

OUAGADOUGOU, Burkina Faso

WMO: 655030

Lat: 12.353N

Lon: 1.512W

Elev: 1037

StdP: 14.15

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	61.1	63.0	14.0	11.7	88.9	17.6	13.9	87.3	18.7	79.9	16.9	80.8	3.5	40	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	20.8	105.7	68.9	104.1	68.9	102.4	69.1	79.8	91.9	79.1	91.1	78.5	90.2	7.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	147.2	83.2	76.5	143.7	82.9	75.5	138.8	82.6	44.3	92.7	43.5	91.4	42.8	91.1	95.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.0	14.9	13.4	DB	57.2	108.4	1.7	0.8	56.0	109.0	55.0	109.5	54.1	110.0	52.9	110.6	(4)
(5)			WB	44.2	84.0	1.4	2.9	43.2	86.1	42.4	87.8	41.6	89.5	40.6	91.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.2	77.3	82.9	89.3	92.2	90.7	86.1	81.9	80.3	81.9	85.6	83.5	78.5	(6)	
	DBStd	5.62	3.51	4.34	3.69	3.25	3.96	3.65	3.08	2.49	2.80	2.42	2.72	3.19	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	12481	847	922	1218	1267	1263	1084	990	940	956	1104	1006	884	(10)	
	CDD65	7006	382	502	753	817	798	634	525	475	506	639	556	419	(11)	
	CDH74	91764	4287	6606	11498	12949	12084	8580	5731	4438	5361	8122	7254	4854	(12)	
(13)	CDH80	52177	2159	3867	7465	8712	7776	4696	2413	1560	2299	4359	4283	2588	(13)	
(14)	Wind	WSAvg	6.2	6.7	6.5	6.1	6.6	7.8	6.5	5.6	5.1	5.1	4.7	6.2	(14)	
(15) Precipitation	PrecAvg	30.2	0.0	0.0	0.2	0.9	2.6	3.8	7.4	8.7	5.4	1.2	0.1	0.0	(15)	
	PrecMax	46.7	0.1	0.5	1.5	3.8	10.0	10.3	14.5	17.8	13.0	4.9	1.0	0.6	(16)	
	PrecMin	21.3	0.0	0.0	0.0	0.0	0.3	1.0	3.6	3.6	0.9	0.0	0.0	0.0	(17)	
	PrecStd	5.9	0.0	0.1	0.4	1.0	1.5	1.7	2.1	2.7	2.2	0.9	0.2	0.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.7	104.3	106.7	107.7	106.1	101.9	96.4	93.0	95.4	100.4	100.5	98.6	(19)	
		MCWB	61.3	64.1	66.2	68.6	72.4	76.1	76.8	78.3	77.7	70.5	66.9	63.2	(20)	
	2%	DB	95.2	102.0	104.7	105.9	104.2	99.0	93.5	90.4	93.5	98.6	98.9	96.6	(21)	
		MCWB	60.6	63.9	65.8	69.2	74.3	76.4	76.7	77.4	77.9	71.6	66.2	62.9	(22)	
	5%	DB	93.2	99.8	103.7	104.3	102.3	97.0	91.6	89.3	91.7	97.0	98.2	94.8	(23)	
		MCWB	59.8	63.4	65.5	69.5	75.0	76.2	76.6	77.0	77.7	72.8	66.0	61.4	(24)	
	10%	DB	91.0	96.9	101.9	102.6	100.4	95.0	89.7	87.5	89.9	95.2	96.7	92.3	(25)	
		MCWB	59.1	62.1	65.3	70.0	75.4	76.1	76.2	76.5	77.2	74.0	65.7	60.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.9	74.3	77.0	79.0	80.6	80.1	80.0	80.1	80.7	80.0	76.2	68.4	(27)	
		MCDB	82.6	93.5	96.0	97.3	96.1	94.3	89.6	88.7	91.1	91.9	90.9	88.6	(28)	
	2%	WB	63.0	70.4	74.8	77.6	79.4	79.0	78.7	78.8	79.2	78.7	74.0	64.9	(29)	
		MCDB	90.9	87.5	93.7	95.6	95.0	92.9	88.7	86.6	88.9	91.1	88.8	91.6	(30)	
	5%	WB	61.3	66.7	73.0	76.6	78.6	78.2	77.9	78.0	78.7	77.9	72.3	63.2	(31)	
		MCDB	89.9	92.7	91.7	94.4	94.2	91.6	87.6	85.5	88.0	89.8	87.1	90.2	(32)	
	10%	WB	59.8	63.5	70.9	75.6	77.8	77.5	77.2	77.3	78.0	77.0	70.4	61.7	(33)	
		MCDB	88.1	94.7	92.0	93.3	93.4	90.3	86.6	84.4	86.8	88.6	87.3	88.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	26.8	26.7	24.7	20.8	18.8	17.0	15.1	14.1	16.1	20.2	27.4	27.8	(35)	
		MCDBR	29.7	29.7	26.3	22.9	20.4	19.0	17.2	16.4	18.2	22.4	28.3	30.4	(36)	
	5% WB	MCWBR	10.8	10.8	10.9	9.8	7.4	6.3	5.9	6.3	6.9	7.4	8.9	10.2	(37)	
		MCWBR	27.8	24.7	20.8	19.7	18.8	17.4	16.0	15.1	17.2	19.4	22.8	28.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.596	0.661	0.767	0.747	0.711	0.670	0.600	0.565	0.562	0.625	0.563	0.541	(40)	
		taud	1.715	1.584	1.425	1.546	1.584	1.676	1.866	1.944	1.937	1.773	1.794	1.831	(41)	
	Ebn at Noon		227	218	200	204	207	213	229	241	243	224	233	237	(42)	
		Edh at Noon	74	87	104	92	87	78	65	61	61	71	68	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1761	1857	1930	1976	1933	1836	1744	1688	1793	1881	1790	1728	(44)	
	RadStd		97	95	104	93	68	68	72	65	54	52	45	63	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page