

BOBO-DIOULASSO, Burkina Faso

WMO: 655100

Lat: 11.160N

Lon: 4.331W

Elev: 1511

StdP: 13.91

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	64.7	66.8	18.8	14.9	83.5	21.8	17.3	82.8	18.0	75.6	15.8	76.6	6.8	20	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	20.3	100.8	68.7	99.9	68.8	98.4	69.1	79.0	89.9	78.2	88.9	77.6	88.1	7.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	145.2	83.4	75.5	141.2	82.7	75.1	139.2	82.4	43.7	90.6	42.9	89.8	42.3	88.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.4	13.1	DB	59.3	104.1	2.6	1.3	57.4	105.1	55.9	105.9	54.5	106.6	52.6	107.6	(4)
(5)			WB	45.1	81.4	2.0	1.4	43.7	82.4	42.5	83.2	41.4	84.0	40.0	85.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	79.1	84.1	88.3	87.9	85.7	81.9	79.1	78.1	79.1	81.8	83.0	79.5
	DBStd	4.52	3.60	4.03	3.02	3.30	3.32	3.06	2.56	2.12	2.44	2.44	1.89	2.97
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11778	902	956	1187	1138	1105	957	901	870	872	986	989	915
	CDD65	6303	437	536	722	688	640	507	436	405	422	521	539	450
	CDH74	72852	4723	7015	10615	9763	8409	5549	3707	2815	3417	5491	6446	4902
	CDH80	36271	2239	3880	6414	5725	4460	2344	1181	726	1156	2461	3339	2346
Wind	WSAvg	6.9	7.8	7.6	7.0	7.7	8.1	7.8	7.0	6.6	5.4	5.3	5.4	7.3
Precipitation	PrecAvg	40.7	0.0	0.1	0.7	1.8	3.7	5.2	8.3	10.7	7.3	2.5	0.3	0.0
	PrecMax	55.4	0.8	1.4	3.7	6.3	9.8	10.2	17.2	18.1	14.7	5.7	3.0	0.8
	PrecMin	24.6	0.0	0.0	0.0	0.0	0.8	1.5	2.7	3.9	3.0	0.1	0.0	0.0
	PrecStd	7.0	0.2	0.3	0.8	1.4	1.9	1.9	3.0	3.3	2.5	1.5	0.6	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.7	101.1	102.6	102.6	100.7	96.9	91.7	89.3	91.7	95.4	96.9	96.1
		MCWB	62.5	65.9	67.2	70.1	74.0	76.9	76.7	76.9	77.2	72.3	67.7	64.3
	2%	DB	94.6	98.9	101.0	100.8	98.5	93.6	89.6	87.4	89.8	93.6	95.3	94.2
		MCWB	61.4	65.4	66.9	70.6	75.3	76.8	76.5	76.4	76.9	73.7	67.5	63.0
	5%	DB	92.6	97.3	100.1	99.4	96.6	91.6	87.9	85.9	88.1	92.0	94.4	92.7
		MCWB	60.8	64.3	66.8	71.4	75.7	76.7	76.1	76.3	76.6	74.8	67.5	62.5
	10%	DB	90.3	95.4	98.5	97.5	94.7	89.8	86.1	84.2	86.3	90.4	93.1	90.9
		MCWB	60.1	63.3	66.9	72.4	76.0	76.2	75.8	75.9	76.2	75.3	67.5	62.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	74.5	76.9	78.7	80.5	79.1	78.3	78.2	79.0	79.0	76.5	73.1
		MCDB	86.4	92.8	92.2	94.1	91.9	90.1	87.1	85.3	87.9	88.4	88.4	86.4
	2%	WB	65.3	72.4	75.5	77.4	79.2	78.2	77.4	77.3	77.9	77.9	75.1	69.0
		MCDB	88.1	89.9	91.8	92.3	91.0	89.0	86.0	84.6	86.6	87.9	87.3	84.6
	5%	WB	63.0	70.6	74.4	76.7	78.3	77.6	76.9	76.8	77.2	77.2	74.0	65.6
		MCDB	88.2	88.1	90.5	91.3	90.2	88.1	85.3	83.9	85.7	87.3	85.8	88.1
	10%	WB	61.3	68.2	73.3	75.9	77.5	77.0	76.3	76.2	76.6	76.5	72.8	63.6
		MCDB	87.4	88.9	89.0	90.4	89.4	87.3	84.1	82.8	84.6	86.4	84.5	87.2
Mean Daily Temperature Range	5% DB	MDBR	22.7	21.8	20.3	19.0	17.6	15.7	13.7	12.7	14.5	17.6	21.7	23.0
		MCDBR	24.3	22.9	21.9	20.9	19.7	18.1	16.0	14.8	17.1	19.6	22.8	24.3
		MCWBR	10.2	9.9	9.4	7.7	5.6	6.1	5.7	5.9	6.7	6.6	8.6	9.6
	5% WB	MCDBR	22.4	19.2	18.8	18.7	17.5	16.3	14.8	13.8	15.7	17.7	19.8	23.0
MCWBR		10.4	10.9	8.4	6.5	6.6	6.4	6.0	6.0	6.8	7.1	7.7	10.5	
Clear-Sky Solar Irradiance	taub	0.546	0.615	0.736	0.670	0.614	0.570	0.511	0.488	0.493	0.547	0.523	0.500	
	taud	1.848	1.709	1.524	1.715	1.804	1.924	2.128	2.205	2.164	1.982	1.950	1.972	
	Ebn at Noon	242	231	207	220	228	235	251	260	261	245	246	251	
	Edh at Noon	65	77	94	77	69	61	50	47	49	58	58	56	
All-Sky Solar Radiation	RadAvg	1801	1872	1929	1917	1902	1780	1660	1580	1689	1844	1784	1748	
	RadStd	92	94	89	76	60	68	51	64	66	49	54	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page