

PO, Burkina Faso

WMO: 655180

Lat: 11.150N

Lon: 1.150W

Elev: 322

StdP: 97.52

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.8	18.9	-10.3	1.6	30.1	-7.7	2.0	29.7	5.2	24.2	4.4	25.5	1.4	0	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.6	39.7	21.5	38.9	21.4	38.1	21.3	27.2	33.1	26.8	32.6	26.5	32.2	2.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	22.0	30.4	25.4	21.4	29.8	25.0	20.9	29.3	88.5	32.9	86.3	32.7	84.6	32.5	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 5.7	4.9	4.2	15.0	41.6	1.4	0.5	13.9	41.9	13.1	42.2	12.2	42.5	11.2	42.9		
(5)			7.4	28.4	1.3	0.8	6.4	29.0	5.7	29.5	5.0	30.0	4.1	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	26.4	29.6	32.2	32.5	30.7	28.4	26.7	26.1	26.7	28.3	28.7	26.5	(6)
(7)		DBStd	2.79	1.95	2.21	1.79	1.99	2.18	1.92	1.49	1.29	1.37	1.34	1.27	1.73	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6774	509	550	689	674	643	551	519	498	500	568	562	512	(10)
(11)		CDD18.3	3733	251	317	431	424	385	301	261	239	250	309	312	254	(11)
(12)		CDH23.3	45167	2786	4185	6540	6420	5383	3574	2421	1878	2208	3363	3672	2737	(12)
(13)	CDH26.7	23862	1436	2422	4169	4096	3085	1626	818	513	769	1547	1997	1385	(13)	
(14)	Wind	WSAvg	1.7	2.1	2.1	2.0	2.2	1.8	1.5	1.3	1.1	1.2	1.2	1.9	(14)	
(15)	Precipitation	PrecAvg	976	0	4	9	55	92	130	184	279	171	49	2	2	(15)
(16)		PrecMax	1201	10	43	38	154	191	245	298	439	259	108	11	24	(16)
(17)		PrecMin	765	0	0	0	16	22	44	103	178	86	9	0	0	(17)
(18)		PrecStd	117	2	9	12	32	37	48	51	73	50	27	3	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	40.1	40.6	40.7	39.5	36.6	33.6	32.2	33.4	36.1	37.2	36.7	(19)
MCWB			16.9	18.8	20.8	22.6	24.9	25.6	25.2	26.3	26.3	23.4	20.2	18.2	(20)	
2%		DB	35.9	38.7	39.6	39.7	38.1	35.2	32.4	31.2	32.4	35.0	36.5	35.5	(21)	
		MCWB	16.8	19.3	20.5	22.6	25.2	25.6	25.4	25.8	26.3	24.3	20.4	17.7	(22)	
5%		DB	34.7	37.6	38.9	38.8	36.9	34.1	31.5	30.3	31.6	34.1	35.8	34.4	(23)	
		MCWB	16.4	19.0	20.2	22.8	25.4	25.5	25.2	25.4	26.1	24.9	20.4	17.2	(24)	
10%		DB	33.4	36.4	38.0	37.8	35.7	32.9	30.5	29.4	30.6	33.1	34.9	33.1	(25)	
		MCWB	15.9	18.4	20.0	23.1	25.3	25.2	25.0	25.2	25.8	25.3	20.5	16.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	24.6	26.5	27.5	27.7	27.2	26.8	27.1	27.7	27.7	25.9	22.9	(27)
MCD B			29.2	34.3	34.9	37.7	35.7	33.4	31.4	31.1	31.6	32.4	33.2	30.8	(28)	
2%		WB	18.9	23.3	25.2	26.2	27.0	26.6	26.2	26.2	27.1	27.1	24.9	20.2	(29)	
		MCD B	33.0	33.0	34.6	35.6	34.5	32.7	30.6	30.0	31.2	32.0	32.2	31.6	(30)	
5%		WB	17.6	22.1	24.3	25.7	26.5	26.2	25.7	25.7	26.5	26.5	24.2	18.7	(31)	
		MCD B	32.7	32.3	33.5	34.5	33.9	32.0	29.9	29.3	30.5	31.6	31.5	31.7	(32)	
10%		WB	16.6	20.6	23.6	25.2	26.1	25.8	25.3	25.3	26.0	26.0	23.4	17.8	(33)	
		MCD B	32.0	32.6	33.0	33.8	33.4	31.4	29.4	28.6	29.9	31.2	30.6	31.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.3	13.4	11.9	10.6	9.5	8.3	7.3	6.6	7.8	10.2	14.0	14.5	(35)
MCDBR			15.7	14.3	12.9	11.7	10.8	9.9	8.6	7.9	9.1	11.6	14.4	15.4	(36)	
MCWBR			6.3	6.1	5.3	3.8	3.1	3.0	3.1	3.3	4.2	4.3	5.5	5.9	(37)	
5% WB		MCD BR	14.9	11.6	10.8	10.5	9.7	8.8	7.9	7.4	8.6	10.0	11.9	14.7	(38)	
		MCWBR	6.8	6.4	4.5	3.4	3.4	3.4	3.4	3.5	4.4	4.5	5.1	6.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.620	0.692	0.784	0.734	0.665	0.614	0.553	0.530	0.535	0.608	0.582	0.569	(40)	
taud		1.707	1.581	1.459	1.616	1.701	1.821	2.010	2.073	2.035	1.835	1.809	1.817	(41)		
Ebn at Noon		701	670	621	650	682	709	758	787	789	723	726	730	(42)		
Edh at Noon		236	276	317	269	242	212	176	168	176	211	211	207	(43)		
(44)	All-Sky Solar Radiation	RadAvg	5.59	5.82	5.96	6.07	5.94	5.54	5.14	4.95	5.27	5.81	5.65	5.49	(44)	
(45)		RadStd	0.28	0.26	0.27	0.22	0.23	0.19	0.22	0.18	0.18	0.19	0.14	0.18	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page