

DALOA, Côte d'Ivoire

WMO: 655600

Lat: 6.793N

Lon: 6.473W

Elev: 823

StdP: 14.26

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	65.0	67.5	41.0	39.0	82.1	45.4	46.2	80.7	9.7	77.6	7.7	77.3	0.1	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	18.6	95.2	75.2	93.6	75.7	92.6	75.9	80.7	90.2	80.0	89.3	79.5	88.4	1.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	150.9	86.5	77.4	146.8	85.5	77.0	144.9	85.0	45.1	90.8	44.4	89.9	43.7	88.8	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.0	4.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			52.5	83.2	1.7	1.6	51.4	84.4	50.4	85.3	49.5	86.2	48.2	87.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.1	80.5	82.9	82.9	82.1	81.1	79.3	77.6	77.2	79.0	79.7	80.3	79.2
	DBStd	2.77	2.79	2.48	2.23	2.28	2.00	1.90	1.80	1.60	1.94	1.70	1.69	2.64
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10996	946	922	1020	962	963	878	857	843	871	920	909	905
	CDD65	5521	481	502	555	512	498	428	392	378	421	455	459	440
	CDH74	48339	4724	5498	6028	5386	4642	3278	2456	2148	3014	3520	3849	3796
	CDH80	19082	2218	2759	2863	2379	1841	1019	540	415	905	1200	1445	1498
Wind	WSAvg	0.4	0.8	1.0	0.6	0.5	0.3	0.3	0.4	0.5	0.2	0.2	0.3	0.3
Precipitation	PrecAvg	48.2	0.3	2.2	4.5	5.0	5.9	6.1	4.4	5.1	6.5	5.4	2.1	0.9
	PrecMax	62.4	1.9	6.3	11.4	8.1	11.0	12.5	12.9	9.8	11.7	8.2	4.6	3.0
	PrecMin	38.0	0.0	0.3	0.7	2.2	2.7	1.5	0.3	0.8	2.9	2.4	0.4	0.0
	PrecStd	6.9	0.5	1.4	2.3	1.6	2.1	2.4	3.0	2.4	2.6	1.7	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.3	97.3	97.0	95.2	93.2	89.9	88.0	87.5	89.9	90.4	91.7	92.8
		MCWB	71.3	74.7	76.1	79.8	79.6	78.5	78.0	77.2	78.7	78.3	78.2	71.5
	2%	DB	93.5	95.4	94.9	93.3	91.2	88.1	86.1	85.5	88.1	89.1	89.9	90.9
		MCWB	71.7	74.2	76.7	79.6	79.3	78.2	76.9	76.8	78.2	78.0	77.7	72.9
	5%	DB	91.8	93.9	93.2	91.7	89.7	86.9	84.6	84.0	86.6	87.5	88.6	89.4
		MCWB	71.6	74.5	77.3	79.1	79.0	77.8	76.3	76.3	77.8	77.6	77.5	73.3
	10%	DB	90.0	92.3	91.5	90.2	88.2	85.5	83.1	82.4	85.1	86.0	87.3	87.6
		MCWB	71.4	74.5	77.5	78.8	78.7	77.3	75.8	75.8	77.3	77.3	77.3	73.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.5	80.5	81.2	81.8	81.0	79.8	79.1	78.6	79.9	79.8	80.2	79.6
		MCDB	88.2	92.5	91.6	91.8	89.6	87.3	85.9	84.9	87.3	87.5	88.5	87.5
	2%	WB	78.0	79.1	80.1	80.8	80.2	79.0	77.9	77.6	79.0	78.9	79.1	78.3
		MCDB	87.8	90.6	90.5	90.7	88.7	86.6	84.3	83.6	86.2	86.8	87.4	86.4
	5%	WB	77.0	78.1	79.3	80.0	79.6	78.3	77.0	76.9	78.2	78.3	78.4	77.5
		MCDB	86.9	89.0	89.7	89.7	87.9	85.5	83.3	82.6	85.1	85.9	86.4	85.2
	10%	WB	76.1	77.2	78.6	79.2	78.9	77.6	76.3	76.2	77.5	77.6	77.7	76.6
		MCDB	84.8	87.5	88.8	88.6	87.1	84.3	81.9	81.3	83.9	84.8	85.5	83.8
Mean Daily Temperature Range	5% DB	MDBR	21.5	20.6	18.6	17.1	15.7	13.5	11.9	11.5	13.5	14.6	16.1	18.5
		MCDBR	22.9	22.1	20.4	18.9	17.3	15.2	13.9	13.5	15.4	16.1	17.3	20.4
		MCWBR	7.5	6.8	6.6	7.0	7.0	6.0	5.5	5.7	6.4	6.2	6.4	7.1
	5% WB	MCDBR	18.6	19.7	19.0	18.1	16.5	14.4	12.7	12.5	14.7	15.5	16.6	17.0
		MCWBR	6.8	6.9	7.2	7.5	7.4	6.3	5.6	5.9	6.5	6.6	7.1	6.9
Clear-Sky Solar Irradiance	taub	0.699	0.700	0.744	0.593	0.511	0.481	0.460	0.443	0.447	0.483	0.547	0.642	
	taud	1.639	1.679	1.610	1.925	2.132	2.234	2.303	2.354	2.349	2.225	1.992	1.764	
	Ebn at Noon	209	214	207	237	252	256	263	272	275	266	245	219	
	Edh at Noon	82	81	87	62	49	44	41	40	41	46	57	71	
All-Sky Solar Radiation	RadAvg	1557	1571	1664	1682	1603	1364	1247	1233	1355	1466	1459	1434	
	RadStd	78	66	64	67	62	60	60	66	57	46	52	54	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page