

DALOA, Côte d'Ivoire

WMO: 655600

Lat: 6.793N

Lon: 6.473W

Elev: 251

StdP: 98.35

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.3	19.7	5.0	5.6	27.8	7.5	6.6	27.1	4.3	25.4	3.4	25.1	0.1	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.3	35.1	24.0	34.2	24.3	33.6	24.4	27.1	32.3	26.7	31.8	26.4	31.4	0.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.6	30.3	25.2	21.0	29.7	25.0	20.7	29.4	87.0	32.7	85.3	32.1	83.8	31.6	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
3.8	2.7	1.9		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
				DB	11.4	28.5	0.9	0.9	10.8	29.1	10.2	29.6	9.7	30.1	9.0	30.8
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	27.0	28.3	28.3	27.8	27.3	26.3	25.4	25.1	26.1	26.5	26.8	26.2
	DBStd	1.54	1.55	1.38	1.24	1.27	1.11	1.06	1.00	0.89	1.08	0.94	0.94	1.47
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6109	526	512	567	534	535	488	476	468	484	511	505	503
	CDD18.3	3067	267	279	308	284	277	238	218	210	234	253	255	244
	CDH23.3	26855	2624	3054	3349	2992	2579	1821	1364	1193	1674	1956	2138	2109
	CDH26.7	10601	1232	1533	1591	1322	1023	566	300	231	503	667	803	832
(14) Wind	WSAvg	0.2	0.4	0.4	0.3	0.2	0.2	0.1	0.2	0.2	0.1	0.1	0.1	0.1
(15) Precipitation	PrecAvg	1224	7	56	115	127	150	155	112	130	164	136	53	22
	PrecMax	1585	48	159	289	206	279	317	327	249	296	209	117	75
	PrecMin	965	0	7	17	57	68	38	7	21	73	60	9	1
	PrecStd	175	12	35	58	40	53	61	75	61	65	43	31	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	36.3	36.1	35.1	34.0	32.2	31.1	30.8	32.1	32.5	33.2	33.8
		MCWB	21.8	23.7	24.5	26.5	26.5	25.8	25.5	25.1	25.9	25.7	25.7	22.0
	2%	DB	34.2	35.2	34.9	34.0	32.9	31.2	30.0	29.7	31.2	31.7	32.2	32.7
		MCWB	22.1	23.5	24.8	26.4	26.3	25.7	25.0	24.9	25.7	25.6	25.4	22.7
	5%	DB	33.2	34.4	34.0	33.2	32.0	30.5	29.2	28.9	30.4	30.9	31.5	31.9
		MCWB	22.0	23.6	25.2	26.2	26.1	25.5	24.6	24.6	25.4	25.3	25.3	22.9
	10%	DB	32.2	33.5	33.1	32.3	31.2	29.7	28.4	28.0	29.5	30.0	30.7	30.9
		MCWB	21.9	23.6	25.3	26.0	26.0	25.2	24.4	24.3	25.2	25.2	25.1	23.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.9	27.3	27.7	27.2	26.6	26.2	25.9	26.6	26.6	26.8	26.5
		MCDB	31.2	33.6	33.1	33.2	32.0	30.7	29.9	29.4	30.7	30.8	31.4	30.8
	2%	WB	25.6	26.2	26.7	27.1	26.8	26.1	25.5	25.3	26.1	26.1	26.2	25.7
		MCDB	31.0	32.6	32.5	32.6	31.5	30.3	29.1	28.7	30.1	30.5	30.8	30.2
	5%	WB	25.0	25.6	26.3	26.6	26.4	25.7	25.0	24.9	25.7	25.7	25.8	25.3
		MCDB	30.5	31.7	32.0	32.0	31.1	29.7	28.5	28.1	29.5	29.9	30.2	29.6
	10%	WB	24.5	25.1	25.9	26.2	26.1	25.3	24.6	24.5	25.3	25.3	25.4	24.8
		MCDB	29.3	30.8	31.5	31.4	30.6	29.1	27.7	27.4	28.9	29.4	29.7	28.8
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	11.4	10.3	9.5	8.7	7.5	6.6	6.4	7.5	8.1	8.9	10.3
		MCDBR	12.7	12.3	11.3	10.5	9.6	8.5	7.7	7.5	8.6	9.0	9.6	11.3
		MCWBR	4.1	3.8	3.7	3.9	3.9	3.4	3.1	3.2	3.6	3.4	3.5	3.9
	5% WB	MCDBR	10.4	11.0	10.6	10.1	9.1	8.0	7.1	7.0	8.2	8.6	9.2	9.4
		MCWBR	3.8	3.8	4.0	4.2	4.1	3.5	3.1	3.3	3.6	3.7	3.9	3.9
(40) Clear-Sky Solar Irradiance	taub		0.699	0.700	0.744	0.593	0.511	0.481	0.460	0.443	0.447	0.483	0.547	0.642
	taud		1.639	1.679	1.610	1.925	2.132	2.234	2.303	2.354	2.349	2.225	1.992	1.764
	Ebn at Noon		658	676	652	747	793	807	828	857	866	837	772	690
	Edh at Noon		259	254	274	197	156	139	130	127	129	145	180	224
(44) All-Sky Solar Radiation	RadAvg		4.91	4.95	5.25	5.30	5.05	4.30	3.93	3.89	4.27	4.62	4.60	4.52
	RadStd		0.25	0.21	0.20	0.21	0.20	0.19	0.19	0.21	0.18	0.15	0.16	0.17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page