

DIMBOKRO CITY, Côte d'Ivoire

WMO: 655620

Lat: 6.650N

Lon: 4.700W

Elev: 92

StdP: 100.22

Time Zone: 0.00 (E00)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.1	20.1	10.2	7.8	29.8	13.2	9.6	27.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.3	37.3	26.8	36.7	26.7	35.9	26.6	29.0	35.2	28.5	34.6	28.1	34.1	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.3	33.5	26.9	22.8	33.0	26.4	22.2	32.0	95.1	35.3	92.7	34.8	90.7	34.2	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	14.5	30.2	2.1	0.9	13.0	30.9	11.7	31.4	10.6	32.0	9.0	32.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.5	28.7	30.1	30.0	29.7	29.2	28.0	27.1	26.6	27.6	28.2	28.5	27.9
	DBStd	1.62	1.72	1.68	1.32	1.26	1.24	1.09	0.97	0.96	0.98	0.96	0.83	1.32
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6736	578	562	619	592	596	541	529	516	529	563	556	555
	CDD18.3	3694	320	328	361	342	338	291	271	258	279	304	306	297
	CDH23.3	39553	3748	4159	4476	4177	3857	2826	2341	2078	2511	3003	3226	3151
(13)	CDH26.7	18632	2034	2318	2398	2165	1854	1147	813	656	951	1277	1493	1526
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(15) Precipitation	PrecAvg	1137	13	49	114	135	146	183	99	73	120	123	56	20
	PrecMax	1953	76	148	273	311	309	354	286	196	311	305	190	104
	PrecMin	816	0	0	1	12	47	61	4	1	7	8	1	0
	PrecStd	218	18	36	54	62	59	77	66	54	72	58	42	26
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	39.1	38.1	37.3	36.8	34.9	33.2	33.1	34.1	35.0	35.1	35.8
		MCWB	25.6	25.8	27.3	28.5	28.7	27.7	26.7	25.9	26.6	26.9	27.0	24.7
	2%	DB	36.6	37.8	37.0	36.4	35.3	33.8	32.2	31.9	33.0	33.9	34.2	34.8
		MCWB	25.3	26.2	27.6	28.2	28.0	27.3	26.3	26.0	26.4	26.9	27.0	25.5
	5%	DB	35.6	36.8	36.1	35.6	34.7	32.9	31.4	30.9	32.1	33.1	33.7	34.0
		MCWB	25.1	25.8	27.4	27.9	27.8	27.0	26.0	25.8	26.2	26.7	26.9	25.6
	10%	DB	34.7	35.8	35.2	34.7	33.9	31.9	30.6	30.0	31.1	32.2	32.9	33.1
		MCWB	24.7	25.7	27.2	27.7	27.5	26.6	25.8	25.5	26.0	26.5	26.6	25.7
	0.4%	WB	28.2	28.7	29.4	29.5	29.5	28.6	27.6	27.2	27.7	28.0	28.2	28.1
		MCDB	35.1	36.0	36.0	35.7	35.0	33.6	31.8	31.2	32.4	33.3	33.4	33.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.3	27.9	28.8	29.0	28.7	27.7	26.9	26.6	27.1	27.5	27.7	27.4
		MCDB	34.1	35.4	35.2	35.3	34.5	32.4	31.1	30.5	31.6	32.6	33.0	32.9
	5%	WB	26.7	27.4	28.2	28.4	28.2	27.2	26.4	26.1	26.6	27.1	27.2	27.0
		MCDB	33.2	34.4	34.6	34.5	33.8	31.9	30.5	30.1	31.0	32.0	32.5	32.4
	10%	WB	26.2	26.9	27.7	27.9	27.6	26.7	25.9	25.6	26.1	26.7	26.9	26.5
		MCDB	31.9	33.3	33.8	33.7	33.0	31.2	29.9	29.4	30.5	31.4	32.0	31.6
	5% DB	MDBR	13.6	12.7	11.3	10.8	9.9	8.6	7.9	7.4	8.4	9.2	10.1	11.8
		MCDBR	14.1	13.4	12.3	11.7	10.9	9.8	9.1	8.8	9.4	10.0	10.8	12.7
		MCWBR	4.6	3.9	4.2	4.3	4.3	4.0	3.7	3.8	3.8	3.9	4.1	4.7
		MCWBR	12.3	12.0	11.5	11.4	10.7	9.2	8.4	8.1	8.8	9.6	10.4	11.0
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.3	3.9	4.7	4.8	4.7	4.1	3.8	3.8	4.0	4.2	4.4	4.4
(40) Clear-Sky Solar Irradiance	taub		0.746	0.742	0.777	0.610	0.522	0.497	0.489	0.472	0.468	0.500	0.563	0.670
		taud	1.583	1.624	1.570	1.900	2.110	2.193	2.223	2.274	2.297	2.183	1.963	1.731
	Ebn at Noon		626	647	631	734	784	793	804	832	848	822	759	669
		Edh at Noon	274	269	286	202	160	145	141	137	136	152	185	232
(44) All-Sky Solar Radiation	RadAvg		4.86	4.84	5.13	5.29	4.99	4.21	3.86	3.66	3.94	4.52	4.67	4.51
	RadStd		0.23	0.19	0.22	0.20	0.17	0.22	0.20	0.24	0.18	0.19	0.15	0.16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page