

YAMO USSOUKRO, Côte d'Ivoire

WMO: 655630

Lat: 6.903N

Lon: 5.366W

Elev: 699

StdP: 14.33

Time Zone: 0.00 (E00)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	59.7	63.3	41.6	39.7	87.2	48.2	51.2	82.8	13.9	78.3	12.3	78.8	1.5	0	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	19.7	96.9	74.7	95.3	75.1	94.1	75.7	80.9	90.3	80.1	89.6	79.7	89.1	6.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	152.0	85.9	77.5	146.6	85.0	77.2	145.2	84.8	45.1	91.2	44.4	90.2	43.9	89.6	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 13.5	11.8	10.8		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(5)			DB	53.5	82.8	3.9	0.9	50.6	83.4	48.3	83.9	46.1	84.4	43.3	85.1	(p)
			WB													(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	80.1	83.7	83.7	83.3	82.2	80.3	78.5	78.0	79.6	80.4	80.7	78.9
	DBStd	2.91	3.57	2.86	2.34	2.18	2.04	1.87	1.65	1.58	1.65	1.62	1.36	2.69
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11225	934	943	1044	999	999	909	884	869	887	942	920	895
	CDD65	5750	469	523	579	549	534	459	419	404	437	477	470	430
	CDH74	51837	4988	5883	6388	5878	5233	3695	2776	2501	3069	3653	3882	3891
	CDH80	22294	2624	3133	3176	2758	2248	1274	723	584	963	1365	1647	1799
Wind	WSAvg	5.1	4.3	5.6	6.0	5.6	5.5	5.5	6.0	6.1	5.1	4.4	4.1	3.7
Precipitation	PrecAvg	45.0	0.4	2.0	4.0	5.6	5.7	6.3	3.6	3.4	4.9	4.9	2.2	0.7
	PrecMax	59.6	2.8	6.8	8.3	7.9	11.3	13.0	7.2	6.1	9.1	8.9	4.6	3.1
	PrecMin	35.7	0.0	0.2	0.3	3.4	2.2	2.8	0.4	0.4	1.8	1.7	0.3	0.0
	PrecStd	6.9	0.7	1.6	1.9	1.4	2.2	2.6	1.9	1.6	2.2	2.0	1.1	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.9	100.0	98.7	96.9	94.9	91.6	88.8	88.8	90.0	91.4	93.0	94.5
		MCWB	72.8	74.4	75.1	79.4	80.1	78.6	77.2	76.2	78.0	78.7	77.7	71.4
	2%	DB	95.2	97.2	96.4	94.7	92.8	89.8	87.3	86.4	88.4	89.8	91.3	92.2
		MCWB	72.2	73.7	76.4	79.5	79.8	78.4	76.8	76.1	77.5	78.1	78.2	72.7
	5%	DB	93.6	95.6	94.6	93.2	91.3	88.2	85.9	85.1	87.4	88.8	89.8	90.8
		MCWB	72.2	73.9	77.0	79.6	79.4	78.2	76.7	75.9	77.3	77.9	78.0	73.1
	10%	DB	91.9	94.3	92.8	91.5	89.7	86.5	84.3	83.5	85.7	87.4	88.3	89.2
		MCWB	72.2	74.4	77.8	79.3	79.0	77.8	76.3	75.5	77.0	77.8	77.9	73.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.0	80.0	81.0	81.8	81.5	80.1	79.1	78.3	79.5	80.7	80.4	79.2
		MCDB	90.6	92.6	91.3	91.8	90.0	87.6	86.0	84.7	87.3	88.7	88.9	88.2
	2%	WB	77.8	79.0	80.0	80.9	80.6	79.4	78.0	77.3	78.6	79.3	79.5	78.3
		MCDB	89.1	91.1	90.8	90.9	89.9	87.1	84.8	83.8	86.2	87.2	88.1	87.2
	5%	WB	76.9	78.2	79.4	80.1	80.0	78.7	77.2	76.6	77.9	78.7	78.9	77.7
		MCDB	87.8	89.9	90.2	89.9	88.9	86.6	83.9	82.8	85.2	86.4	87.5	86.3
	10%	WB	76.1	77.4	78.8	79.6	79.4	78.1	76.5	75.9	77.1	78.0	78.2	76.9
		MCDB	86.4	88.6	89.6	89.1	88.0	85.3	82.7	81.8	84.2	85.5	86.6	85.2
Mean Daily Temperature Range	5% DB	MDBR	26.8	23.3	19.7	18.4	16.9	14.6	12.8	12.5	14.2	15.9	18.4	23.4
		MCDBR	27.1	25.2	21.7	20.0	18.3	16.3	14.8	14.5	15.9	17.3	19.4	25.2
		MCWBR	9.9	7.8	6.8	7.0	7.0	6.4	6.0	5.6	6.3	6.9	8.0	9.8
	5% WB	MCDBR	23.5	21.6	19.7	19.0	17.5	15.5	13.5	13.1	15.0	16.5	18.6	20.6
		MCWBR	8.9	7.1	7.3	7.5	7.2	6.5	6.0	5.8	6.4	7.0	8.2	8.8
Clear-Sky Solar Irradiance	taub	0.713	0.716	0.761	0.604	0.517	0.488	0.472	0.454	0.456	0.493	0.556	0.651	
	taud	1.622	1.656	1.588	1.908	2.117	2.218	2.275	2.328	2.327	2.196	1.973	1.755	
	Ebn at Noon	206	211	203	234	250	254	259	269	272	262	242	217	
	Edh at Noon	83	82	89	64	50	45	43	41	42	47	58	72	
All-Sky Solar Radiation	RadAvg	1550	1559	1650	1689	1597	1351	1220	1177	1289	1443	1455	1430	
	RadStd	74	63	64	65	61	73	57	79	58	58	49	59	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page