

ADIAKE, Côte d'Ivoire

WMO: 655850

Lat: 5.300N

Lon: 3.300W

Elev: 128

StdP: 14.63

Time Zone: 0.00 (E00)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.6	71.3	61.0	80.4	77.8	65.1	93.2	76.5	12.3	79.3	11.4	79.5	1.5	320	0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	13.5	91.6	80.2	90.7	80.1	89.8	79.9	82.5	89.0	81.8	88.3	81.2	87.6	4.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	160.4	86.4	80.0	156.7	85.7	79.4	153.2	85.0	46.4	88.7	45.6	88.8	45.0	88.1	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	9.7	8.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	81.4	82.7	83.1	82.8	81.6	79.3	77.9	77.0	78.4	79.9	81.4	81.4
	DBStd	2.55	1.88	1.89	1.86	1.84	1.83	1.64	1.51	1.35	1.31	1.55	1.31	1.75
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11152	975	915	1025	983	980	879	866	837	851	927	942	972
	CDD65	5677	510	495	560	533	515	429	401	372	401	462	492	507
	CDH74	51546	5050	5209	6166	5874	5203	3434	2576	1960	2539	3778	4773	4984
	CDH80	15644	1827	1905	2403	2216	1669	675	290	164	337	868	1576	1714
Wind	WSAvg	2.7	2.3	3.2	3.2	2.8	2.9	2.6	3.3	3.1	2.5	2.2	1.9	1.6
Precipitation	PrecAvg	73.7	1.1	2.6	3.9	5.6	11.1	19.6	7.2	2.5	4.3	6.9	5.8	2.1
	PrecMax	101.4	5.7	7.2	8.0	10.5	26.7	35.4	23.6	12.2	17.8	15.2	15.0	7.4
	PrecMin	47.0	0.0	0.1	0.2	1.2	4.9	5.2	0.5	0.2	0.2	1.2	1.3	0.0
	PrecStd	15.2	1.2	1.7	2.0	2.3	4.6	8.1	5.2	2.5	3.3	3.5	3.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	92.7	92.9	92.8	91.2	88.2	85.8	84.6	86.0	88.4	90.7	91.5
		MCWB	77.3	78.6	80.9	81.6	81.1	80.2	77.6	75.7	77.7	79.8	80.9	79.4
	2%	DB	90.0	90.9	91.3	91.2	89.8	86.4	84.1	82.8	84.3	87.2	89.4	89.8
		MCWB	78.3	79.7	80.6	81.1	80.7	79.2	76.9	75.2	77.0	79.3	80.5	79.5
	5%	DB	89.2	89.7	90.1	89.9	88.6	85.2	82.8	81.9	83.0	86.0	88.2	88.8
		MCWB	78.3	79.5	80.2	80.4	80.4	78.4	76.4	75.0	76.5	78.7	80.1	79.5
	10%	DB	87.9	88.4	89.2	88.9	87.3	83.9	81.9	80.6	82.1	84.5	87.4	87.6
		MCWB	78.2	79.3	79.9	80.2	80.1	77.9	76.1	74.7	76.2	78.0	79.8	79.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	82.5	83.1	83.3	83.0	81.0	79.1	77.3	78.8	80.9	82.3	82.5
		MCDB	88.3	89.4	89.9	90.0	89.1	86.5	83.4	81.5	83.7	86.8	88.9	88.8
	2%	WB	81.0	81.5	81.9	82.1	81.9	80.0	78.1	76.4	77.8	79.9	81.4	81.3
		MCDB	87.6	88.0	88.4	88.9	88.0	85.1	82.2	80.4	82.3	85.7	88.0	87.9
	5%	WB	80.3	80.8	81.2	81.4	81.0	79.1	77.3	75.7	77.2	79.1	80.7	80.6
		MCDB	86.8	87.1	87.6	87.9	87.0	83.8	81.2	79.6	81.5	84.6	87.4	87.3
	10%	WB	79.6	80.1	80.6	80.7	80.4	78.4	76.6	75.3	76.7	78.4	80.0	79.9
		MCDB	85.5	86.0	86.9	87.0	86.1	82.7	80.2	79.1	80.6	83.3	86.2	86.0
Mean Daily Temperature Range	5% DB	MDBR	15.2	13.7	13.5	13.0	11.9	9.3	8.0	8.3	8.6	10.5	13.1	14.2
		MCDBR	16.3	14.8	14.3	14.1	13.9	11.5	9.7	9.9	10.0	12.2	14.2	15.5
		MCWBR	7.2	5.8	5.6	5.9	6.4	5.6	4.2	4.0	4.1	5.6	7.0	7.4
	5% WB	MCDBR	14.6	13.7	13.8	13.7	13.1	10.8	8.9	8.5	9.2	11.5	13.9	14.2
		MCWBR	7.3	6.0	6.1	6.4	6.6	5.7	4.3	3.9	4.1	5.6	7.1	7.4
Clear-Sky Solar Irradiance	taub		0.794	0.767	0.761	0.587	0.512	0.510	0.517	0.507	0.475	0.479	0.547	0.678
	taud		1.538	1.603	1.609	1.974	2.170	2.175	2.141	2.172	2.293	2.292	2.050	1.745
	Ebn at Noon		190	201	204	238	251	247	247	255	267	267	246	212
	Edh at Noon		91	87	87	60	48	47	49	48	43	43	54	73
All-Sky Solar Radiation	RadAvg		1601	1551	1641	1654	1501	1239	1289	1268	1323	1512	1599	1521
	RadStd		74	62	69	69	61	89	77	83	62	56	45	38

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page