

TABOU, Côte d'Ivoire

WMO: 655920

Lat: 4.417N

Lon: 7.367W

Elev: 69

StdP: 14.66

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	68.6	70.6	63.2	86.9	73.4	66.5	97.7	74.3	16.9	77.4	15.9	77.6	2.0	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.7	89.8	79.9	88.8	79.8	88.0	79.7	81.6	87.2	80.9	86.6	80.5	86.2	8.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.7	85.1	79.2	152.0	84.5	78.9	150.4	84.2	45.3	87.9	44.6	87.1	44.2	86.3	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	14.2	12.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.2	79.5	80.6	81.2	81.2	80.1	78.7	77.2	76.6	77.5	78.6	79.5	79.4
	DBStd	2.14	1.86	1.69	1.65	1.64	1.65	1.60	1.75	1.42	1.31	1.31	1.28	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10641	915	857	967	935	932	861	845	823	826	885	884	911
	CDD65	5166	450	437	502	485	467	411	380	358	376	420	434	446
	CDH74	43274	3967	4068	4963	4901	4376	3329	2446	1798	2311	3282	3941	3892
	CDH80	10704	1283	1396	1761	1706	1160	436	159	65	150	479	972	1137
(14) Wind	WSAvg	4.5	3.6	4.3	4.6	4.8	3.9	4.5	5.2	5.5	5.5	5.5	4.0	2.9
(15) Precipitation	PrecAvg	86.9	1.7	1.9	2.8	4.8	13.9	18.9	8.5	6.1	9.8	7.2	6.8	4.8
	PrecMax	116.0	7.3	6.0	7.2	17.6	39.9	34.5	47.2	18.5	25.1	16.1	21.7	14.6
	PrecMin	55.1	0.0	0.0	0.2	0.3	3.1	4.3	0.3	0.4	2.2	0.5	0.3	0.1
	PrecStd	15.9	1.8	1.7	1.8	3.5	7.8	7.9	7.6	4.3	5.5	3.9	3.9	3.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	90.4	91.2	90.8	89.3	86.2	83.9	82.9	83.7	85.9	87.3	88.2
		MCWB	78.6	80.1	80.2	80.4	80.3	79.2	76.8	76.3	77.8	78.7	79.8	79.0
	2%	DB	88.1	89.0	89.6	89.6	87.7	84.6	82.7	81.7	82.6	84.5	86.3	87.4
		MCWB	78.9	79.8	80.0	80.2	79.9	78.3	76.0	75.6	77.3	78.3	79.3	79.1
	5%	DB	87.1	87.9	88.4	88.5	86.4	83.7	81.8	80.7	81.9	83.8	85.6	86.4
		MCWB	78.7	79.7	79.8	80.1	79.4	77.8	75.7	75.2	77.0	78.0	78.9	78.9
	10%	DB	86.0	86.8	87.5	87.4	85.4	82.5	80.8	79.7	80.8	82.7	84.6	85.5
		MCWB	78.3	79.3	79.7	79.9	79.1	77.1	75.3	74.8	76.4	77.4	78.5	78.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.5	81.9	82.3	82.3	81.4	80.1	78.4	77.4	79.2	79.8	80.9	81.5
		MCDB	86.6	87.8	88.1	88.5	86.5	84.5	81.6	80.7	82.1	83.7	85.8	86.6
	2%	WB	80.6	81.0	81.1	81.3	80.7	79.2	77.3	76.6	78.1	79.0	80.0	80.3
		MCDB	86.2	86.8	87.1	87.5	85.9	83.5	80.8	79.7	81.3	83.3	85.1	85.7
	5%	WB	79.9	80.5	80.6	80.7	80.0	78.5	76.6	76.0	77.4	78.5	79.3	79.6
		MCDB	85.3	86.2	86.7	86.8	85.0	82.6	80.1	79.0	80.5	82.7	84.3	84.9
	10%	WB	79.2	79.8	80.0	80.1	79.4	77.6	76.0	75.5	76.9	77.8	78.9	79.0
		MCDB	84.4	85.3	85.8	85.8	84.1	81.4	79.4	78.3	79.9	81.8	83.8	84.1
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	13.7	13.4	12.7	10.2	7.4	6.9	6.5	6.6	8.6	10.7	12.6
		MCDBR	14.9	14.7	14.6	14.4	12.3	9.5	8.5	7.9	8.0	10.1	11.9	14.0
		MCWBR	7.4	6.7	6.4	6.3	5.7	4.5	4.1	3.9	4.1	4.9	6.0	6.9
	5% WB	MCDBR	13.5	13.9	13.7	13.5	11.7	9.1	7.5	7.2	7.5	9.5	11.5	12.9
		MCWBR	7.3	6.9	6.6	6.5	5.8	4.9	4.1	3.8	4.2	5.0	6.1	6.9
(40) Clear-Sky Solar Irradiance	taub		0.746	0.702	0.702	0.546	0.491	0.507	0.512	0.502	0.470	0.460	0.507	0.634
	taud		1.619	1.715	1.721	2.090	2.254	2.187	2.152	2.187	2.312	2.362	2.189	1.835
	Ebn at Noon		201	215	216	248	256	248	248	256	269	273	258	224
	Edh at Noon		85	78	78	53	44	46	48	47	43	41	47	67
(44) All-Sky Solar Radiation	RadAvg		1556	1515	1633	1602	1385	1225	1338	1361	1400	1531	1531	1482
	RadStd		98	75	89	84	91	86	100	87	59	69	57	48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page