

TABOU, Côte d'Ivoire

WMO: 655920

Lat: 4.417N

Lon: 7.367W

Elev: 21

StdP: 101.07

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.3	21.5	17.3	12.4	23.0	19.1	14.0	23.5	7.5	25.2	7.1	25.3	0.9	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.1	32.1	26.6	31.6	26.6	31.1	26.5	27.5	30.7	27.2	30.3	27.0	30.1	3.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	29.5	26.2	21.7	29.2	26.1	21.5	29.0	87.4	31.1	85.9	30.6	84.9	30.2	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	26.4	27.0	27.3	27.3	26.7	25.9	25.1	24.8	25.3	25.9	26.4	26.3
	DBStd	1.19	1.03	0.94	0.92	0.91	0.92	0.89	0.97	0.79	0.73	0.73	0.71	0.89
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5912	508	476	537	519	518	478	469	457	459	492	491	506
	CDD18.3	2870	250	243	279	269	259	228	211	199	209	233	241	248
	CDH23.3	24041	2204	2260	2757	2723	2431	1849	1359	999	1284	1823	2189	2162
CDH26.7	5947	713	776	978	948	644	242	88	36	83	266	540	632	
Wind	WSAvg	2.0	1.6	1.9	2.1	2.1	1.7	2.0	2.3	2.5	2.5	2.5	1.8	1.3
Precipitation	PrecAvg	2207	43	48	72	123	353	479	215	155	249	184	173	121
	PrecMax	2946	185	152	184	447	1014	877	1200	471	638	409	550	372
	PrecMin	1400	0	0	6	8	80	108	7	9	57	13	7	3
	PrecStd	405	45	42	46	89	198	200	193	110	140	100	98	94
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	32.4	32.9	32.7	31.8	30.1	28.9	28.3	28.7	29.9	30.7	31.2
		MCWB	25.9	26.7	26.8	26.9	26.9	26.2	24.9	24.6	25.5	25.9	26.5	26.1
	2%	DB	31.1	31.7	32.0	32.0	31.0	29.2	28.2	27.6	28.1	29.2	30.2	30.8
		MCWB	26.0	26.6	26.6	26.8	26.6	25.7	24.5	24.2	25.2	25.7	26.3	26.2
	5%	DB	30.6	31.1	31.3	31.4	30.2	28.7	27.7	27.0	27.7	28.8	29.8	30.2
		MCWB	25.9	26.5	26.6	26.7	26.3	25.4	24.3	24.0	25.0	25.6	26.1	26.0
	10%	DB	30.0	30.4	30.8	30.8	29.7	28.0	27.1	26.5	27.1	28.2	29.2	29.7
		MCWB	25.7	26.3	26.5	26.6	26.2	25.1	24.0	23.8	24.7	25.2	25.8	25.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.7	28.0	27.9	27.4	26.7	25.8	25.2	26.2	26.5	27.1	27.5
		MCDB	30.3	31.0	31.1	31.4	30.3	29.1	27.5	27.1	27.8	28.7	29.9	30.3
	2%	WB	27.0	27.2	27.3	27.4	27.0	26.2	25.2	24.8	25.6	26.1	26.7	26.9
		MCDB	30.1	30.4	30.6	30.8	30.0	28.6	27.1	26.5	27.4	28.5	29.5	29.8
	5%	WB	26.6	26.9	27.0	27.1	26.7	25.8	24.8	24.5	25.2	25.8	26.3	26.5
		MCDB	29.6	30.1	30.4	30.4	29.5	28.1	26.7	26.1	26.9	28.2	29.0	29.4
	10%	WB	26.2	26.6	26.7	26.7	26.3	25.4	24.5	24.1	24.9	25.5	26.0	26.1
		MCDB	29.1	29.6	29.9	29.9	29.0	27.4	26.4	25.7	26.6	27.7	28.8	29.0
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.6	7.4	7.1	5.7	4.1	3.8	3.6	3.7	4.8	5.9	7.0
		MCDBR	8.3	8.2	8.1	8.0	6.8	5.3	4.7	4.4	4.4	5.6	6.6	7.8
		MCWBR	4.1	3.7	3.6	3.5	3.2	2.5	2.3	2.2	2.3	2.7	3.3	3.8
	5% WB	MCDBR	7.5	7.7	7.6	7.5	6.5	5.0	4.1	4.0	4.1	5.3	6.4	7.2
		MCWBR	4.0	3.8	3.7	3.6	3.2	2.7	2.3	2.1	2.4	2.8	3.4	3.8
Clear-Sky Solar Irradiance	taub	0.746	0.702	0.702	0.546	0.491	0.507	0.512	0.502	0.470	0.460	0.507	0.634	
	taud	1.619	1.715	1.721	2.090	2.254	2.187	2.152	2.187	2.312	2.362	2.189	1.835	
	Ebn at Noon	634	679	682	782	807	781	782	806	848	861	814	706	
	Edh at Noon	267	247	246	167	138	145	151	149	134	128	149	212	
All-Sky Solar Radiation	RadAvg	4.91	4.78	5.15	5.05	4.37	3.86	4.22	4.29	4.41	4.83	4.83	4.67	
	RadStd	0.31	0.24	0.28	0.27	0.29	0.27	0.32	0.27	0.18	0.22	0.18	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page