

SASSANDRA, Côte d'IvoireWMO: **655990**Lat: **4.950N**Lon: **6.083W**Elev: **217**StdP: **14.58**Time Zone: **0.00 (E00)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	70.8	71.7	60.9	80.4	77.5	67.7	102.5	76.6	13.5	80.4	11.8	78.5	1.8	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.9	89.9	80.7	89.3	80.5	88.2	80.2	82.1	88.2	81.6	87.5	81.0	86.7	1.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	159.1	86.0	79.9	156.2	85.4	79.2	153.0	84.7	46.1	88.5	45.4	88.2	44.9	87.5	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.5	7.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			62.4	84.0	4.6	0.8	59.1	84.6	56.4	85.1	53.8	85.5	50.5	86.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.0	81.2	81.6	82.0	82.2	80.8	79.0	77.7	76.8	77.7	79.5	80.5	80.8
	DBStd	2.38	1.88	1.98	1.79	1.83	1.80	1.75	1.32	1.30	1.45	1.48	1.37	1.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10941	966	885	992	965	956	870	860	830	832	916	915	954
	CDD65	5466	501	465	527	515	491	420	395	365	382	451	465	489
	CDH74	47998	4929	4613	5480	5609	4864	3305	2353	1702	2111	3687	4568	4777
CDH80	12570	1542	1453	1827	1952	1385	515	228	119	244	704	1217	1384	
Wind	WSAvg	1.8	1.7	0.5	0.7	1.0	2.0	2.1	2.8	3.3	2.2	2.5	1.6	1.8
Precipitation	PrecAvg	58.3	0.9	1.3	2.0	4.1	9.3	19.0	6.5	1.5	1.7	4.4	5.0	2.7
	PrecMax	88.0	4.5	5.4	4.8	11.1	23.9	48.6	29.5	6.7	7.3	11.4	12.0	8.2
	PrecMin	30.8	0.0	0.0	0.0	0.1	1.1	3.5	0.2	0.2	0.0	0.1	0.5	0.0
	PrecStd	13.7	1.1	1.3	1.1	2.5	4.9	10.5	6.8	1.3	1.5	3.3	2.7	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.0	90.9	91.3	89.5	87.0	84.4	83.6	84.6	86.4	88.7	89.3
		MCWB	78.6	80.7	80.9	81.9	80.8	79.7	77.4	76.6	77.5	79.3	80.5	80.1
	2%	DB	88.8	89.3	89.6	89.9	88.1	85.3	83.2	82.4	83.4	85.7	87.7	88.0
		MCWB	79.5	80.5	80.6	81.3	80.6	78.8	76.8	75.9	77.0	78.8	80.3	79.9
	5%	DB	87.9	88.2	88.5	89.1	87.4	84.1	82.4	81.3	82.4	84.5	86.4	87.3
		MCWB	79.4	80.0	80.3	81.0	80.4	78.1	76.4	75.5	76.6	78.3	79.4	79.7
	10%	DB	86.8	87.2	87.5	87.9	86.1	82.9	81.2	80.4	81.4	83.8	85.7	86.1
		MCWB	78.9	79.6	80.1	80.5	79.8	77.7	76.0	75.2	76.3	78.0	79.1	79.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	82.6	82.7	82.8	82.4	80.7	78.9	77.7	78.8	80.2	81.4	81.8
		MCDB	87.7	89.1	88.5	89.3	87.8	85.6	83.1	81.7	83.1	85.2	86.7	87.7
	2%	WB	80.9	81.6	81.7	82.1	81.1	79.5	77.8	76.8	77.8	79.2	80.6	80.9
		MCDB	86.9	87.6	87.5	88.5	86.6	84.1	81.9	80.8	82.1	84.2	86.7	86.8
	5%	WB	80.4	80.9	81.0	81.5	80.6	78.8	77.1	76.2	77.2	78.9	79.9	80.3
		MCDB	86.2	86.5	86.6	87.5	86.2	83.1	81.2	80.1	81.5	83.8	85.6	86.0
	10%	WB	79.9	80.3	80.5	80.9	80.0	78.1	76.5	75.6	76.6	78.3	79.2	79.7
		MCDB	85.1	85.4	85.9	86.5	85.1	82.0	80.3	79.4	80.5	82.8	84.5	84.9
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.1	12.1	11.9	10.6	8.3	7.9	8.1	8.3	9.4	11.1	11.8
		MCDBR	13.5	13.0	12.9	13.0	12.2	9.9	9.0	9.2	9.3	10.2	12.0	12.7
		MCWBR	6.3	5.6	5.5	5.8	5.8	5.0	4.4	4.5	4.2	4.8	6.0	6.4
	5% WB	MCDBR	12.5	12.4	12.3	12.4	11.6	9.5	8.3	8.7	8.9	9.7	11.9	11.9
		MCWBR	6.0	5.7	5.6	5.8	5.9	5.1	4.4	4.6	4.4	4.9	6.2	6.1
Clear-Sky Solar Irradiance	taub	0.754	0.718	0.722	0.561	0.497	0.503	0.507	0.493	0.467	0.465	0.520	0.647	
	taud	1.599	1.684	1.680	2.042	2.224	2.195	2.169	2.217	2.318	2.339	2.137	1.804	
	Ebn at Noon	199	212	212	245	254	249	250	258	270	271	254	220	
	Edh at Noon	86	81	81	56	45	45	47	46	42	41	50	69	
All-Sky Solar Radiation	RadAvg	1570	1538	1652	1649	1448	1250	1350	1353	1441	1559	1567	1496	
	RadStd	75	71	78	80	71	91	96	94	58	61	58	48	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page