

HAYAYA, Comoros

WMO: 670020

Lat: 11.534S

Lon: 43.272E

Elev: 93

StdP: 14.65

Time Zone: 3.00 (E03)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	67.7	68.4	59.0	74.7	73.4	61.0	80.3	73.9	27.2	80.9	25.0	81.4	5.4	100	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.5	91.4	78.4	90.0	78.6	89.4	78.6	81.8	87.4	81.1	87.1	80.6	86.9	12.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.5	158.8	86.0	79.2	152.1	85.2	78.9	150.5	85.1	45.7	87.5	44.9	87.9	44.3	86.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.2	20.5	18.0	DB	65.1	94.0	0.7	0.9	64.5	94.6	64.1	95.1	63.7	95.6	63.2	96.2
			WB	59.5	85.1	1.0	1.1	58.8	85.9	58.2	86.6	57.7	87.2	56.9	88.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.1	81.7	81.7	82.0	81.9	80.4	78.3	77.0	76.3	77.3	79.7	82.1	82.3
	DBStd	2.85	1.79	1.70	1.58	1.73	1.83	1.74	1.77	1.78	1.96	2.41	2.18	1.65
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10969	984	887	991	958	943	850	837	816	818	922	962	1001
	CDD65	5494	519	467	526	508	478	400	372	351	368	457	512	536
	CDH74	52530	5571	4950	5510	5241	4655	3280	2695	2472	2746	4118	5446	5846
	CDH80	16746	1946	1697	1964	1801	1533	856	570	462	568	1210	1960	2179
Wind	WSAvg	7.8	7.1	6.5	6.3	7.3	8.4	9.1	9.3	8.3	8.0	8.5	8.5	6.5
Precipitation	PrecAvg	47.0	8.6	6.9	7.1	5.7	3.6	2.2	1.7	1.2	1.0	1.8	2.4	4.7
	PrecMax	74.3	16.8	13.5	14.7	10.6	9.5	3.7	3.1	2.5	4.2	6.7	11.1	13.9
	PrecMin	30.5	3.1	2.5	3.3	2.3	1.2	1.1	1.0	0.7	0.2	0.6	0.6	0.9
	PrecStd	11.8	3.3	2.8	3.1	2.4	1.9	0.7	0.5	0.4	0.8	1.2	2.0	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.2	90.9	91.5	91.5	90.0	88.2	86.7	87.0	87.8	91.1	93.2	91.8
		MCWB	79.5	79.5	79.6	79.5	77.0	74.7	73.2	72.7	74.1	76.4	77.8	78.1
	2%	DB	89.6	89.5	89.9	89.8	88.6	86.6	85.8	85.1	86.0	89.0	91.1	90.3
		MCWB	79.9	79.7	79.7	79.0	77.0	74.8	73.1	73.1	73.9	76.2	77.6	78.6
	5%	DB	88.2	88.1	88.9	88.7	87.6	85.7	84.4	84.0	84.4	87.4	89.4	89.3
		MCWB	79.7	79.7	79.7	79.0	77.0	74.8	73.5	73.3	74.2	76.0	77.5	78.9
	10%	DB	87.6	87.5	87.8	87.6	86.3	84.4	83.0	82.5	83.0	85.8	87.8	87.9
		MCWB	79.6	79.5	79.8	79.0	76.6	74.8	73.4	73.2	74.2	76.0	77.8	79.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.9	82.3	82.5	82.1	80.6	79.6	78.8	77.9	78.3	80.7	82.2	82.1
		MCDB	87.8	87.6	87.5	87.4	87.0	83.9	83.1	82.6	82.8	85.4	87.7	88.3
	2%	WB	81.4	81.0	81.3	81.0	79.3	78.2	76.6	76.4	77.0	79.4	80.7	80.9
		MCDB	87.2	86.8	87.1	87.2	86.2	83.7	82.3	81.9	82.5	84.8	86.7	87.6
	5%	WB	80.5	80.5	80.5	80.2	78.4	77.1	75.5	75.3	76.2	78.5	79.8	80.1
		MCDB	86.9	86.4	86.9	86.6	85.5	83.4	81.9	81.4	82.0	84.2	86.2	86.9
	10%	WB	79.8	79.9	79.9	79.5	77.6	76.1	74.5	74.4	75.4	77.5	79.0	79.6
		MCDB	85.8	85.6	86.1	85.9	84.7	82.6	81.2	80.8	81.5	83.6	85.8	86.4
Mean Daily Temperature Range	5% DB	MDBR	11.4	11.4	12.2	12.2	13.4	13.7	13.9	14.2	13.4	13.0	12.7	12.5
		MCDBR	12.8	12.8	13.5	13.6	14.4	15.1	15.2	15.4	14.6	14.2	14.1	13.8
		MCWBR	7.2	7.1	7.1	6.7	7.7	8.5	9.1	9.3	7.8	6.7	6.6	7.3
	5% WB	MCDBR	12.0	11.9	12.9	12.9	13.6	14.1	14.2	14.4	13.7	13.4	13.2	12.9
		MCWBR	7.3	7.1	7.3	7.0	7.9	9.0	9.9	9.8	8.7	8.2	7.7	7.7
Clear-Sky Solar Irradiance	taub		0.439	0.431	0.398	0.386	0.377	0.363	0.360	0.365	0.388	0.409	0.417	0.405
	taud		2.449	2.475	2.590	2.613	2.608	2.618	2.613	2.585	2.497	2.462	2.461	2.537
	Ebn at Noon		287	288	292	286	279	278	282	288	291	291	292	297
	Edh at Noon		38	37	32	30	29	28	28	30	35	37	38	35
All-Sky Solar Radiation	RadAvg		1828	1826	1842	1766	1631	1546	1592	1797	1969	2124	2185	2058
	RadStd		181	150	110	115	77	56	46	37	58	59	85	125

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page