

PAMANDZI, Mayotte

WMO: 670050

Lat: 12.805S

Lon: 45.281E

Elev: 23

StdP: 14.68

Time Zone: 3.00 (E03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.3	70.4	62.7	85.2	76.8	64.1	89.6	77.0	23.5	78.0	21.8	78.6	2.6	240	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.7	89.8	79.4	89.1	79.3	88.1	79.0	81.0	87.1	80.6	86.8	80.1	86.1	9.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.7	84.8	78.9	150.2	84.6	78.4	147.8	84.3	44.8	87.9	44.3	86.5	43.7	86.7	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.7	19.5	17.6	DB	66.6	91.4	1.3	1.2	65.7	92.2	64.9	92.9	64.2	93.6	63.2	94.4
			WB	62.9	82.4	2.7	1.1	60.9	83.2	59.4	83.9	57.9	84.5	55.9	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	82.7	82.8	83.1	82.9	81.5	79.2	77.4	76.7	77.9	80.2	81.8	82.8
	DBStd	2.79	1.75	1.62	1.58	1.46	1.67	1.69	1.57	1.54	1.54	1.66	1.62	1.48
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11222	1014	917	1025	988	978	876	849	829	838	936	955	1017
	CDD65	5747	549	497	560	538	513	426	384	364	388	471	505	552
	CDH74	58562	6276	5731	6553	6297	5504	3808	2769	2545	3007	4410	5351	6311
	CDH80	16971	2140	1978	2386	2273	1555	660	274	302	547	1118	1583	2155
Wind	WSAvg	8.5	9.0	7.8	6.9	7.5	9.9	11.2	11.7	9.1	7.4	7.2	7.5	7.0
Precipitation	PrecAvg	49.4	11.5	9.1	8.9	3.9	1.4	0.8	0.5	0.6	0.9	1.7	3.3	6.9
	PrecMax	69.5	19.1	17.3	14.6	9.8	4.1	3.0	1.3	2.2	2.1	4.4	7.4	17.1
	PrecMin	34.1	4.4	3.3	4.1	0.9	0.0	0.0	0.1	0.1	0.2	0.3	0.7	2.3
	PrecStd	8.6	4.0	3.3	2.8	2.1	1.1	0.7	0.3	0.5	0.6	1.1	2.0	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	89.9	90.3	89.9	88.2	86.3	84.5	84.5	86.1	88.1	89.6	90.0
		MCWB	79.0	79.4	79.9	80.2	78.4	76.0	74.0	74.4	75.3	77.2	79.0	78.6
	2%	DB	88.6	89.0	89.6	89.1	87.5	85.1	83.0	83.2	84.5	86.5	88.1	89.3
		MCWB	79.1	79.5	79.8	79.7	78.0	75.2	73.1	73.5	74.7	76.4	78.1	78.5
	5%	DB	87.9	88.0	88.2	88.0	86.3	84.3	82.5	82.5	84.0	85.9	87.4	88.0
		MCWB	79.1	79.4	79.6	79.2	77.2	74.8	72.9	72.9	74.4	76.1	77.8	78.4
	10%	DB	87.2	87.4	87.8	87.5	85.8	83.3	81.5	81.8	82.7	84.6	86.2	87.4
		MCWB	78.9	79.3	79.6	78.9	76.9	74.2	72.4	72.6	73.5	75.4	77.1	78.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.3	81.9	82.0	80.1	78.0	76.1	76.2	77.3	79.4	80.9	80.8
		MCDB	87.0	87.1	87.7	87.7	86.5	84.4	82.2	82.6	84.1	85.5	87.5	87.4
	2%	WB	80.4	80.6	81.0	80.8	79.2	76.5	74.7	74.8	76.0	78.1	79.7	80.0
		MCDB	86.7	86.7	87.1	86.8	85.5	83.0	81.0	81.3	82.7	84.4	86.0	86.5
	5%	WB	79.8	80.0	80.4	80.0	78.4	75.7	74.0	74.1	75.3	77.2	78.7	79.3
		MCDB	86.0	85.9	86.6	86.0	84.5	82.3	80.3	80.6	81.7	83.6	84.9	85.8
	10%	WB	79.2	79.6	79.9	79.6	77.7	75.0	73.3	73.3	74.5	76.4	77.9	78.9
		MCDB	85.1	85.3	85.7	85.5	83.8	81.6	79.6	79.8	80.9	82.8	84.1	85.2
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	9.7	9.4	8.6	8.7	9.1	10.9	11.1	10.5	9.5	9.6
		MCDBR	9.7	10.0	10.3	10.1	9.2	9.6	9.9	11.6	11.5	11.1	10.1	10.3
		MCWBR	4.2	4.3	4.3	4.3	4.2	4.5	4.7	5.3	4.9	4.5	4.1	4.2
	5% WB	MCDBR	9.1	9.5	9.7	9.6	9.0	9.4	9.6	11.0	10.8	10.3	9.5	9.7
		MCWBR	4.4	4.5	4.5	4.6	4.5	4.6	4.9	5.4	5.0	4.7	4.3	4.3
Clear-Sky Solar Irradiance	taub	0.427	0.421	0.393	0.375	0.365	0.351	0.348	0.356	0.385	0.414	0.436	0.409	
	taud	2.493	2.513	2.610	2.653	2.648	2.661	2.654	2.618	2.512	2.451	2.413	2.532	
	Ebn at Noon	291	291	293	289	282	281	285	291	291	290	286	296	
	Edh at Noon	37	36	32	29	28	26	27	30	35	38	40	35	
All-Sky Solar Radiation	RadAvg	1745	1795	1808	1789	1674	1582	1640	1835	1997	2107	2081	1955	
	RadStd	143	136	108	86	61	43	32	29	51	59	83	99	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page