

QUELIMANE, Mozambique

WMO: 672830

Lat: 17.856S

Lon: 36.869E

Elev: 36

StdP: 14.68

Time Zone: 2.00 (E02)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	57.4	59.3	55.0	64.5	66.2	56.8	68.8	67.4	18.4	75.7	15.5	75.7	1.9	300	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	15.7	98.2	77.9	95.1	79.0	93.3	78.7	82.5	91.2	81.6	89.8	80.8	88.6	9.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.5	158.8	86.3	79.4	152.8	85.4	78.9	150.3	85.0	46.4	92.0	45.4	90.1	44.5	88.6	91.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	16.1	14.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.5	83.3	83.1	82.3	79.2	75.4	72.0	71.2	73.2	76.6	80.1	83.1	83.4
	DBStd	5.52	2.45	2.27	2.37	2.64	2.66	2.72	3.13	3.47	4.40	4.19	3.87	3.05
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD50	10417	1031	927	1002	875	787	661	656	718	799	932	994	1035
	CDD65	4943	566	507	537	425	322	211	192	253	349	467	544	570
	CDH74	47642	6241	5649	5684	3691	2251	1246	1131	1786	2854	4558	6036	6515
	CDH80	18015	2515	2327	2128	1178	611	224	236	487	1006	1812	2674	2817
(14) Wind	WSAvg	6.1	6.0	5.6	5.1	5.1	4.4	4.8	5.0	6.1	7.7	8.1	7.7	7.3
(15) Precipitation	PrecAvg	60.2	10.4	9.8	8.6	5.7	3.5	2.0	3.0	1.3	0.6	0.9	3.0	7.7
	PrecMax	83.5	31.5	23.6	17.7	17.1	17.5	5.0	20.0	5.7	3.4	6.4	9.3	24.2
	PrecMin	32.4	3.4	2.3	0.6	1.3	0.3	0.1	0.3	0.0	0.0	0.0	0.0	0.6
	PrecStd	14.7	6.3	5.1	4.4	3.2	3.1	1.1	3.1	1.4	0.7	1.3	2.5	6.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.0	96.7	94.9	92.9	92.8	88.3	90.0	93.0	98.3	101.3	103.8	99.4
		MCWB	80.7	80.4	81.7	79.0	76.5	72.4	69.9	71.0	73.1	75.5	77.3	80.1
	2%	DB	94.0	93.6	91.8	89.6	87.7	84.5	85.9	87.8	92.8	95.4	98.5	95.3
		MCWB	80.3	79.9	80.4	78.6	75.2	71.5	71.0	71.2	74.2	76.4	77.2	80.7
	5%	DB	92.0	91.7	90.1	87.8	85.5	82.4	82.4	84.5	88.4	91.2	93.8	93.3
		MCWB	80.1	79.3	79.8	77.4	74.1	71.0	70.7	71.4	73.5	75.9	77.7	80.0
	10%	DB	89.9	89.9	88.8	86.1	83.8	80.6	80.2	82.4	85.6	88.1	91.3	91.2
		MCWB	79.4	78.8	79.1	76.3	72.7	70.3	69.5	71.0	73.1	75.1	77.0	79.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.5	82.8	83.0	81.2	79.3	75.8	74.9	75.6	77.5	80.5	82.3	83.5
		MCDB	92.4	91.2	90.8	88.5	86.0	82.8	81.9	84.0	89.6	92.8	93.4	92.5
	2%	WB	82.0	81.8	82.0	79.8	77.1	74.3	73.1	73.8	75.9	78.5	80.5	82.1
		MCDB	90.1	89.5	89.5	86.7	83.9	81.1	80.0	82.0	86.2	89.6	90.4	91.4
	5%	WB	81.0	80.8	80.9	78.9	75.4	72.9	71.8	72.8	75.0	77.3	79.2	80.9
		MCDB	88.7	88.1	87.8	85.4	82.4	79.2	79.0	80.7	84.3	86.1	88.7	89.2
	10%	WB	80.3	80.1	80.1	77.9	74.2	71.7	70.8	71.9	73.8	76.4	78.3	80.1
		MCDB	87.6	87.0	86.5	83.9	81.1	78.3	77.7	79.2	81.9	84.4	87.2	87.9
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	14.6	13.6	14.9	18.1	19.0	19.3	21.0	20.5	19.0	18.1	15.7
		MCDBR	17.5	17.4	15.4	16.5	20.2	21.4	22.9	23.6	23.6	23.1	22.2	18.2
	5% WB	MCWBR	6.7	6.5	6.3	7.1	9.2	10.4	10.4	10.4	9.2	8.3	7.5	6.8
		MCWBR	15.2	15.0	14.1	14.8	18.4	18.8	20.3	21.3	20.7	18.9	19.0	16.5
(40) Clear-Sky Solar Irradiance	taub	taub	0.426	0.414	0.403	0.380	0.359	0.347	0.359	0.405	0.489	0.476	0.456	0.436
		taud	2.434	2.467	2.491	2.519	2.539	2.553	2.506	2.343	2.111	2.189	2.283	2.391
	Ebn at Noon	Ebn at Noon	292	292	288	284	279	276	276	272	259	272	281	289
		Edh at Noon	39	37	35	32	30	28	30	38	51	49	45	41
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1961	1954	1820	1662	1468	1315	1347	1624	1863	2036	2087	2040
	RadStd	RadStd	172	154	137	73	56	69	54	67	57	90	128	89

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page