

QUELIMANE, Mozambique

WMO: 672830

Lat: 17.856S

Lon: 36.869E

Elev: 11

StdP: 101.19

Time Zone: 2.00 (E02)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	15.2	12.8	9.2	19.0	13.8	9.8	19.6	8.2	24.3	6.9	24.3	0.8	300	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.7	36.8	25.5	35.1	26.1	34.0	25.9	28.1	32.9	27.6	32.1	27.1	31.4	4.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	30.2	26.3	21.8	29.7	26.1	21.5	29.5	90.0	33.3	87.6	32.3	85.7	31.5	32.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.2	6.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	28.5	28.4	28.0	26.2	24.1	22.2	21.8	22.9	24.8	26.7	28.4	28.6
	DBStd	3.07	1.36	1.26	1.32	1.46	1.48	1.51	1.74	1.93	2.44	2.33	2.15	1.69
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD10.0	5787	573	515	557	486	437	367	364	399	444	518	552	575
	CDD18.3	2746	314	282	298	236	179	117	107	141	194	259	302	317
	CDH23.3	26468	3467	3138	3158	2051	1251	692	628	992	1586	2532	3353	3619
(13)	CDH26.7	10008	1397	1293	1182	654	339	124	131	271	559	1007	1486	1565
(14)	Wind	WSAvg	2.7	2.7	2.5	2.3	2.3	2.0	2.2	2.7	3.4	3.6	3.4	3.2
(15) Precipitation	PrecAvg	1530	265	248	218	144	89	50	75	32	15	24	77	195
	PrecMax	2120	800	600	450	434	445	128	509	146	87	163	237	615
	PrecMin	824	87	58	14	33	7	2	8	0	0	0	0	16
	PrecStd	373	160	129	112	82	78	29	80	35	18	32	63	152
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	35.9	34.9	33.9	33.8	31.3	32.2	33.9	36.8	38.5	39.9	37.5
		MCWB	27.0	26.9	27.6	26.1	24.7	22.4	21.1	21.7	22.8	24.2	25.2	26.7
	2%	DB	34.5	34.2	33.2	32.0	30.9	29.2	30.0	31.0	33.8	35.2	36.9	35.2
		MCWB	26.8	26.6	26.9	25.9	24.0	22.0	21.6	21.8	23.5	24.6	25.1	27.0
	5%	DB	33.3	33.1	32.3	31.0	29.7	28.0	28.0	29.2	31.3	32.9	34.3	34.0
		MCWB	26.7	26.3	26.5	25.2	23.4	21.6	21.5	21.9	23.0	24.4	25.4	26.6
	10%	DB	32.2	32.2	31.5	30.0	28.8	27.0	26.8	28.0	29.8	31.2	32.9	32.9
		MCWB	26.3	26.0	26.2	24.6	22.6	21.3	20.8	21.7	22.8	24.0	25.0	26.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	28.2	28.3	27.3	26.3	24.3	23.8	24.2	25.3	26.9	28.0	28.6
		MCDB	33.6	32.9	32.7	31.4	30.0	28.2	27.7	28.9	32.0	33.8	34.1	33.6
	2%	WB	27.8	27.7	27.8	26.6	25.0	23.5	22.8	23.2	24.4	25.8	27.0	27.8
		MCDB	32.3	31.9	31.9	30.4	28.8	27.3	26.7	27.8	30.1	32.0	32.5	33.0
	5%	WB	27.2	27.1	27.1	26.0	24.1	22.7	22.1	22.7	23.9	25.2	26.2	27.1
		MCDB	31.5	31.2	31.0	29.6	28.0	26.2	26.1	27.1	29.1	30.0	31.5	31.8
	10%	WB	26.8	26.7	26.7	25.5	23.5	22.1	21.5	22.2	23.2	24.6	25.7	26.7
		MCDB	30.9	30.5	30.3	28.8	27.3	25.7	25.4	26.2	27.7	29.1	30.7	31.0
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	8.1	7.6	8.3	10.1	10.6	10.7	11.7	11.4	10.6	10.0	8.7
		MCDBR	9.7	9.7	8.6	9.2	11.2	11.9	12.7	13.1	13.1	12.9	12.3	10.1
		MCWBR	3.7	3.6	3.5	3.9	5.1	5.8	5.8	5.1	4.6	4.1	3.8	
	5% WB	MCDBR	8.4	8.3	7.9	8.2	10.2	10.4	11.3	11.8	11.5	10.5	10.5	9.2
		MCWBR	3.8	3.8	3.6	3.9	5.1	5.7	5.7	5.8	5.1	4.3	4.1	4.0
(40) Clear-Sky Solar Irradiance	taub		0.426	0.414	0.403	0.380	0.359	0.347	0.359	0.405	0.489	0.476	0.456	0.436
	taud		2.434	2.467	2.491	2.519	2.539	2.553	2.506	2.343	2.111	2.189	2.283	2.391
	Ebn at Noon		921	922	909	894	878	871	870	856	818	856	887	911
	Edh at Noon		124	118	111	102	93	88	95	119	160	154	143	129
(44) All-Sky Solar Radiation	RadAvg		6.18	6.16	5.74	5.24	4.63	4.15	4.25	5.12	5.87	6.42	6.58	6.43
	RadStd		0.54	0.49	0.43	0.23	0.17	0.22	0.17	0.21	0.18	0.28	0.41	0.28

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page