

MAPUTO, Mozambique

WMO: 673410

Lat: 25.921S

Lon: 32.573E

Elev: 145

StdP: 14.62

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	53.5	55.4	37.6	33.3	71.3	42.5	40.4	70.5	32.2	68.9	28.1	69.4	4.2	210	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.5	96.8	75.2	93.3	74.8	91.0	74.6	79.9	89.0	78.9	87.5	78.0	86.1	13.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	143.1	83.5	76.7	140.1	83.1	75.5	134.4	82.3	43.5	89.8	42.5	87.7	41.6	86.1	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	22.6	19.1	DB	47.9	105.8	1.7	3.2	46.6	108.0	45.6	109.9	44.6	111.7	43.3	114.0	(4)
(5)			WB	46.1	82.4	2.5	1.1	44.3	83.1	42.8	83.8	41.4	84.4	39.5	85.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.0	80.9	81.0	79.9	76.0	72.5	69.1	67.5	70.5	72.5	74.7	76.7	79.6	(6)	
	DBStd	5.98	3.41	2.96	3.39	3.69	3.45	3.08	3.41	4.24	4.91	4.85	4.76	4.43	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	24	0	0	0	0	0	3	14	4	3	0	0	0	(9)	
	CDD50	9139	956	868	927	779	698	572	543	634	676	767	802	917	(10)	
	CDD65	3689	491	448	462	329	233	125	92	174	229	302	352	452	(11)	
	CDH74	29204	4789	4409	4186	2268	1385	764	622	1089	1362	1872	2515	3943	(12)	
	CDH80	9717	1711	1565	1462	657	364	174	152	367	486	617	790	1372	(13)	
(14) Wind	WSAvg	9.6	10.4	10.0	9.3	8.7	7.6	7.8	8.8	10.1	10.7	10.5	11.0	10.4	(14)	
(15) Precipitation	PrecAvg	31.1	6.7	5.4	3.7	2.1	1.1	0.6	0.7	0.5	1.4	2.3	3.0	3.3	(15)	
	PrecMax	49.4	31.5	19.7	10.9	7.8	6.0	2.4	6.3	1.6	12.6	8.8	7.5	8.3	(16)	
	PrecMin	14.4	0.2	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.6	0.3	(17)	
	PrecStd	9.6	5.7	4.4	2.6	1.7	1.3	0.6	1.3	0.5	2.2	1.9	1.8	2.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.6	96.5	97.0	94.6	91.9	89.7	89.4	93.5	98.1	100.4	98.2	101.0	(19)	
		MCWB	78.7	78.1	77.8	74.2	69.3	63.4	63.6	65.6	67.6	72.8	73.2	78.2	(20)	
	2%	DB	93.0	91.7	91.7	89.6	87.5	84.5	84.4	88.0	90.9	91.7	91.7	94.0	(21)	
		MCWB	78.1	77.5	76.7	73.5	69.2	64.5	63.3	66.5	68.6	72.2	74.8	77.7	(22)	
	5%	DB	89.9	89.6	89.4	86.2	84.0	80.9	80.6	83.9	85.4	85.8	87.6	89.8	(23)	
		MCWB	76.5	76.3	76.0	72.6	69.1	65.0	63.6	66.5	68.8	72.1	74.2	76.8	(24)	
	10%	DB	87.9	87.8	87.0	83.9	80.8	78.5	77.1	79.5	80.8	82.3	84.2	86.7	(25)	
		MCWB	75.8	75.7	75.1	72.3	68.8	65.0	64.0	66.0	68.6	70.6	73.0	75.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.0	80.1	77.9	75.4	70.9	69.7	72.4	73.8	77.2	78.7	80.8	(27)	
		MCDB	91.3	88.5	88.6	86.6	82.6	78.0	75.8	82.0	84.3	86.9	89.5	92.6	(28)	
	2%	WB	79.6	79.6	78.9	76.1	73.2	69.1	67.7	70.3	72.2	74.9	77.0	79.2	(29)	
		MCDB	88.6	87.0	86.9	84.4	80.6	76.6	75.1	78.5	81.3	83.4	85.0	89.9	(30)	
	5%	WB	78.5	78.6	77.7	74.8	71.8	67.8	66.6	69.1	71.0	73.6	75.7	77.9	(31)	
		MCDB	86.5	86.0	85.2	82.6	79.1	75.6	74.4	77.1	79.3	81.9	82.9	87.2	(32)	
	10%	WB	77.5	77.4	76.7	73.7	70.5	66.8	65.4	67.9	69.8	72.2	74.7	76.7	(33)	
		MCDB	84.7	84.7	83.8	81.0	77.7	74.7	73.5	75.6	77.5	79.8	81.4	84.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	14.5	15.2	16.4	19.2	20.9	21.0	20.1	18.2	16.0	14.7	14.8	(35)	
		MCDBR	17.9	16.9	18.7	20.2	23.4	26.0	27.3	27.3	27.2	23.8	21.0	20.2	(36)	
		MCWBR	7.0	6.5	7.0	8.3	10.0	12.0	12.1	10.9	10.3	8.9	8.4	8.1	(37)	
	5% WB	MCDBR	16.0	15.2	16.2	17.5	19.5	21.3	21.4	21.0	20.5	19.8	17.4	17.9	(38)	
		MCWBR	7.1	6.9	6.7	8.1	9.4	11.7	11.7	10.4	9.6	8.6	7.4	7.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.440	0.424	0.425	0.413	0.383	0.372	0.372	0.437	0.493	0.504	0.473	0.459	(40)	
	taud		2.348	2.399	2.388	2.374	2.425	2.432	2.428	2.228	2.098	2.108	2.228	2.275	(41)	
	Ebn at Noon		288	287	278	265	260	256	261	253	253	261	277	283	(42)	
	Edh at Noon		43	40	38	36	31	29	30	40	50	52	48	46	(43)	
(44) All-Sky Solar Radiation	RadAvg		1948	1934	1688	1412	1261	1119	1172	1370	1546	1628	1793	1942	(44)	
	RadStd		141	144	102	82	50	65	47	92	87	105	127	158	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page