

WALVIS BAY PELICAN POINT, Namibia

WMO: 681040

Lat: 22.892S

Lon: 14.435E

Elev: 0

StdP: 101.33

Time Zone: 2.00 (E02)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	7.2	-9.2	1.7	21.9	-5.9	2.3	22.0	18.1	20.0	14.6	20.0	2.3	90	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.4	33.8	17.3	31.1	16.8	28.9	17.1	21.4	27.6	20.4	25.9	19.6	24.5	6.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.2	23.7	18.6	13.4	22.4	17.9	12.8	21.5	62.2	27.5	58.4	26.1	56.0	24.4	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.0	9.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	20.0	20.1	19.8	19.8	17.5	17.3	16.6	14.8	15.2	16.1	17.3	18.2
	DBStd	3.59	1.73	1.87	2.50	3.83	4.16	4.80	4.60	3.58	2.03	1.59	1.78	2.04
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	651	4	4	10	22	68	81	97	127	99	72	39	27
	CDD10.0	2811	308	282	305	294	232	218	204	149	154	189	219	254
	CDD18.3	420	54	53	57	65	42	50	43	18	4	3	9	23
	CDH23.3	2799	104	137	279	592	417	452	426	206	49	19	63	54
	CDH26.7	1067	11	17	80	263	183	192	181	96	17	3	18	6
Wind	WSAvg	3.7	3.8	3.8	3.5	3.3	3.4	3.9	3.9	3.6	3.7	3.6	3.9	4.2
Precipitation	PrecAvg	62	10	11	16	4	1	1	0	0	1	1	5	6
	PrecMax	171	76	74	62	32	4	3	8	3	10	13	28	40
	PrecMin	10	1	0	1	0	0	0	0	0	0	0	1	0
	PrecStd	49	18	16	15	8	1	1	2	1	2	3	7	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	29.5	31.8	36.1	35.8	34.2	33.9	33.9	29.0	25.2	28.1	28.0
		MCWB	19.6	20.1	20.5	19.9	17.6	16.1	15.7	15.5	14.8	16.7	18.7	19.4
	2%	DB	25.6	26.8	28.1	33.0	31.8	31.8	31.2	28.7	23.0	22.9	24.5	25.0
		MCWB	19.3	19.5	20.0	19.8	17.1	15.1	15.2	15.1	15.1	15.2	16.3	18.3
	5%	DB	24.1	25.0	25.9	29.4	27.8	28.8	28.2	23.5	20.9	21.2	23.0	23.4
		MCWB	18.6	19.1	19.3	19.1	16.5	14.3	14.2	13.1	14.9	15.2	15.8	17.7
	10%	DB	23.0	23.7	23.8	26.5	24.2	25.4	24.9	20.0	19.1	19.9	21.3	22.1
		MCWB	18.3	18.5	18.6	17.9	15.3	14.4	13.7	13.4	14.3	14.9	15.6	16.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	21.7	23.0	22.6	20.8	20.3	18.9	18.7	17.7	18.3	18.6	20.1
		MCDB	25.5	26.6	29.3	29.9	28.7	26.9	25.7	27.4	21.2	21.4	23.9	25.0
	2%	WB	20.2	20.3	21.1	20.9	18.4	17.4	16.9	16.2	16.2	16.8	17.2	19.0
		MCDB	23.5	24.7	26.4	30.3	26.4	25.1	26.1	22.4	20.7	20.3	22.1	23.7
	5%	WB	19.5	19.6	19.7	19.7	17.3	16.2	15.6	14.9	15.4	15.8	16.5	18.2
		MCDB	22.9	23.6	24.4	27.7	24.9	24.3	24.9	20.5	19.3	19.6	21.2	22.3
	10%	WB	18.8	19.0	18.7	18.4	16.2	15.2	14.5	14.1	14.7	15.1	15.9	17.5
		MCDB	22.2	22.6	23.0	25.1	22.7	22.5	22.1	18.5	18.3	19.0	20.5	21.1
Mean Daily Temperature Range	5% DB	MDBR	6.9	7.4	8.7	11.2	11.1	12.2	11.7	10.8	9.3	9.2	9.0	6.8
		MCDBR	8.5	9.6	11.7	16.1	16.8	16.3	16.1	17.5	13.3	11.3	12.0	9.7
		MCWBR	3.7	4.1	5.0	6.0	6.8	7.4	7.3	8.2	6.7	5.4	5.3	4.3
	5% WB	MCDBR	7.2	7.9	10.6	13.4	13.4	13.6	13.3	13.2	10.3	9.5	10.4	8.9
		MCWBR	3.8	3.9	5.1	5.8	6.2	7.5	7.2	7.4	5.6	5.2	5.0	4.3
Clear-Sky Solar Irradiance	taub	0.439	0.447	0.422	0.379	0.350	0.340	0.362	0.405	0.467	0.461	0.405	0.410	
	taud	2.288	2.284	2.338	2.423	2.442	2.427	2.368	2.242	2.035	2.105	2.315	2.316	
	Ebn at Noon	909	888	883	880	866	854	843	839	827	865	934	936	
	Edh at Noon	143	141	128	108	98	95	104	128	170	167	138	139	
All-Sky Solar Radiation	RadAvg	7.35	6.92	6.21	5.29	4.41	4.03	4.20	4.74	5.52	6.51	7.47	7.64	
	RadStd	0.31	0.29	0.24	0.25	0.19	0.15	0.15	0.24	0.26	0.21	0.37	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page