

HOSEA KUTAKO INTL, Namibia

WMO: 681120

Lat: 22.480S

Lon: 17.471E

Elev: 1719

StdP: 82.31

Time Zone: 2.00 (E02)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.2	0.4	-19.2	0.8	13.4	-16.9	1.1	14.3	9.5	20.0	8.5	19.9	2.3	250	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.4	33.9	14.4	32.9	14.2	32.0	14.1	19.0	24.7	18.5	24.4	18.0	24.1	3.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	15.5	20.8	16.9	14.9	20.5	16.2	14.3	20.1	62.2	24.8	60.2	24.6	58.4	24.1	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	23.7	22.9	21.1	19.1	15.3	12.5	11.8	14.9	18.6	21.7	22.6	23.7		
	DBStd	4.90	2.26	2.43	2.28	2.06	2.64	2.34	2.78	2.74	3.14	2.86	2.69	2.20		
	HDD10.0	29	0	0	0	0	2	8	16	3	1	0	0	0		
	HDD18.3	654	1	1	3	15	98	177	203	110	33	7	4	1		
	CDD10.0	3296	424	360	345	273	166	81	71	154	258	363	378	424		
	CDD18.3	880	167	128	91	37	4	0	0	2	41	112	132	166		
	CDH23.3	10462	1597	1188	871	469	186	34	37	248	875	1501	1617	1839		
	CDH26.7	3931	659	466	249	83	17	1	0	34	293	633	689	808		
(14) Wind	WSAvg	2.8	2.9	2.7	2.3	2.2	2.5	2.5	2.7	2.9	3.0	3.3	3.2	3.0		
(15) Precipitation	PrecAvg	389	82	101	94	34	7	2	0	0	2	13	22	29		
	PrecMax	627	210	290	315	101	37	13	2	2	18	74	72	106		
	PrecMin	205	8	0	6	0	0	0	0	0	0	0	0	0		
	PrecStd	113	61	80	81	29	11	5	1	1	5	20	22	30		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	34.2	32.2	30.1	28.9	26.1	25.6	29.1	32.1	34.4	34.2	35.0		
		MCWB	15.3	15.4	15.0	14.4	12.4	9.4	9.5	11.5	12.3	13.7	13.7	14.4		
	2%	DB	33.0	32.4	30.7	28.8	26.9	24.1	24.4	27.8	31.0	33.1	32.9	33.5		
		MCWB	14.9	15.2	14.7	14.1	11.9	9.5	9.2	10.7	12.2	13.0	13.7	14.4		
	5%	DB	31.9	31.1	29.5	27.4	25.5	23.1	23.1	26.2	29.9	31.8	31.9	32.2		
		MCWB	15.0	15.1	14.7	13.7	11.4	9.5	8.9	9.9	11.8	12.7	13.6	14.3		
	10%	DB	30.7	29.8	28.2	26.1	24.2	21.9	21.8	24.6	28.8	30.2	30.8	31.1		
		MCWB	15.1	15.3	15.1	13.8	11.3	9.2	8.5	9.4	11.4	12.5	13.5	14.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.7	19.7	19.0	17.9	14.7	12.2	11.5	12.7	14.6	16.5	18.0	18.4		
		MCDB	25.4	25.5	25.3	23.0	22.3	21.3	22.6	26.0	27.7	26.3	24.9	25.1		
	2%	WB	19.1	19.0	18.2	17.0	13.4	11.1	10.4	11.7	13.6	15.5	17.1	17.7		
		MCDB	24.7	24.8	24.3	22.4	22.4	20.6	22.1	25.1	26.4	25.3	24.2	25.0		
	5%	WB	18.5	18.5	17.6	16.4	12.6	10.4	9.5	10.7	12.8	14.7	16.5	17.1		
		MCDB	24.4	24.3	23.6	22.1	22.8	20.6	21.4	24.2	26.4	25.4	23.9	24.8		
	10%	WB	18.0	18.0	17.0	15.6	11.9	9.6	8.8	10.0	12.1	14.0	15.8	16.6		
		MCDB	24.1	23.9	23.0	21.7	22.4	20.4	20.6	23.3	26.3	25.4	23.8	24.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	13.2	13.6	14.1	17.3	18.8	18.8	19.0	18.9	16.9	16.0	14.4		
		MCDBR	15.6	15.8	15.5	16.4	18.6	20.5	20.4	21.0	20.1	18.9	17.7	16.7		
		MCWBR	5.4	5.6	5.8	6.6	7.9	9.8	9.9	10.0	8.9	7.7	7.0	5.8		
	5% WB	MCDBR	11.0	11.2	11.6	11.4	15.8	17.7	18.3	18.0	16.8	14.6	12.7	12.3		
		MCWBR	3.8	4.3	4.9	5.3	7.0	8.7	9.2	8.8	7.9	5.7	4.8	4.3		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.334	0.327	0.299	0.266	0.246	0.254	0.299	0.367	0.375	0.322	0.321		
	taud		2.509	2.530	2.526	2.569	2.604	2.601	2.547	2.387	2.201	2.235	2.468	2.514		
	Ebn at Noon		1009	996	977	965	963	967	967	949	920	944	1014	1023		
	Edh at Noon		115	110	106	93	82	79	86	110	144	146	119	114		
(44) All-Sky Solar Radiation	RadAvg		7.29	6.79	6.14	5.54	5.08	4.70	4.92	5.69	6.61	7.16	7.65	7.78		
	RadStd		0.49	0.55	0.37	0.38	0.12	0.11	0.08	0.16	0.21	0.31	0.41	0.43		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page