

QUEENSTOWN, South Africa

WMO: 686470

Lat: 31.918S

Lon: 26.878E

Elev: 1104

StdP: 88.75

Time Zone: 2.00 (E02)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.0	0.5	-12.0	1.5	14.9	-10.0	1.8	15.3	11.6	16.0	10.0	14.9	0.8	90	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	33.5	17.2	31.7	17.0	30.1	16.8	20.6	26.7	19.8	25.9	19.1	25.2	4.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	15.6	23.0	18.1	14.9	22.1	17.4	14.2	21.5	64.9	26.7	61.9	26.0	59.4	25.1	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	21.6	21.3	19.9	16.7	14.0	10.9	10.7	12.9	15.3	17.3	18.7	20.7
	DBStd	5.22	3.35	3.04	3.46	3.35	3.46	3.31	3.64	3.99	4.20	4.18	3.90	3.48
	HDD10.0	95	0	0	0	2	7	28	35	16	4	2	1	0
	HDD18.3	1126	12	9	25	68	140	222	236	174	108	71	43	17
	CDD10.0	2518	358	317	306	202	131	56	57	106	164	228	262	332
	CDD18.3	509	112	93	72	18	5	1	1	7	18	37	54	91
	CDH23.3	4151	878	602	484	117	55	2	0	57	267	415	487	787
	CDH26.7	1467	354	210	154	15	7	0	0	8	72	146	168	333
Wind	WSAvg	2.7	2.8	2.6	2.5	2.0	1.9	2.9	2.6	2.8	3.0	3.0	3.2	3.2
Precipitation	PrecAvg	492	64	82	73	39	15	15	9	19	23	50	58	67
	PrecMax	729	192	189	210	110	46	48	64	149	120	133	142	179
	PrecMin	306	1	8	7	7	0	0	0	0	0	0	5	6
	PrecStd	127	44	51	49	24	14	16	15	30	26	37	41	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	34.4	33.3	29.1	27.3	22.9	22.6	27.8	31.5	33.3	33.4	36.2
		MCWB	18.0	18.4	18.9	16.3	14.3	11.0	9.4	12.1	13.9	14.6	16.2	17.0
	2%	DB	32.7	31.7	30.3	26.5	24.8	20.5	21.2	24.8	28.5	30.6	30.8	32.9
		MCWB	18.0	18.7	17.6	15.5	12.6	9.7	9.3	10.9	12.6	14.6	16.2	16.8
	5%	DB	30.6	29.3	28.2	24.7	22.9	19.1	20.0	22.9	26.4	28.1	28.5	30.4
		MCWB	17.9	18.5	17.4	14.8	12.1	8.9	8.8	10.3	12.1	14.1	15.7	17.0
	10%	DB	28.2	27.1	26.0	22.8	21.1	17.5	18.4	20.9	24.0	25.4	26.2	27.7
		MCWB	17.7	18.7	17.3	14.4	11.4	8.4	8.2	9.8	11.7	13.8	15.6	17.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	22.0	21.7	17.9	15.2	12.1	10.9	13.9	15.7	17.6	19.2	20.6
		MCDB	28.6	28.3	27.0	24.6	23.4	17.5	19.9	21.8	24.2	25.8	26.1	27.4
	2%	WB	20.0	20.7	20.0	17.0	13.8	11.2	10.0	12.6	14.6	16.5	18.2	19.3
		MCDB	27.1	26.2	25.3	22.8	22.2	16.9	19.2	20.4	23.9	24.7	25.6	26.2
	5%	WB	19.3	20.0	18.8	16.2	13.0	10.5	9.5	11.6	13.7	15.7	17.5	18.6
		MCDB	26.0	25.7	24.4	21.6	21.2	16.2	18.1	20.2	22.0	23.6	24.6	25.6
	10%	WB	18.8	19.2	17.9	15.5	12.1	9.7	8.8	10.6	12.7	15.1	16.7	17.9
		MCDB	25.1	24.5	23.6	20.7	18.9	15.5	16.7	18.5	20.8	22.0	23.2	24.8
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.1	11.4	11.2	12.5	11.8	13.0	12.5	13.6	13.1	12.4	12.9
		MCDBR	16.2	14.9	14.7	14.2	15.2	13.9	14.2	15.3	17.5	18.1	16.9	17.8
		MCWBR	5.1	4.3	4.8	4.8	6.0	6.4	6.3	5.7	5.5	5.3	4.5	4.6
		MCDDBR	12.8	12.1	11.9	11.7	13.3	11.1	13.1	13.0	14.6	14.0	13.8	13.8
	5% WB	MCWBR	4.6	4.9	5.2	4.8	5.8	5.5	6.1	5.1	5.0	4.9	4.8	4.8
Clear-Sky Solar Irradiance	taub	0.339	0.341	0.326	0.298	0.280	0.265	0.266	0.312	0.342	0.350	0.329	0.333	
	taud	2.508	2.501	2.514	2.571	2.590	2.597	2.583	2.435	2.344	2.367	2.481	2.516	
	Ebn at Noon	1000	978	959	937	907	900	914	904	925	957	1003	1009	
	Edh at Noon	114	111	102	86	75	70	74	97	119	125	116	113	
All-Sky Solar Radiation	RadAvg	6.99	6.38	5.46	4.35	3.50	3.11	3.38	4.15	5.29	6.18	7.00	7.36	
	RadStd	0.41	0.40	0.35	0.23	0.15	0.18	0.18	0.27	0.32	0.39	0.38	0.46	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (9 neighbors)	+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page