

CAPE TOWN INTL, South Africa

WMO: 688160

Lat: 33.9631S

Lon: 18.6022E

Elev: 42

StdP: 100.82

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.1	5.3	0.8	4.0	13.6	2.1	4.4	11.9	13.4	14.1	12.1	14.1	1.6	50	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.8	31.9	19.8	29.9	19.3	28.1	18.7	21.2	28.0	20.6	27.0	20.0	25.8	5.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.0	22.9	18.6	13.5	22.5	18.0	13.0	22.1	62.0	28.2	59.4	27.0	57.3	26.2	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	12.0	10.9	1.5	36.4	1.0	1.6	0.7	37.5	0.1	38.4	-0.4	39.3	-1.2	40.5 (4)		
(5)			1.0	22.9	1.0	1.0	0.2	23.6	-0.4	24.2	-1.0	24.8	-1.7	25.6 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	21.7	21.9	20.4	17.9	15.4	13.2	12.6	13.0	14.5	16.8	18.5	20.7	(6)
(7)		DBStd	4.02	2.16	2.17	2.37	2.60	2.26	2.06	2.16	2.07	2.34	2.71	2.38	2.20	(7)
(8)		HDD10.0	5	0	0	0	0	0	1	3	1	0	0	0	0	(8)
(9)		HDD18.3	848	2	1	6	38	94	154	177	164	118	63	26	5	(9)
(10)		CDD10.0	2637	363	333	322	238	169	98	84	96	136	212	256	331	(10)
(11)		CDD18.3	437	107	101	69	26	4	1	1	1	3	16	32	77	(11)
(12)		CDH23.3	2682	595	567	398	197	57	17	17	21	53	151	192	417	(12)
(13)		CDH26.7	737	168	169	119	61	13	2	1	3	18	38	46	100	(13)
(14)	Wind	WSAvg	5.1	6.6	6.3	5.4	4.5	3.9	4.0	4.0	4.4	4.8	5.3	6.0	6.3	(14)
(15)	Precipitation	PrecAvg	508	11	13	17	41	65	95	81	76	42	30	21	16	(15)
(16)		PrecMax	750	59	53	72	179	144	231	208	215	138	110	86	89	(16)
(17)		PrecMin	298	0	0	0	4	5	23	0	14	8	1	0	1	(17)
(18)		PrecStd	112	10	14	16	31	36	45	44	38	26	26	20	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	33.5	34.0	32.1	28.3	25.9	25.7	26.1	29.1	30.4	30.5	32.0	(19)
(20)			MCWB	20.2	20.5	19.8	18.4	16.2	14.5	14.4	15.0	16.3	17.6	18.5	20.3	(20)
(21)		2%	DB	30.5	31.0	29.6	28.1	24.3	21.9	22.1	22.0	24.0	27.0	27.8	29.2	(21)
(22)			MCWB	20.2	20.3	19.2	17.9	15.6	13.5	13.5	13.7	15.4	17.0	17.8	19.4	(22)
(23)		5%	DB	28.2	28.8	27.1	25.2	21.9	19.0	19.1	19.1	21.1	24.7	25.2	27.2	(23)
(24)			MCWB	19.6	19.6	18.7	17.0	15.2	13.3	12.7	13.3	14.8	16.5	17.2	18.9	(24)
(25)		10%	DB	26.2	26.8	25.2	23.0	19.9	17.2	17.1	17.2	19.0	22.1	23.2	25.6	(25)
(26)			MCWB	19.1	19.4	18.4	16.6	15.0	13.1	12.8	13.2	14.0	15.8	16.7	18.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	22.3	21.5	19.9	17.7	16.2	15.6	16.5	17.6	19.4	20.2	21.4	(27)
(28)			MCDWB	29.9	29.0	28.9	28.4	23.0	20.3	20.8	22.5	24.5	27.5	27.4	29.0	(28)
(29)		2%	WB	21.2	21.2	20.5	18.9	16.8	15.2	14.7	15.2	16.3	18.1	18.9	20.4	(29)
(30)			MCDWB	27.8	27.5	26.8	25.2	20.9	18.0	18.7	19.1	21.6	24.6	25.2	26.9	(30)
(31)		5%	WB	20.4	20.6	19.7	18.1	16.1	14.5	14.0	14.3	15.4	17.1	18.0	19.6	(31)
(32)			MCDWB	26.3	26.5	25.2	23.2	19.9	17.2	17.6	17.5	19.8	22.7	23.5	25.6	(32)
(33)		10%	WB	19.7	19.8	18.9	17.3	15.5	13.9	13.3	13.6	14.6	16.2	17.3	18.9	(33)
(34)			MCDWB	24.9	25.2	23.7	21.6	18.8	16.6	16.4	16.5	18.2	20.8	22.0	24.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.8	10.1	10.5	9.7	9.4	9.9	9.3	9.4	10.0	9.3	9.3	(35)
(36)			MCDBR	12.8	13.5	13.6	15.0	14.2	13.8	14.9	14.2	14.5	15.1	13.3	12.3	(36)
(37)			MCWBR	5.2	5.2	5.5	6.4	7.0	7.7	8.0	7.8	7.3	7.0	6.0	5.3	(37)
(38)		5% WB	MCDWB	10.6	11.1	11.3	12.1	10.6	9.7	11.0	10.9	12.0	12.1	10.9	10.6	(38)
(39)			MCWBR	4.7	4.7	5.0	5.6	6.0	6.1	6.7	6.6	6.5	6.0	5.2	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.343	0.334	0.322	0.320	0.314	0.316	0.332	0.341	0.351	0.338	0.342	(40)	
(41)		taud	2.538	2.539	2.560	2.591	2.589	2.576	2.565	2.518	2.454	2.443	2.523	2.525	(41)	
(42)		Ebn at Noon	996	973	946	904	850	827	844	877	922	953	993	998	(42)	
(43)		Edh at Noon	110	106	96	83	74	70	75	88	105	115	111	112	(43)	
(44)	All-Sky Solar Radiation	RadAvg	8.19	7.31	5.87	4.28	2.97	2.50	2.79	3.54	4.88	6.43	7.64	8.28	(44)	
(45)		RadStd	0.19	0.21	0.23	0.21	0.19	0.14	0.16	0.17	0.20	0.30	0.23	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.36	+0.49	N/A	N/A	+0.53	+0.47	-2	-74	+111	+61	(46)
(47)	Regional (12 neighbors)	+0.36	+0.49	N/A	N/A	+0.53	+0.47	-2	-74	+111	+61	(47)

Nomenclature: See separate page