

WILLOWMORE, South Africa

WMO: 688320

Lat: 33.3003S

Lon: 23.4839E

Elev: 840

StdP: 91.63

Time Zone: 2.00 (E02)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.3	1.1	-8.3	2.1	16.5	-6.3	2.4	15.2	9.5	13.6	8.5	14.2	0.5	240	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	35.1	17.6	33.1	17.3	31.3	16.8	20.0	28.4	19.3	27.5	18.6	26.5	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	14.2	22.2	17.0	13.4	21.8	16.1	12.7	21.5	61.3	28.2	58.8	27.9	56.3	26.5	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.3	7.3	6.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-3.1	21.2	0.9	1.0	-3.8	21.9	-4.3	22.5	-4.9	23.1	-5.5	23.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	22.7	22.1	20.6	16.6	13.5	9.8	9.9	11.5	13.8	16.7	18.2	21.0	(6)	(7)
	DBStd	5.63	3.25	3.19	3.20	3.93	3.27	2.99	3.36	3.50	3.46	4.13	3.62	3.23	(7)	(8)
	HDD10.0	121	0	0	0	2	8	38	43	23	7	1	0	0	(8)	(9)
	HDD18.3	1262	4	6	14	78	152	255	261	213	139	82	47	11	(9)	(10)
	CDD10.0	2439	394	339	328	200	117	33	40	69	122	209	247	340	(10)	(11)
	CDD18.3	539	140	111	84	26	3	1	0	2	5	32	43	93	(11)	(12)
	CDH23.3	5242	1353	959	680	261	45	6	7	42	92	438	443	916	(12)	(13)
	CDH26.7	2133	624	404	259	80	7	0	0	11	17	179	157	395	(13)	(14)
(14) Wind	WSAvg	2.9	3.3	3.1	2.9	2.4	2.2	2.5	2.5	2.7	3.0	3.2	3.4	3.3	(14)	(15)
(15) Precipitation	PrecAvg	263	27	33	37	30	18	12	12	15	11	18	28	26	(15)	(16)
	PrecMax	525	113	135	121	103	76	33	70	54	66	74	152	99	(16)	(17)
	PrecMin	98	0	0	0	2	0	0	0	0	0	0	2	0	(17)	(18)
	PrecStd	96	28	35	27	24	20	9	14	14	14	17	32	27	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.1	36.8	34.5	31.8	27.6	23.9	24.2	27.8	29.1	35.0	33.9	36.7	(19)	(20)
		MCWB	18.1	18.9	17.5	15.6	14.3	11.7	11.7	12.4	13.7	16.5	15.9	17.2	(20)	(21)
	2%	DB	35.0	33.8	32.0	29.2	24.4	21.1	21.5	23.8	26.3	31.3	30.8	33.3	(21)	(22)
		MCWB	18.2	18.3	17.1	15.4	13.2	10.7	10.5	11.1	12.7	15.8	15.3	17.0	(22)	(23)
	5%	DB	32.5	31.3	29.7	26.3	22.1	18.7	19.3	20.9	23.6	28.1	28.3	30.9	(23)	(24)
		MCWB	17.7	18.0	16.6	15.0	12.5	9.9	9.9	10.2	11.8	14.6	15.0	16.6	(24)	(25)
	10%	DB	30.1	29.1	27.3	23.6	19.8	16.3	16.9	18.4	21.0	25.0	25.9	28.3	(25)	(26)
		MCWB	17.2	17.4	16.3	14.0	12.0	9.1	9.0	9.6	11.1	13.9	14.5	16.2	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.5	20.2	17.7	16.4	13.0	12.5	14.5	15.2	18.1	18.2	20.2	(27)	(28)
		MCDB	29.1	30.4	28.8	24.7	21.7	19.8	21.1	20.5	22.8	29.2	27.1	28.6	(28)	(29)
	2%	WB	19.7	20.2	18.9	16.9	14.5	11.6	11.6	13.0	13.9	17.0	17.0	19.0	(29)	(30)
		MCDB	28.4	28.5	27.0	25.3	20.6	18.2	18.9	19.1	22.8	27.5	25.4	28.1	(30)	(31)
	5%	WB	19.1	19.5	18.1	16.0	13.7	10.7	10.7	11.8	12.9	15.9	16.0	18.0	(31)	(32)
		MCDB	27.8	27.0	25.4	23.3	19.8	16.9	17.0	17.2	20.8	24.2	25.4	26.8	(32)	(33)
	10%	WB	18.4	18.7	17.4	15.1	12.8	9.8	9.7	10.7	11.9	14.8	15.3	17.2	(33)	(34)
		MCDB	27.0	25.4	24.4	21.7	18.6	15.3	15.2	16.7	19.1	23.0	23.8	25.3	(34)	(35)
(36) Mean Daily Temperature Range	5% DB	MDBR	13.6	12.9	12.2	12.0	11.6	11.4	12.0	12.1	12.4	12.8	13.0	13.7	(35)	(36)
		MCDBR	17.8	16.6	16.5	16.0	15.2	15.4	15.8	16.5	17.4	18.8	17.4	18.1	(36)	(37)
	5% WB	MCWBR	4.8	4.4	4.4	5.0	6.2	7.1	7.0	6.8	6.0	5.8	4.6	5.1	(37)	(38)
		MCWBR	14.9	13.8	13.4	13.3	12.9	12.4	12.9	12.5	15.1	16.0	15.3	15.6	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.333	0.338	0.325	0.300	0.284	0.273	0.275	0.302	0.321	0.337	0.323	0.329	(40)	(41)
		taud	2.532	2.517	2.542	2.602	2.624	2.632	2.614	2.512	2.443	2.433	2.521	2.531	(41)	(42)
	Ebn at Noon		1005	979	958	931	896	884	898	912	945	968	1008	1012	(42)	(43)
		Edh at Noon	111	108	99	82	71	66	71	88	107	116	111	111	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		7.64	6.86	5.64	4.30	3.28	2.83	3.10	3.95	5.27	6.35	7.38	7.92	(44)	(45)
	RadStd		0.29	0.26	0.35	0.19	0.14	0.14	0.19	0.21	0.28	0.35	0.39	0.49	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		N/A	N/A	+1.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page