

GRABOUW ELGIN, South Africa

WMO: 689250

Lat: 34.153S

Lon: 19.030E

Elev: 297

StdP: 97.81

Time Zone: 2.00 (E02)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	3.5	-0.5	3.8	8.2	0.9	4.2	7.0	12.0	14.1	10.9	13.3	0.2	110	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.0	31.5	20.2	29.4	19.6	27.6	19.1	21.4	29.1	20.6	27.4	19.9	25.9	2.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.4	24.2	18.3	13.7	23.4	17.7	13.1	22.7	63.7	29.3	60.9	27.4	58.3	26.1	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.4	7.5	6.1	DB	0.2	36.2	0.6	1.2	-0.3	37.1	-0.6	37.9	-1.0	38.5	-1.4	39.4
			WB	0.0	22.8	0.7	0.6	-0.5	23.2	-1.0	23.5	-1.4	23.8	-1.9	24.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	21.1	21.4	19.7	16.8	14.1	12.0	11.6	11.5	13.0	15.7	17.6	19.9
	DBStd	4.52	2.91	2.67	3.02	3.07	2.42	2.43	2.68	2.32	2.58	3.07	2.89	2.80
	HDD10.0	37	0	0	0	0	1	8	13	10	4	1	0	0
	HDD18.3	1155	8	4	19	65	132	192	208	211	161	93	47	15
	CDD10.0	2292	345	319	302	203	130	67	63	57	94	177	227	307
	CDD18.3	368	94	91	62	18	2	0	1	0	1	11	25	63
	CDH23.3	2109	539	486	322	101	17	6	9	4	8	91	152	373
Wind	WSAvg	1.9	1.7	1.6	1.5	1.5	1.9	2.2	2.2	2.2	2.1	1.9	1.8	1.8
	PrecAvg	1272	39	33	38	91	162	208	187	167	113	99	80	59
	PrecMax	1657	155	79	107	264	280	354	340	374	264	290	208	170
	PrecMin	503	7	6	6	17	82	56	18	44	34	8	18	16
	PrecStd	228	33	20	24	54	55	74	77	66	61	63	57	40
	DB	34.1	33.4	32.7	29.4	25.6	24.2	24.7	23.2	24.9	30.6	30.4	32.4	
	MCWB	21.1	21.0	20.5	18.8	15.9	13.7	12.2	12.8	16.2	19.5	18.6	20.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.7	30.3	29.2	26.3	22.6	20.6	21.6	19.6	21.6	25.9	27.1	29.3	
	2% MCWB	20.6	20.2	19.6	18.2	15.2	12.7	12.0	13.1	15.0	17.4	17.5	19.5	
	5% DB	28.4	28.2	26.7	24.0	20.5	18.0	18.6	17.5	19.4	23.2	24.8	27.1	
	5% MCWB	19.8	19.7	18.9	17.4	14.7	12.3	12.0	12.5	14.2	16.4	17.1	18.9	
	10% DB	26.2	26.3	24.6	21.8	18.7	16.2	16.3	15.7	17.4	20.9	22.8	25.1	
	10% MCWB	19.0	19.3	18.1	16.6	14.0	11.9	11.9	11.8	13.1	15.3	16.5	18.2	
	WB	22.6	22.5	21.9	20.2	17.9	15.5	15.0	15.6	17.8	20.1	20.6	21.3	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	31.3	29.8	30.5	26.8	22.4	20.2	20.3	19.7	23.1	27.9	27.6	29.8	
	2% WB	21.5	21.2	20.5	18.9	16.3	14.1	13.8	14.3	16.1	18.6	19.1	20.2	
	2% MCDB	29.2	28.0	27.6	24.5	20.5	17.2	18.1	17.2	20.5	25.1	25.0	27.6	
	5% WB	20.5	20.4	19.5	18.0	15.3	13.3	12.8	13.1	14.7	17.1	17.9	19.3	
	5% MCDB	26.8	26.4	25.3	23.1	19.3	16.3	16.7	16.1	18.6	22.0	22.9	25.8	
	10% WB	19.6	19.7	18.6	17.1	14.5	12.5	12.0	12.1	13.5	15.9	16.9	18.5	
	10% MCDB	25.0	24.9	23.5	21.2	18.0	15.4	15.6	14.9	16.8	20.1	21.5	24.1	
Mean Daily Temperature Range	MDBR	10.3	10.0	10.1	10.0	9.5	8.9	9.1	8.2	8.6	9.4	9.9	10.1	
	5% DB	13.9	13.3	13.7	13.5	13.3	12.9	13.9	12.0	12.6	14.0	13.8	13.5	
	5% MCWBR	5.3	4.9	5.2	6.1	7.4	7.5	7.6	6.9	6.6	6.4	6.1	5.7	
	5% WB	12.6	11.6	12.3	12.4	11.9	10.0	11.3	10.2	11.8	12.9	12.3	12.4	
	5% MCWBR	5.3	4.7	5.3	5.8	7.1	6.5	6.7	6.5	6.5	6.5	6.0	5.5	
	taub	0.333	0.335	0.326	0.312	0.308	0.302	0.303	0.320	0.330	0.341	0.329	0.334	
	taud	2.550	2.551	2.571	2.606	2.604	2.595	2.582	2.530	2.472	2.458	2.535	2.539	
Clear-Sky Solar Irradiance	Ebn at Noon	1004	981	954	914	863	841	858	890	934	963	1002	1007	
	Edh at Noon	108	104	95	82	72	68	73	87	103	113	109	110	
	RadAvg	8.01	7.14	5.74	4.20	2.98	2.51	2.78	3.54	4.88	6.33	7.52	8.11	
All-Sky Solar Radiation	RadStd	0.22	0.22	0.25	0.20	0.17	0.14	0.15	0.17	0.21	0.32	0.26	0.26	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	+0.36	+0.49	N/A	N/A	+0.53	+0.47	-2	-74	+111	+61

Nomenclature: See separate page