

BAGRAM, AfghanistanWMO: **697284**Lat: **34.944N**Lon: **69.259E**Elev: **4895**StdP: **12.28**Time Zone: **4.50 (AFG)**Period: **02-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	21.2	-3.6	5.4	43.0	1.2	7.0	42.3	14.3	42.4	12.2	40.5	4.0	240	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	98.3	61.0	96.5	60.2	94.5	59.8	69.4	83.8	67.7	83.1	65.7	82.2	11.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	109.7	78.1	62.5	101.8	78.5	59.3	90.4	77.2	36.7	84.1	35.1	82.4	33.4	81.5	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.4	22.3	19.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	35.4	39.5	52.2	61.2	70.2	78.9	83.6	81.2	73.7	63.2	49.7	39.6
	DBStd	17.44	6.06	7.33	6.77	5.72	6.12	5.25	3.65	3.89	4.28	6.33	5.27	6.23
	HDD50	1200	451	298	55	3	0	0	0	0	0	0	69	324
	HDD65	3550	916	713	398	138	21	0	0	0	2	116	459	787
	CDD50	5151	0	5	122	338	627	867	1042	968	711	409	60	2
	CDD65	2027	0	0	1	23	183	417	577	503	263	60	0	0
	CDH74	26220	0	0	31	352	2005	5154	8107	6653	3166	744	8	0
	CDH80	12652	0	0	1	74	710	2461	4498	3454	1243	211	0	0
Wind	WSAvg	6.5	3.1	3.4	4.7	6.6	8.7	11.7	11.5	9.2	6.8	5.2	3.0	3.4
Precipitation	PrecAvg	15.3	1.7	2.8	2.6	2.0	1.3	0.6	0.6	0.9	0.6	0.6	0.8	0.8
	PrecMax	25.9	4.0	5.5	6.6	4.8	5.1	2.3	1.9	3.5	1.9	2.3	3.0	2.8
	PrecMin	4.9	0.2	0.2	0.2	0.3	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.1
	PrecStd	4.8	1.1	1.4	1.6	1.2	1.1	0.6	0.4	0.7	0.6	0.7	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.3	62.3	77.2	86.4	93.2	99.1	101.1	100.0	93.6	89.5	75.2	62.4
		MCWB	40.3	46.1	51.9	55.0	57.4	60.8	62.4	61.3	59.5	54.3	50.4	43.8
	2%	DB	53.9	57.9	74.1	81.7	89.9	96.5	98.7	97.2	91.4	85.7	70.0	57.6
		MCWB	38.4	45.4	50.5	54.6	57.1	59.5	61.0	60.7	59.1	55.5	47.5	40.4
	5%	DB	50.4	55.0	70.2	78.4	87.5	93.6	96.8	95.2	89.4	82.1	66.1	55.3
		MCWB	36.7	44.0	49.0	53.8	56.7	58.9	60.2	60.5	58.3	54.4	46.1	39.2
	10%	DB	46.7	51.4	66.0	74.6	84.0	91.1	94.9	93.1	87.3	77.6	62.4	52.3
		MCWB	35.7	42.4	47.8	52.4	55.6	58.0	60.0	60.1	58.1	52.3	45.0	38.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	49.8	53.8	58.8	60.9	67.9	72.3	70.8	68.3	62.9	52.9	46.0
		MCDB	53.0	56.6	69.6	76.4	80.4	85.7	86.5	84.6	84.9	80.0	65.3	54.6
	2%	WB	40.2	47.6	52.4	56.9	59.6	62.2	69.9	69.4	65.7	59.4	50.9	44.1
		MCDB	48.7	54.2	67.1	75.2	78.9	89.9	84.2	83.3	81.1	74.8	62.9	52.0
	5%	WB	38.7	45.9	51.1	55.4	58.5	60.2	66.7	68.2	64.3	56.6	49.3	42.2
		MCDB	45.9	52.2	65.0	71.6	78.1	88.8	83.5	82.9	78.7	73.7	61.0	52.0
	10%	WB	37.2	44.3	49.8	54.3	57.4	58.9	63.5	66.9	62.8	54.4	47.5	39.6
		MCDB	44.3	50.3	62.8	69.3	78.0	87.7	86.8	82.2	77.7	73.1	57.6	49.3
Mean Daily Temperature Range	5% DB	MDBR	19.1	15.7	20.1	22.1	22.2	21.9	22.6	23.6	25.9	26.6	23.5	22.1
		MCDBR	25.0	20.7	27.7	28.3	26.4	25.3	25.2	26.5	28.5	29.8	28.0	26.0
		MCWBR	13.0	9.9	10.2	8.9	8.5	9.1	10.2	10.5	10.9	11.5	11.6	13.0
	5% WB	MCDBR	19.2	16.8	22.1	23.3	23.2	24.4	23.5	21.8	22.3	25.7	22.5	21.6
		MCWBR	10.6	8.2	9.0	8.0	8.3	9.1	11.6	10.5	10.4	11.1	10.1	10.9
Clear-Sky Solar Irradiance	taub	0.310	0.360	0.422	0.456	0.462	0.474	0.475	0.442	0.390	0.376	0.341	0.312	
	taud	2.274	2.090	1.982	1.958	1.977	1.948	1.959	2.062	2.187	2.168	2.251	2.306	
	Ebn at Noon	280	275	267	264	264	259	258	265	274	267	266	272	
	Edh at Noon	33	44	54	58	57	59	58	52	43	40	33	30	
All-Sky Solar Radiation	RadAvg	908	1139	1507	1843	2238	2522	2540	2332	2023	1560	1045	859	
	RadStd	81	119	128	141	162	140	80	114	73	90	96	100	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page