

SELAWIK, AK, USA

WMO: 700197

Lat: 66.600N

Lon: 159.986W

Elev: 25

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26558

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.6	-36.2	-29.4	1.1	-23.0	-28.7	1.1	-21.7	30.2	8.3	27.2	11.2	2.5	60	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	72.6	59.7	69.8	58.5	65.9	57.3	61.8	69.6	59.9	66.8	58.3	64.7	8.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.1	72.1	64.5	56.0	66.9	62.9	54.6	63.5	61.6	27.6	69.6	26.3	67.1	25.2	64.5	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.9	23.3	20.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-29.8	64.0	4.5	3.8	-33.1	66.8	-35.7	69.0	-38.2	71.1	-41.5	73.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	-3.7	0.7	2.4	16.7	36.0	52.3	57.9	53.6	43.5	25.4	7.9	0.0		
	DBStd	25.62	20.40	16.74	14.85	12.15	9.71	7.71	5.53	5.74	6.83	10.25	14.13	15.03		
	HDD50	9837	1665	1380	1474	999	438	63	6	28	209	763	1262	1550		
	HDD65	14783	2130	1800	1939	1449	898	384	227	355	646	1228	1712	2015		
	CDD50	545	0	0	0	0	6	133	252	140	14	0	0	0		
	CDD65	12	0	0	0	0	0	3	8	1	0	0	0	0		
	CDH74	60	0	0	0	0	0	20	36	4	0	0	0	0		
	CDH80	4	0	0	0	0	0	1	3	0	0	0	0	0		
	WSAvg	9.6	10.8	11.0	10.0	9.8	9.0	9.6	8.6	8.6	8.7	8.8	9.8	10.2		
	PrecAvg	18.0	1.3	1.3	0.9	0.7	0.8	1.3	2.3	2.8	1.9	1.8	1.5	1.3		
	PrecMax	22.6	2.7	3.6	3.1	2.2	1.7	2.6	4.2	6.2	3.7	4.5	3.3	3.0		
Precipitation	PrecMin	13.3	0.3	0.2	0.2	0.1	0.3	0.5	1.2	1.0	1.0	0.7	0.2	0.6		
	PrecStd	2.6	0.6	0.8	0.6	0.5	0.4	0.5	0.7	1.1	0.8	0.8	0.9	0.6		
	DB	35.3	36.0	35.3	39.5	65.7	76.8	79.3	73.0	61.3	45.3	36.3	34.3	34.3		
	MCWB	33.5	34.2	33.4	35.1	52.7	60.2	63.2	61.3	51.1	41.2	34.5	32.6	32.6		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.7	32.7	32.1	36.8	59.0	72.2	73.1	68.2	57.3	42.6	34.2	29.8	29.8		
	2% MCWB	29.9	31.4	30.8	33.6	48.3	57.9	60.6	58.3	50.1	39.4	32.5	28.6	28.6		
	5% DB	27.4	28.8	27.6	36.0	54.0	68.4	70.4	64.4	54.8	39.3	31.9	25.2	25.2		
	5% MCWB	26.2	27.8	26.0	33.3	45.7	56.5	59.8	56.9	49.7	36.8	31.1	23.6	23.6		
	10% DB	23.2	24.8	23.3	34.2	48.4	64.1	66.4	62.9	52.5	37.1	27.6	20.7	20.7		
	10% MCWB	21.9	23.4	21.9	32.1	43.1	54.6	58.4	55.6	48.6	35.2	26.4	19.8	19.8		
	0.4% WB	33.6	34.0	33.6	36.1	53.4	62.2	65.4	63.6	53.6	42.2	34.3	32.9	32.9		
	0.4% MCDB	34.9	35.2	34.5	39.3	63.8	72.2	74.7	69.4	58.7	44.2	35.3	34.0	34.0		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	30.7	31.7	30.8	34.3	49.5	59.7	62.4	60.5	51.9	39.9	32.4	28.6	28.6		
	2% MCDB	31.8	33.0	32.1	36.4	57.8	68.9	70.2	65.8	55.7	42.4	33.7	29.5	29.5		
	5% WB	27.3	28.2	26.3	33.3	46.3	57.6	60.8	58.6	50.6	37.6	30.8	24.4	24.4		
	5% MCDB	27.7	29.1	27.6	35.2	52.5	65.5	68.4	63.7	54.1	39.1	31.9	25.9	25.9		
	10% WB	23.6	24.0	22.5	32.0	43.6	55.7	59.2	56.8	49.2	35.7	26.6	20.4	20.4		
	10% MCDB	25.2	25.5	24.0	34.0	48.9	63.4	65.7	61.5	52.6	37.1	27.5	21.2	21.2		
	MDBR	12.4	14.1	15.2	14.9	14.3	14.7	11.1	10.5	9.9	8.8	11.1	12.3	12.3		
	5% DB MCDBR	12.0	15.9	12.7	13.7	22.7	19.7	16.4	13.8	12.7	8.4	9.9	12.3	12.3		
Mean Daily Temperature Range	5% DB MCWBR	11.3	15.4	11.8	11.6	13.6	9.2	7.7	7.7	7.6	6.7	9.3	11.4	11.4		
	5% WB MCDBR	12.0	16.0	12.6	12.5	20.6	16.7	14.5	12.0	10.9	7.7	9.9	12.3	12.3		
	5% WB MCWBR	11.4	15.5	11.9	10.9	13.1	8.5	7.4	7.1	7.0	6.4	9.4	11.5	11.5		
Clear-Sky Solar Irradiance	taub	0.173	0.239	0.255	0.320	0.349	0.350	0.359	0.357	0.310	0.257	0.168	N/A	N/A		
	taud	1.912	2.145	2.257	2.137	2.276	2.408	2.408	2.438	2.517	2.345	1.939	N/A	N/A		
	Ebn at Noon	75	197	260	263	268	272	265	253	242	193	72	0	0		
	Edh at Noon	5	16	24	36	35	32	31	27	20	13	4	0	0		
All-Sky Solar Radiation	RadAvg	25	195	743	1418	1714	1879	1491	1099	685	250	51	0	0		
	RadStd	3	23	58	88	169	162	117	145	77	33	8	0	0		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+2.57	N/A	N/A	+1.80	+1.48	N/A	-855	-918	+117	+2

Nomenclature: See separate page