

SELAWIK, AK, USA

WMO: 700197

Lat: 66.600N

Lon: 159.986W

Elev: 8

StdP: 101.23

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26558

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.4	(c) -37.9	(d) -34.1	(e) 0.2	(f) -30.5	(g) -33.7	(h) 0.2	(i) -29.8	(j) 13.5	(k) -13.2	(l) 12.1	(m) -11.5	(n) 1.1	(o) 60	(p) 0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	22.5	15.4	21.0	14.7	18.8	14.1	16.6	20.9	15.5	19.3	14.6	18.2	3.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.5	10.3	18.1	13.3	9.6	17.2	12.6	9.1	16.4	46.2	20.9	43.2	19.5	40.7	18.0	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.6	(b) 10.4	(c) 9.1	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 11.6	(b) 10.4	(c) 9.1	(d) WB	(e) -34.4	(f) 17.8	(g) 2.5	(h) 2.1	(i) -36.1	(j) 19.3	(k) -37.6	(l) 20.5	(m) -39.0	(n) 21.7	(o) -40.8	(p) 23.2	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.1	-19.8	-17.4	-16.4	-8.5	2.2	11.3	14.4	12.0	6.4	-3.7	-13.4	-17.8		
	DBStd	14.24	11.33	9.30	8.25	6.75	5.40	4.28	3.07	3.19	3.79	5.69	7.85	8.35		
	HDD10.0	5465	925	767	819	555	243	35	3	16	116	424	701	861		
	HDD18.3	8213	1183	1000	1077	805	499	213	126	197	359	682	951	1119		
	CDD10.0	303	0	0	0	0	3	74	140	78	8	0	0	0		
	CDD18.3	7	0	0	0	0	0	2	4	1	0	0	0	0		
	CDH23.3	33	0	0	0	0	0	11	20	2	0	0	0	0		
	CDH26.7	2	0	0	0	0	0	1	2	0	0	0	0	0		
(14) Wind	WSAvg	4.3	4.8	4.9	4.5	4.4	4.0	4.3	3.8	3.8	3.9	3.9	4.4	4.6		
(15) Precipitation	PrecAvg	457	32	33	24	19	20	33	59	70	49	45	38	34		
	PrecMax	575	69	92	79	57	42	66	106	157	93	115	85	76		
	PrecMin	338	7	6	4	2	7	13	30	26	25	19	5	15		
	PrecStd	65	16	20	15	13	9	13	18	27	20	21	23	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.8	2.2	1.8	4.2	18.7	24.9	26.3	22.8	16.3	7.4	2.4	1.3		
		MCWB	0.9	1.2	0.8	1.7	11.5	15.7	17.3	16.3	10.6	5.1	1.4	0.3		
	2%	DB	-0.7	0.4	0.0	2.7	15.0	22.3	22.8	20.1	14.0	5.9	1.2	-1.2		
		MCWB	-1.2	-0.3	-0.7	0.9	9.1	14.4	15.9	14.6	10.1	4.1	0.3	-1.9		
	5%	DB	-2.6	-1.8	-2.5	2.2	12.2	20.2	21.3	18.0	12.7	4.0	-0.1	-3.8		
		MCWB	-3.2	-2.4	-3.3	0.7	7.6	13.6	15.4	13.8	9.8	2.7	-0.5	-4.7		
	10%	DB	-4.9	-4.0	-4.9	1.2	9.1	17.8	19.1	17.1	11.4	2.8	-2.5	-6.3		
		MCWB	-5.6	-4.8	-5.6	0.1	6.2	12.5	14.6	13.1	9.2	1.8	-3.1	-6.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	1.1	0.9	2.3	11.9	16.8	18.6	17.5	12.0	5.7	1.3	0.5		
		MCDB	1.6	1.8	1.4	4.1	17.7	22.4	23.7	20.8	14.8	6.8	1.9	1.1		
	2%	WB	-0.7	-0.2	-0.7	1.3	9.7	15.4	16.9	15.8	11.0	4.4	0.2	-1.9		
		MCDB	-0.1	0.5	0.1	2.5	14.4	20.5	21.2	18.8	13.2	5.8	1.0	-1.4		
	5%	WB	-2.6	-2.1	-3.1	0.7	8.0	14.2	16.0	14.8	10.3	3.1	-0.7	-4.2		
		MCDB	-2.4	-1.6	-2.4	1.8	11.4	18.6	20.2	17.6	12.3	3.9	-0.1	-3.4		
	10%	WB	-4.7	-4.4	-5.3	0.0	6.5	13.2	15.1	13.8	9.6	2.1	-3.0	-6.5		
		MCDB	-3.8	-3.6	-4.5	1.1	9.4	17.5	18.7	16.4	11.4	2.9	-2.5	-6.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.8	8.4	8.3	7.9	8.2	6.2	5.8	5.5	4.9	6.2	6.8		
		MCDBR	6.7	8.8	7.1	7.6	12.6	10.9	9.1	7.7	7.1	4.7	5.5	6.8		
		MCWBR	6.3	8.6	6.6	6.5	7.6	5.1	4.3	4.3	4.2	3.7	5.2	6.3		
	5% WB	MCDBR	6.7	8.9	7.0	6.9	11.5	9.3	8.1	6.7	6.1	4.3	5.5	6.8		
		MCWBR	6.3	8.6	6.6	6.1	7.3	4.7	4.1	3.9	3.9	3.6	5.2	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.173	0.239	0.255	0.320	0.349	0.350	0.359	0.357	0.310	0.257	0.168	N/A		
	taud		1.912	2.145	2.257	2.137	2.276	2.408	2.408	2.438	2.517	2.345	1.939	N/A		
	Ebn at Noon		236	622	821	830	846	857	835	797	763	608	227	0		
	Edh at Noon		15	50	76	113	110	100	97	85	62	41	13	0		
(44) All-Sky Solar Radiation	RadAvg		0.08	0.62	2.34	4.47	5.40	5.92	4.70	3.46	2.16	0.79	0.16	0.00		
	RadStd		0.01	0.07	0.18	0.28	0.53	0.51	0.37	0.46	0.24	0.10	0.02	0.00		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+1.43	N/A	N/A	N/A	+1.00	+0.82	N/A	-475	-510	+65	+1

Nomenclature: See separate page