

TIN CITY, AK, USA

WMO: 701170

Lat: 65.563N

Lon: 167.921W

Elev: 271

StdP: 14.55

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26634

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-22.6	-19.4	-28.6	1.1	-21.8	-25.2	1.4	-19.1	51.9	-11.1	48.9	-5.8	29.0	10	1.178

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	61.4	54.8	57.6	53.3	54.8	51.6	56.2	60.0	54.1	57.3	52.0	54.6	10.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.3	63.5	57.5	52.3	58.7	55.4	50.3	54.6	53.1	24.0	60.1	22.7	57.4	21.5	54.3	62.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.2	42.6	39.2	DB	-26.2	68.5	4.8	3.9	-29.6	71.3	-32.4	73.6	-35.1	75.8	-38.5	78.6	(4)
(5)			WB	-25.2	59.5	5.4	1.8	-29.1	60.8	-32.2	61.9	-35.2	62.9	-39.1	64.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.2	2.4	3.1	2.1	14.7	30.0	40.8	47.6	47.3	41.5	31.4	19.7	8.4
	DBStd	19.81	14.32	15.17	12.68	11.18	6.88	6.54	5.11	4.24	5.65	6.73	9.78	13.34
	HDD50	9498	1476	1315	1486	1059	622	287	111	107	260	577	908	1290
	HDD65	14897	1941	1735	1951	1509	1086	726	541	548	705	1042	1358	1755
	CDD50	76	0	0	0	0	1	12	35	24	4	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	20.0	25.0	26.2	24.2	22.7	18.0	16.4	14.9	16.1	16.4	17.3	19.0	24.4
Precipitation	PrecAvg	19.3	1.3	1.2	1.1	0.8	0.9	1.1	2.3	2.8	2.2	2.6	1.7	1.3
	PrecMax	33.1	3.0	3.5	4.3	3.6	2.7	2.2	3.9	5.9	5.5	4.9	5.9	3.3
	PrecMin	11.3	0.0	0.1	0.0	0.1	0.1	0.2	0.5	0.7	0.6	0.7	0.2	0.0
	PrecStd	4.6	0.8	0.8	1.1	0.7	0.7	0.5	0.9	1.2	1.0	1.1	1.1	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.7	36.5	32.4	39.2	55.6	65.6	68.9	63.2	57.1	50.9	41.0	37.7
		MCWB	34.6	34.6	31.3	34.8	47.8	55.5	58.1	57.7	50.5	45.8	37.9	34.4
	2%	DB	32.4	32.6	30.2	35.9	46.3	59.2	62.7	58.5	53.5	46.1	37.2	33.6
		MCWB	31.3	31.9	29.4	33.7	42.0	51.9	55.6	54.9	49.8	43.3	35.6	32.1
	5%	DB	29.6	30.2	27.8	33.5	41.6	54.4	58.7	55.8	51.0	42.3	35.1	30.8
		MCWB	28.9	29.7	26.9	32.2	38.9	49.5	54.3	53.4	48.3	40.4	34.2	29.8
	10%	DB	25.3	27.4	23.6	30.8	37.7	50.7	55.2	53.7	48.8	39.4	32.8	28.0
		MCWB	24.5	26.8	22.6	30.2	35.5	47.4	52.1	51.9	47.0	37.9	31.9	27.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.9	34.6	32.0	36.2	48.4	56.1	59.2	58.4	52.7	46.3	39.1	34.7
		MCDB	37.1	35.6	32.4	38.0	55.0	63.5	65.2	62.0	56.0	49.5	40.0	36.7
	2%	WB	31.9	32.2	29.8	33.6	42.8	52.8	56.8	55.6	50.3	43.4	35.9	32.3
		MCDB	32.8	32.9	30.2	35.1	46.5	58.3	61.4	57.6	52.5	46.0	36.7	33.5
	5%	WB	28.9	30.0	27.1	32.2	39.2	50.2	54.6	53.8	48.8	40.8	34.1	30.0
		MCDB	29.6	30.4	27.6	33.4	41.5	54.1	58.5	55.5	50.7	42.4	35.0	30.9
	10%	WB	24.5	26.8	22.3	30.2	36.3	47.6	52.3	51.9	47.2	38.4	32.1	27.3
		MCDB	25.3	27.4	23.4	31.0	37.9	50.7	55.3	53.2	48.6	39.5	33.0	28.1
Mean Daily Temperature Range	5% DB	MDBR	9.6	10.1	9.4	9.2	6.9	8.5	7.4	6.4	5.9	5.9	7.8	8.9
		MCDBR	13.3	12.4	10.9	9.5	12.7	15.2	14.4	10.2	7.9	6.7	6.8	10.9
		MCWBR	12.2	11.9	11.0	7.8	9.1	10.0	9.0	7.4	6.0	6.1	6.1	10.1
	5% WB	MCDBR	13.3	12.5	10.4	9.2	12.1	14.1	13.6	9.6	7.3	6.1	6.3	10.8
		MCWBR	12.4	12.1	10.7	7.8	9.0	10.2	9.1	7.3	5.8	5.9	5.9	10.0
Clear-Sky Solar Irradiance	taub	0.165	0.247	0.270	0.336	0.364	0.353	0.368	0.391	0.320	0.285	0.374	0.185	
	taud	1.902	2.086	2.153	1.991	2.133	2.429	2.434	2.304	2.492	2.280	2.701	1.899	
	Ebn at Noon	106	199	254	257	264	272	264	241	241	184	82	17	
	Edh at Noon	6	18	28	42	41	31	30	31	21	15	7	2	
All-Sky Solar Radiation	RadAvg	35	233	790	1418	1652	1749	1416	1033	641	235	50	7	
	RadStd	4	27	65	104	172	148	129	115	60	23	7	1	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)		+1.49	N/A	N/A	N/A	+0.86	+0.99	N/A	N/A	+63	N/A

Nomenclature: See separate page