

AMBLER, AK, USA

WMO: 701718

Lat: 67.100N

Lon: 157.850W

Elev: 289

StdP: 14.54

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26551

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.5	-35.7	-29.5	1.1	-19.0	-28.8	1.1	-17.7	21.5	3.6	20.1	4.5	1.9	40	0.738

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	76.9	59.6	73.2	57.9	70.3	56.8	61.7	73.3	59.7	70.2	58.0	67.6	5.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.7	69.2	64.4	54.7	64.4	63.0	53.8	62.2	62.1	27.6	73.1	26.2	70.7	25.1	67.5	67.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	17.0	15.3	DB	-44.5	79.9	8.6	4.5	-50.7	83.1	-55.7	85.7	-60.6	88.2	-66.8	91.4	
			WB	-32.7	63.7	7.3	2.4	-38.0	65.4	-42.3	66.8	-46.3	68.1	-51.6	69.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	-2.4	4.8	6.2	22.0	40.2	56.5	58.4	52.2	42.7	23.5	7.6	1.8	(6)
		DBStd	25.07	19.19	15.71	13.37	12.20	10.70	7.01	6.41	6.40	7.39	11.71	13.91	14.97	
		HDD50	9324	1626	1266	1359	839	333	22	10	48	235	822	1271	1493	
		HDD65	14180	2091	1686	1824	1289	770	265	219	400	670	1287	1721	1958	
		CDD50	643	0	0	0	0	28	217	270	114	14	0	0	0	
		CDD65	26	0	0	0	0	0	10	14	2	0	0	0	0	
		CDH74	251	0	0	0	0	4	107	123	17	0	0	0	0	
		CDH80	31	0	0	0	0	0	15	16	0	0	0	0	0	
		CDH80	31	0	0	0	0	0	15	16	0	0	0	0	0	
(14)	Wind	WSAvg	6.2	6.6	7.4	7.0	7.3	6.2	5.2	4.5	4.7	6.0	6.3	6.4	6.9	(14)
(15)	Precipitation	PrecAvg	18.0	1.3	1.3	0.9	0.7	0.8	1.3	2.3	2.8	1.9	1.8	1.5	1.3	(15)
(16)		PrecMax	22.6	2.7	3.6	3.1	2.2	1.7	2.6	4.2	6.2	3.7	4.5	3.3	3.0	(16)
(17)		PrecMin	13.3	0.3	0.2	0.2	0.1	0.3	0.5	1.2	1.0	1.0	0.7	0.2	0.6	(17)
(18)		PrecStd	2.6	0.6	0.8	0.6	0.5	0.4	0.5	0.7	1.1	0.8	0.8	0.9	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	35.8	36.5	50.9	72.8	81.8	82.0	76.6	65.3	48.0	36.8	34.3	(19)
(20)			MCWB	31.3	32.1	32.3	40.6	53.6	61.0	62.0	61.5	51.3	39.4	31.8	31.4	(20)
(21)		2%	DB	29.8	31.8	32.5	45.5	66.4	76.9	77.3	71.3	59.9	43.7	34.1	29.9	(21)
(22)			MCWB	28.6	30.3	29.9	37.0	51.3	58.2	60.6	59.2	49.2	38.6	30.9	28.6	(22)
(23)		5%	DB	27.2	28.2	28.3	42.5	61.4	73.1	73.5	66.0	55.5	40.3	30.1	26.7	(23)
(24)			MCWB	25.1	26.4	25.4	35.1	48.1	56.4	59.1	56.2	48.1	36.5	28.7	24.5	(24)
(25)		10%	DB	24.0	25.4	25.4	37.8	56.0	70.3	71.5	63.1	53.5	37.1	27.1	21.1	(25)
(26)			MCWB	22.3	23.2	22.3	32.8	45.7	55.4	58.6	54.2	47.5	33.9	24.8	19.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.1	32.5	33.4	40.7	54.9	62.7	64.2	63.7	53.4	42.6	34.0	32.2	(27)
(28)			MCDB	33.2	33.8	35.3	49.5	71.0	78.2	77.3	74.0	59.3	45.6	35.8	33.5	(28)
(29)		2%	WB	28.8	30.3	30.1	37.6	52.0	59.7	62.3	60.0	51.3	39.5	31.5	28.6	(29)
(30)			MCDB	29.6	31.6	32.3	43.8	65.2	73.2	74.3	67.8	56.6	43.3	33.1	29.6	(30)
(31)		5%	WB	25.6	27.2	26.1	35.8	49.5	58.1	60.8	57.6	49.9	37.1	28.3	24.7	(31)
(32)			MCDB	27.5	28.5	28.4	41.3	60.1	70.4	71.7	64.6	54.6	40.0	29.4	26.8	(32)
(33)		10%	WB	23.0	24.0	22.8	33.4	46.4	56.4	59.1	55.6	48.0	34.5	24.8	20.5	(33)
(34)			MCDB	25.0	25.8	25.7	38.0	55.2	68.2	68.7	61.5	52.4	37.4	27.3	22.2	(34)
(35)	Mean Daily Temperature Range	MDBR	12.1	12.0	14.2	14.8	16.2	18.2	15.3	13.9	12.0	9.2	10.1	10.6		(35)
(36)		5% DB	MCDBR	10.4	10.1	12.9	15.9	23.9	22.4	20.7	19.3	16.6	10.4	7.7	10.3	(36)
(37)			MCWBR	9.8	9.1	10.7	10.7	12.8	10.2	9.7	10.5	9.7	7.5	7.0	9.4	(37)
(38)		5% WB	MCDBR	10.4	9.7	11.7	14.4	21.7	20.3	18.9	15.5	13.5	9.0	7.6	10.1	(38)
(39)			MCWBR	10.1	9.1	10.0	9.9	11.9	9.9	9.3	9.1	8.1	7.0	7.3	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.171	0.240	0.258	0.321	0.350	0.355	0.363	0.347	0.307	0.249	0.167	N/A		(40)
(41)		taud	1.913	2.116	2.240	2.129	2.266	2.386	2.387	2.448	2.508	2.309	1.937	N/A		(41)
(42)		Ebn at Noon	63	190	256	261	267	269	263	255	241	190	60	0		(42)
(43)		Edh at Noon	4	16	24	36	35	32	31	27	19	13	3	0		(43)
(44)	All-Sky Solar Radiation	RadAvg	22	200	771	1478	1739	1812	1457	1083	658	244	47	0		(44)
(45)		RadStd	2	19	56	76	178	161	124	137	83	34	6	0		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page