

INDIAN MOUNTAIN, AK, USA

WMO: 701730

Lat: 66.000N

Lon: 153.700W

Elev: 1276

StdP: 14.03

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26535

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.0	-32.2	-43.2	0.5	-34.7	-38.2	0.6	-29.6	34.8	1.4	31.7	1.5	0.2	330	0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	76.2	58.4	72.9	56.9	69.9	55.7	60.4	71.4	58.9	69.2	57.4	66.9	6.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.4	70.9	62.6	54.7	66.6	61.6	53.0	62.6	60.6	27.3	71.3	26.1	69.2	25.1	66.9	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.9	21.5	18.4	-38.7	80.5	5.2	3.0	-42.4	82.6	-45.4	84.3	-48.3	86.0	-52.1	88.2		
(5)			-37.6	62.4	4.0	1.8	-40.5	63.7	-42.9	64.7	-45.2	65.8	-48.1	67.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	-3.4	2.3	8.6	27.3	44.9	56.6	58.9	51.8	42.5	22.9	6.8	1.7
	DBStd	24.96	17.25	15.41	12.45	10.79	8.01	5.61	5.66	5.99	7.58	10.57	12.03	13.63
	HDD50	9086	1656	1336	1283	682	194	10	5	48	238	841	1296	1497
	HDD65	13937	2121	1756	1748	1132	623	256	202	410	675	1306	1746	1962
	CDD50	641	0	0	0	0	35	209	280	104	13	0	0	0
	CDD65	19	0	0	0	0	0	6	12	1	0	0	0	0
	CDH74	187	0	0	0	0	1	54	115	17	0	0	0	0
	CDH80	14	0	0	0	0	0	3	11	0	0	0	0	0
Wind	WSAvg	5.8	6.2	5.6	7.3	6.9	5.8	5.1	4.7	4.3	5.5	5.6	6.0	6.4
Precipitation	PrecAvg	16.6	1.0	1.0	0.7	0.6	0.8	1.5	2.2	2.6	2.0	1.6	1.3	1.2
	PrecMax	21.7	2.7	3.6	2.0	2.3	1.7	4.2	4.4	6.1	4.8	4.2	3.8	3.8
	PrecMin	12.1	0.0	0.0	0.0	0.1	0.1	0.4	1.1	0.4	0.9	0.4	0.1	0.3
	PrecStd	3.0	0.6	0.7	0.5	0.5	0.4	0.7	0.7	1.1	1.1	0.8	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.2	39.1	54.2	71.7	79.2	81.9	76.5	64.5	44.3	32.8	32.6
		MCWB	30.7	30.8	33.2	42.0	53.2	58.9	60.3	60.3	50.2	38.4	29.7	31.5
	2%	DB	28.4	29.6	33.4	48.9	66.3	75.1	77.4	71.0	59.6	40.6	30.1	27.3
		MCWB	26.8	26.4	29.7	38.6	49.8	56.4	59.2	57.6	49.2	37.2	28.1	25.7
	5%	DB	24.0	26.2	30.0	45.8	62.6	72.1	74.1	65.9	56.6	37.9	27.4	22.6
		MCWB	22.4	23.7	25.8	36.7	48.1	55.1	58.1	55.2	47.6	35.1	26.1	21.0
	10%	DB	19.0	22.8	26.2	42.3	59.2	69.1	71.0	62.3	53.4	35.4	23.3	19.2
		MCWB	17.4	20.7	22.6	34.9	45.9	53.7	57.4	53.6	46.7	33.1	21.7	17.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.1	32.2	34.2	42.4	55.1	60.6	63.2	62.3	52.6	40.7	30.4	31.4
		MCDB	33.3	33.0	37.4	52.6	68.0	73.5	74.2	71.8	59.1	41.9	31.3	32.0
	2%	WB	27.1	27.0	30.3	39.3	52.1	58.4	61.3	59.1	50.4	38.1	28.4	25.8
		MCDB	28.5	29.7	33.5	47.0	62.7	70.5	72.7	67.3	56.6	39.6	29.6	27.2
	5%	WB	22.8	23.7	26.1	37.4	49.4	57.0	59.8	57.1	49.1	35.4	25.9	21.2
		MCDB	24.3	25.9	29.5	44.7	59.9	68.5	70.6	63.7	54.8	37.4	27.6	22.5
	10%	WB	17.5	20.7	22.7	35.2	47.1	55.3	58.5	55.1	47.5	33.2	21.9	17.7
		MCDB	19.0	22.8	26.2	42.0	57.9	66.1	68.6	61.0	52.3	35.0	23.3	19.1
Mean Daily Temperature Range	5% DB	MDBR	10.9	12.6	14.3	15.0	17.0	17.7	15.8	13.8	11.9	9.1	9.9	10.1
		MCDBR	12.9	13.0	14.4	17.2	22.2	22.7	22.2	20.5	17.9	9.5	9.5	10.7
		MCWBR	11.7	11.2	10.9	10.2	11.1	10.2	9.9	10.3	10.0	7.0	8.5	9.8
	5% WB	MCDBR	12.2	13.0	13.3	16.3	20.2	19.4	18.7	16.5	14.6	8.6	8.7	10.4
		MCWBR	11.3	11.5	10.5	9.9	10.5	9.6	9.3	9.2	9.0	6.7	7.9	9.7
Clear-Sky Solar Irradiance	taub	0.159	0.229	0.244	0.296	0.338	0.350	0.353	0.350	0.294	0.250	0.162	0.163	
	taud	1.927	2.192	2.287	2.224	2.357	2.380	2.409	2.428	2.551	2.373	1.944	1.935	
	Ebn at Noon	102	212	269	276	274	272	268	256	252	204	93	17	
	Edh at Noon	5	16	23	33	33	33	31	28	19	13	5	1	
All-Sky Solar Radiation	RadAvg	35	233	806	1460	1709	1806	1511	1114	680	259	61	5	
	RadStd	4	20	60	90	154	137	109	118	91	39	8	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+1.73	N/A	N/A	N/A	N/A	N/A	N/A	-603	N/A	N/A

Nomenclature: See separate page