

INDIAN MOUNTAIN, AK, USA

WMO: 701730

Lat: 66.000N

Lon: 153.700W

Elev: 389

StdP: 96.74

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26535

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.3	-35.7	-41.8	0.1	-37.1	-39.0	0.1	-34.2	15.5	-17.0	14.2	-17.0	0.1	330	0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	24.5	14.7	22.7	13.9	21.0	13.2	15.8	21.9	15.0	20.7	14.1	19.4	2.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	10.1	17.0	12.6	9.5	16.5	11.7	8.9	15.9	45.5	21.8	42.8	20.7	40.6	19.4	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	9.6	8.2	-39.3	26.9	2.9	1.6	-41.3	28.1	-43.0	29.1	-44.6	30.0	-46.7	31.2		
(5)			-38.7	16.9	2.2	1.0	-40.3	17.6	-41.6	18.2	-42.9	18.8	-44.5	19.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.8	-19.7	-16.5	-13.0	-2.6	7.2	13.7	14.9	11.0	5.8	-5.1	-14.0	-16.8		
	DBStd	13.87	9.59	8.56	6.92	6.00	4.45	3.11	3.14	3.33	4.21	5.87	6.68	7.57		
	HDD10.0	5048	920	742	713	379	108	6	3	27	132	467	720	832		
	HDD18.3	7743	1178	976	971	629	346	142	112	228	375	726	970	1090		
	CDD10.0	356	0	0	0	0	19	116	156	58	7	0	0	0		
	CDD18.3	11	0	0	0	0	0	3	7	1	0	0	0	0		
	CDH23.3	104	0	0	0	0	1	30	64	9	0	0	0	0		
	CDH26.7	8	0	0	0	0	0	2	6	0	0	0	0	0		
(14) Wind	WSAvg	2.6	2.8	2.5	3.3	3.1	2.6	2.3	2.1	1.9	2.5	2.5	2.7	2.9		
(15) Precipitation	PrecAvg	421	26	26	19	14	20	38	56	66	52	40	32	31		
	PrecMax	552	68	91	52	59	44	107	113	155	121	107	96	97		
	PrecMin	308	1	1	0	2	2	10	29	11	22	11	2	7		
	PrecStd	75	16	19	12	12	11	18	18	27	28	21	24	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.6	0.7	4.0	12.3	22.0	26.2	27.7	24.7	18.1	6.9	0.5	0.3		
		MCWB	-0.7	-0.7	0.7	5.6	11.8	15.0	15.7	15.7	10.1	3.6	-1.3	-0.3		
	2%	DB	-2.0	-1.3	0.8	9.4	19.0	23.9	25.2	21.7	15.4	4.8	-1.1	-2.6		
		MCWB	-2.9	-3.1	-1.3	3.7	9.9	13.6	15.1	14.2	9.5	2.9	-2.1	-3.5		
	5%	DB	-4.4	-3.2	-1.1	7.6	17.0	22.3	23.4	18.8	13.6	3.3	-2.6	-5.2		
		MCWB	-5.3	-4.6	-3.5	2.6	8.9	12.8	14.5	12.9	8.7	1.7	-3.3	-6.1		
	10%	DB	-7.2	-5.1	-3.2	5.7	15.1	20.6	21.7	16.8	11.9	1.9	-4.9	-7.1		
		MCWB	-8.1	-6.3	-5.2	1.6	7.7	12.1	14.1	12.0	8.1	0.6	-5.7	-8.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.5	0.1	1.2	5.8	12.8	15.9	17.3	16.9	11.5	4.8	-0.9	-0.3		
		MCDB	0.7	0.5	3.0	11.5	20.0	23.1	23.4	22.1	15.0	5.5	-0.4	0.0		
	2%	WB	-2.7	-2.8	-0.9	4.1	11.2	14.7	16.3	15.1	10.2	3.4	-2.0	-3.4		
		MCDB	-2.0	-1.3	0.8	8.3	17.0	21.4	22.6	19.6	13.7	4.2	-1.3	-2.7		
	5%	WB	-5.1	-4.6	-3.3	3.0	9.7	13.9	15.4	13.9	9.5	1.9	-3.4	-6.0		
		MCDB	-4.3	-3.4	-1.4	7.1	15.5	20.3	21.5	17.6	12.6	3.0	-2.4	-5.3		
	10%	WB	-8.1	-6.3	-5.2	1.8	8.4	12.9	14.7	12.8	8.6	0.7	-5.6	-8.0		
		MCDB	-7.2	-5.1	-3.2	5.6	14.4	18.9	20.3	16.1	11.3	1.7	-4.8	-7.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	7.0	7.9	8.3	9.4	9.8	8.8	7.7	6.6	5.1	5.5	5.6		
		MCDBR	7.1	7.2	8.0	9.6	12.3	12.6	12.3	11.4	9.9	5.3	5.3	6.0		
		MCWBR	6.5	6.2	6.1	5.7	6.2	5.7	5.5	5.7	5.5	3.9	4.7	5.4		
		MCDBR	6.8	7.2	7.4	9.0	11.2	10.8	10.4	9.2	8.1	4.8	4.8	5.8		
	5% WB	MCWBR	6.3	6.4	5.8	5.5	5.8	5.3	5.2	5.1	5.0	3.7	4.4	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.159	0.229	0.244	0.296	0.338	0.350	0.353	0.350	0.294	0.250	0.162	0.163		
	taud		1.927	2.192	2.287	2.224	2.357	2.380	2.409	2.428	2.551	2.373	1.944	1.935		
	Ebn at Noon		320	668	849	869	864	859	844	807	794	644	293	53		
	Edh at Noon		17	49	74	104	103	103	97	87	60	41	15	4		
(44) All-Sky Solar Radiation	RadAvg		0.11	0.73	2.54	4.60	5.39	5.69	4.76	3.51	2.14	0.82	0.19	0.02		
	RadStd		0.01	0.06	0.19	0.28	0.48	0.43	0.34	0.37	0.29	0.12	0.03	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.96	N/A	N/A	N/A	N/A	N/A	N/A	-335	N/A	N/A

Nomenclature: See separate page