

GOLOVIN, AK, USA

WMO: 701995

Lat: 64.550N

Lon: 163.007W

Elev: 8

StdP: 101.23

Time Zone: -9.00 (NAK)

Period: 99-19

WBAN: 26628

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.0	-29.0	-33.8	0.2	-27.0	-32.8	0.2	-26.4	19.1	-4.9	17.6	-5.5	3.3	320	0.844

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	22.0	15.3	19.0	14.0	17.6	13.2	15.8	19.8	14.8	18.4	13.8	17.3	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	9.9	17.5	12.7	9.2	16.4	12.1	8.8	15.8	44.1	19.8	41.1	18.3	38.5	17.3	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	13.3	11.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.6	-13.6	-12.0	-12.2	-4.2	2.8	10.4	12.6	11.8	6.7	-0.3	-9.0	-13.3
	DBStd	11.63	9.49	8.02	7.00	5.80	5.08	3.81	2.98	3.44	3.52	4.77	6.52	8.30
	HDD10.0	4466	731	615	689	424	228	38	8	17	107	318	571	721
	HDD18.3	7288	989	848	947	674	481	239	179	206	348	576	821	979
	CDD10.0	226	0	0	0	0	6	51	88	73	8	0	0	0
	CDD18.3	7	0	0	0	0	0	2	2	3	0	0	0	0
	CDH23.3	32	0	0	0	0	1	17	10	5	0	0	0	0
	CDH26.7	5	0	0	0	0	0	4	1	0	0	0	0	0
Wind	WSAvg	4.6	5.6	5.7	4.8	4.7	3.6	3.5	3.9	4.1	4.8	4.5	4.9	5.2
Precipitation	PrecAvg	619	42	43	32	27	28	37	68	93	78	67	56	46
	PrecMax	845	86	134	90	65	68	63	142	189	163	140	117	87
	PrecMin	448	12	10	8	8	10	17	19	28	20	30	9	19
	PrecStd	94	21	27	21	15	14	12	28	33	32	31	29	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	2.9	2.8	9.8	20.9	26.1	24.2	23.7	17.0	10.9	5.4	4.0
		MCWB	0.4	0.9	0.3	5.0	12.1	15.1	15.5	16.4	11.1	8.3	3.0	0.8
	2%	DB	2.0	2.1	1.2	7.3	14.9	21.0	21.2	21.3	13.8	7.8	3.0	2.4
		MCWB	0.3	0.1	-0.4	3.2	8.9	14.0	15.0	15.5	10.3	6.0	1.9	0.7
	5%	DB	0.9	0.9	-0.1	5.3	12.3	17.9	18.8	18.8	12.5	7.2	2.1	1.0
		MCWB	-0.6	-0.7	-0.9	1.9	7.6	12.7	14.6	14.0	10.1	5.3	1.0	-0.5
	10%	DB	-1.2	-1.2	-1.4	3.6	9.2	16.3	17.4	17.2	11.6	6.1	0.2	-2.0
		MCWB	-2.3	-2.1	-2.3	0.9	6.0	11.9	13.5	13.3	9.6	4.3	-0.6	-3.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.1	1.9	1.2	4.8	12.3	16.2	17.5	17.6	12.3	8.0	3.5	1.8
		MCDB	2.0	2.8	2.3	9.2	19.1	20.8	22.3	21.7	14.4	9.5	4.6	2.8
	2%	WB	0.2	0.1	0.0	3.4	9.9	14.8	15.7	16.0	11.2	6.6	2.2	0.7
		MCDB	1.4	1.4	0.9	6.8	14.6	19.8	19.3	20.1	13.0	7.8	3.3	2.5
	5%	WB	-0.8	-1.0	-1.0	2.3	8.0	13.5	14.7	14.8	10.5	5.6	0.7	-0.8
		MCDB	0.5	0.1	-0.3	5.2	11.1	17.7	18.2	17.9	12.2	7.1	1.7	0.6
	10%	WB	-2.3	-2.2	-2.8	1.2	6.5	12.2	13.8	13.7	9.8	4.5	-0.6	-3.0
		MCDB	-1.4	-1.4	-1.9	3.3	9.6	16.0	17.2	16.7	11.5	6.1	0.2	-2.0
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.4	7.8	7.9	7.1	6.8	5.3	5.7	5.4	4.6	5.2	6.3
		MCDBR	6.5	5.9	6.0	8.5	11.1	10.0	9.1	7.2	6.2	4.6	4.1	6.0
		MCWBR	5.7	5.2	4.9	5.9	6.6	5.9	5.3	4.4	4.2	3.6	3.8	5.0
	5% WB	MCDBR	6.5	5.8	4.9	8.2	10.0	9.2	8.1	6.2	5.0	4.3	3.9	5.6
		MCWBR	6.0	5.3	4.3	5.9	6.2	5.7	5.1	4.3	3.6	3.7	3.8	4.8
Clear-Sky Solar Irradiance	taub	0.180	0.256	0.265	0.335	0.356	0.352	0.359	0.389	0.316	0.279	0.366	0.180	
	taud	1.917	2.135	2.242	2.091	2.260	2.431	2.448	2.341	2.540	2.386	2.788	1.899	
	Ebn at Noon	374	649	829	825	848	864	846	771	780	637	340	122	
	Edh at Noon	25	59	82	123	115	99	95	97	64	46	23	9	
All-Sky Solar Radiation	RadAvg	0.15	0.79	2.56	4.46	5.24	5.76	4.57	3.52	2.20	0.90	0.22	0.05	
	RadStd	0.02	0.11	0.26	0.29	0.48	0.52	0.30	0.45	0.21	0.12	0.04	0.00	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.83	N/A	N/A	N/A	+0.48	+0.55	N/A	N/A	+35	N/A

Nomenclature: See separate page