

ST MARY'S, AK, USA

WMO: 702005

Lat: 62.062N

Lon: 163.300W

Elev: 95

StdP: 100.19

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26647

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.8	(c) -27.5	(d) -33.7	(e) 0.2	(f) -26.9	(g) -32.5	(h) 0.2	(i) -25.6	(j) 16.0	(k) -7.9	(l) 15.1	(m) -8.4	(n) 2.7	(o) 40	(p) 0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	22.0	14.4	19.1	13.4	17.6	12.4	15.4	19.8	14.3	18.1	13.3	16.6	4.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	9.7	16.4	12.5	9.1	15.4	11.6	8.6	14.7	43.2	20.1	40.1	18.1	37.6	16.6	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.4	11.9	10.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-31.9	24.0	3.6	2.5	-34.5	25.8	-36.6	27.2	-38.7	28.6	-41.3	30.4
			-30.8	16.8	2.9	1.9	-32.8	18.2	-34.5	19.4	-36.1	20.4	-38.2	21.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.2	-13.5	-11.0	-11.2	-3.3	4.6	10.4	12.1	10.9	6.8	-0.9	-7.7	-12.4
	DBStd	11.17	8.64	8.16	7.43	6.39	4.60	3.11	2.78	2.83	3.27	4.72	6.49	7.73
	HDD10.0	4274	729	589	659	399	173	30	10	21	101	338	531	694
	HDD18.3	7138	988	823	917	649	424	237	196	231	345	596	781	952
	CDD10.0	179	0	0	0	0	7	43	74	49	6	0	0	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	20	0	0	0	0	1	4	11	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	4.9	5.8	6.2	5.4	5.2	4.5	4.0	3.9	4.1	4.2	4.4	5.2	5.5
Precipitation	PrecAvg	632	44	45	37	32	32	42	61	82	79	65	63	50
	PrecMax	861	92	124	122	67	71	73	112	157	154	109	146	107
	PrecMin	506	9	12	8	7	10	16	24	31	6	12	7	17
	PrecStd	90	22	27	25	16	15	11	21	25	29	24	35	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.0	2.7	3.5	12.1	22.0	23.7	24.8	22.7	17.1	10.2	11.1	3.5
		MCWB	1.0	1.1	1.4	6.1	11.6	14.5	17.2	16.4	11.4	7.4	5.7	0.7
	2%	DB	2.0	1.7	2.2	8.7	17.3	21.3	22.0	19.1	14.1	8.1	5.8	2.0
		MCWB	0.9	0.6	0.7	4.4	9.8	13.5	14.9	14.6	10.2	6.6	3.7	1.1
	5%	DB	0.2	0.9	1.0	6.3	14.6	18.8	19.1	17.4	12.6	7.0	2.4	0.2
		MCWB	-0.3	0.0	-0.1	2.9	8.4	12.4	14.1	13.2	9.9	5.6	1.4	-0.3
	10%	DB	-2.0	-0.5	-1.0	4.0	12.4	17.2	17.5	15.8	11.4	5.4	1.1	-1.6
		MCWB	-2.6	-1.0	-1.7	1.6	7.4	11.4	13.1	12.6	9.3	4.0	0.3	-2.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	1.5	1.8	6.2	11.9	15.7	17.7	17.3	12.6	8.4	5.9	1.7
		MCDB	2.7	2.1	3.0	10.6	19.6	22.2	23.8	21.2	15.2	9.2	9.5	2.4
	2%	WB	0.7	0.6	0.7	4.6	10.2	14.1	15.5	15.3	11.2	7.1	2.9	0.6
		MCDB	1.6	1.3	1.6	8.2	16.3	19.1	19.9	19.0	13.4	8.0	4.3	1.6
	5%	WB	-0.3	-0.1	-0.2	3.2	8.9	12.9	14.6	14.0	10.3	5.7	1.3	-0.3
		MCDB	0.3	0.6	0.7	6.2	14.1	17.8	18.5	16.6	12.2	6.9	2.4	0.4
	10%	WB	-2.3	-1.2	-1.7	1.9	7.7	11.8	13.6	12.8	9.5	4.3	0.1	-2.1
		MCDB	-1.9	-0.7	-1.1	4.1	11.9	16.3	17.1	14.9	11.3	5.6	1.1	-1.8
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.6	6.6	7.0	8.4	9.0	7.1	6.3	6.1	5.2	4.7	5.3
		MCDBR	5.2	5.3	5.9	8.3	13.1	13.1	11.5	9.4	8.2	5.4	4.3	6.0
		MCWBR	4.8	4.9	4.8	5.5	7.4	7.0	6.2	5.5	5.1	4.2	4.0	5.6
	5% WB	MCDBR	5.2	5.4	5.4	8.0	12.3	11.5	10.2	8.1	6.8	4.9	3.9	5.9
		MCWBR	4.9	5.0	4.6	5.5	7.1	6.4	5.8	5.0	4.6	4.1	3.9	5.7
Clear-Sky Solar Irradiance	taub		0.210	0.270	0.276	0.345	0.371	0.365	0.365	0.382	0.324	0.287	0.230	0.197
	taud		2.036	2.166	2.234	2.094	2.261	2.379	2.417	2.345	2.503	2.402	2.018	1.882
	Ebn at Noon		487	691	841	831	844	859	849	795	791	683	425	271
	Edh at Noon		35	66	89	127	118	107	101	100	71	53	35	22
All-Sky Solar Radiation	RadAvg		0.31	1.01	2.83	4.46	5.09	5.26	4.26	3.39	2.24	1.09	0.36	0.14
	RadStd		0.04	0.12	0.25	0.34	0.48	0.54	0.34	0.43	0.20	0.09	0.06	0.01

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	+1.67	+1.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page