

KALTAG, AK, USA

WMO: 702006

Lat: 64.327N

Lon: 158.742W

Elev: 181

StdP: 14.60

Time Zone: -9.00 (NAK)

Period: 99-19

WBAN: 26502

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.0	-38.6	-34.9	0.8	-28.1	-33.0	0.9	-27.4	24.2	4.3	21.1	7.0	1.0	230	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	78.0	60.7	74.1	59.2	70.9	57.9	63.1	74.4	61.0	70.9	59.2	68.2	6.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	73.2	66.2	56.5	68.6	64.1	54.9	64.6	62.4	28.5	74.6	27.1	70.6	25.9	68.3	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.8	14.8	-46.1	84.4	4.6	3.2	-49.4	86.8	-52.0	88.7	-54.6	90.5	-57.9	92.8		
(5)			-34.1	65.8	2.0	2.1	-35.6	67.3	-36.8	68.5	-37.9	69.7	-39.4	71.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	-3.4	5.9	8.7	27.0	44.5	56.1	57.9	53.7	44.9	28.4	8.3	-0.3		
	DBStd	25.52	21.55	16.34	12.92	10.86	8.75	5.64	5.55	5.58	7.25	10.63	14.49	17.25		
	HDD50	8778	1657	1234	1280	691	209	13	5	28	181	669	1251	1560		
	HDD65	13610	2122	1654	1745	1141	635	270	229	351	603	1134	1701	2025		
	CDD50	656	0	0	0	0	39	197	250	143	27	0	0	0		
	CDD65	13	0	0	0	0	0	3	9	1	0	0	0	0		
	CDH74	330	0	0	0	0	26	102	165	29	8	0	0	0		
	CDH80	43	0	0	0	0	1	10	27	3	2	0	0	0		
	WSAvg	4.8	5.2	4.9	5.9	5.4	4.8	4.9	4.4	3.9	3.9	4.4	4.9	5.0		
	PrecAvg	20.7	1.4	1.3	1.1	0.8	1.0	1.6	2.5	3.3	2.5	1.9	1.7	1.5		
(15) Precipitation	PrecMax	25.7	3.0	3.6	2.9	1.9	1.9	2.6	4.7	5.8	4.3	5.4	4.4	3.5		
	PrecMin	14.7	0.4	0.4	0.1	0.1	0.3	0.7	0.9	1.4	1.1	0.6	0.2	0.4		
	PrecStd	3.2	0.7	0.7	0.7	0.5	0.4	0.6	0.9	0.9	1.0	1.0	1.0	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.5	42.8	38.0	54.8	77.9	81.4	83.8	78.8	71.4	50.4	37.0	36.1		
		MCWB	34.7	35.0	32.8	42.9	56.9	61.2	66.1	64.1	56.6	43.6	34.6	33.3		
	2%	DB	33.8	34.6	34.4	49.5	70.7	76.8	78.5	71.9	63.3	46.9	34.1	31.9		
		MCWB	32.5	31.8	31.1	39.9	53.5	58.6	62.2	61.0	53.1	42.5	32.5	30.5		
	5%	DB	29.7	31.3	31.6	46.1	65.3	73.2	74.7	67.3	59.2	44.5	31.7	27.2		
		MCWB	27.8	28.9	28.6	38.1	50.3	57.4	60.7	58.2	51.1	40.7	30.4	24.8		
	10%	DB	24.8	27.5	28.0	42.4	60.9	70.2	71.1	64.0	55.8	41.3	27.8	22.4		
		MCWB	23.0	25.4	25.6	36.0	48.7	56.3	59.7	56.6	50.0	38.8	26.2	20.7		
	0.4%	WB	35.2	36.3	34.5	43.6	57.4	64.0	66.8	65.2	57.5	46.4	35.1	34.3		
		MCDB	37.6	40.8	36.9	53.6	76.3	77.5	80.7	75.2	68.3	48.7	36.2	35.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.8	32.6	32.0	40.4	54.4	61.1	63.8	62.1	54.2	43.6	32.6	30.5		
		MCDB	34.2	34.5	34.0	48.2	68.5	72.9	76.1	70.0	60.8	46.0	33.7	31.8		
	5%	WB	28.4	29.3	28.6	38.5	52.0	59.1	61.7	59.7	52.3	41.3	30.2	25.8		
		MCDB	30.1	31.4	31.0	45.1	62.8	70.0	72.4	65.8	57.4	43.9	31.5	27.6		
	10%	WB	24.3	25.6	25.6	36.6	49.7	57.3	59.9	57.8	50.7	38.9	26.3	21.2		
		MCDB	26.0	27.9	28.4	41.9	59.1	67.2	69.7	63.1	55.2	41.2	27.8	22.9		
	5% DB	MDBR	14.5	17.7	21.4	19.7	21.1	21.7	18.1	17.1	16.0	11.9	13.4	14.1		
		MCDBR	14.3	16.0	19.3	22.1	30.3	29.1	27.5	23.3	23.1	13.1	9.4	12.4		
		MCWBR	12.5	13.6	15.8	13.6	15.5	13.9	13.9	13.4	14.2	9.6	8.6	11.1		
		MCWBR	13.1	15.7	16.5	19.4	26.6	25.0	24.8	19.7	18.8	11.2	9.3	11.3		
(35) Mean Daily Temperature Range	5% WB	MCWBR	11.5	13.9	13.9	12.4	13.9	13.0	13.0	12.1	12.1	8.7	8.8	10.4		
	Clear-Sky Solar Irradiance	taub	0.184	0.256	0.263	0.323	0.344	0.361	0.365	0.364	0.309	0.280	0.184	0.182		
		taud	1.942	2.170	2.259	2.164	2.364	2.378	2.407	2.426	2.551	2.373	1.948	1.916		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	123	210	266	268	274	271	266	255	251	203	116	44		
		Edh at Noon	8	18	26	36	33	33	32	28	20	15	8	3		
(44) All-Sky Solar Radiation	RadStd	RadAvg	56	254	818	1418	1671	1721	1429	1087	689	285	83	19		
		RadStd	8	31	71	90	177	156	98	126	82	44	12	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page