

SPARREVOHN, AK, USA

WMO: 702350

Lat: 61.100N

Lon: 155.583W

Elev: 1588

StdP: 13.87

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26534

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.2	-21.6	-33.5	0.9	-25.9	-28.6	1.2	-21.0	35.8	36.4	31.7	28.8	2.4	170	0.737

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	72.9	57.5	69.0	55.7	65.5	54.0	59.6	69.8	57.4	65.6	55.7	63.2	6.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.2	68.9	62.4	53.4	64.4	60.1	51.9	60.8	58.6	26.7	70.0	25.3	65.8	24.2	63.3	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.7	20.9	17.4	-29.5	78.7	4.2	3.9	-32.5	81.5	-35.0	83.8	-37.4	86.0	-40.5	88.9		
			-28.5	63.2	6.4	4.7	-33.1	66.6	-36.8	69.4	-40.4	72.0	-45.1	75.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.5	9.5	16.8	18.6	32.1	44.8	52.8	55.6	52.6	45.0	30.9	16.6	14.0	
	DBStd	20.37	20.02	16.74	13.63	9.67	7.35	5.92	5.62	5.51	6.68	10.40	14.28	16.81	
	HDD50	6846	1257	929	973	537	194	32	10	32	171	593	1003	1115	
	HDD65	11865	1722	1349	1438	986	627	369	296	387	602	1056	1453	1580	
	CDD50	466	0	0	0	0	32	116	185	112	19	2	0	0	
	CDD65	11	0	0	0	0	0	3	6	2	0	0	0	0	
	CDH74	84	0	0	0	0	1	25	44	14	0	0	0	0	
	CDH80	6	0	0	0	0	0	1	5	0	0	0	0	0	
Wind	WSAvg	5.7	5.1	5.9	6.3	6.2	6.2	5.0	4.8	5.4	5.6	6.0	5.8	5.6	
Precipitation	PrecAvg	27.3	2.0	1.7	1.5	1.5	1.6	2.2	3.1	3.5	3.1	2.5	2.3	2.3	
	PrecMax	33.3	4.4	3.6	3.3	2.4	3.0	3.1	4.6	5.3	5.4	4.8	5.1	3.7	
	PrecMin	21.3	0.6	0.2	0.3	0.4	0.4	1.1	1.5	1.5	0.9	0.5	0.2	0.8	
	PrecStd	3.1	0.9	0.7	0.7	0.5	0.6	0.6	0.7	0.9	1.2	1.0	1.2	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	45.2	44.4	55.0	71.9	77.6	79.7	76.6	64.5	56.0	47.6	47.2	
		MCWB	39.8	37.0	35.8	43.0	51.3	58.2	61.5	63.7	52.4	45.6	37.9	38.6	
	2%	DB	42.9	41.7	41.2	49.8	66.1	71.6	73.1	69.5	59.6	51.1	43.9	42.0	
		MCWB	36.5	34.7	33.8	38.7	50.0	56.1	58.4	58.3	49.9	42.7	38.2	34.6	
	5%	DB	39.8	38.7	38.8	46.7	61.2	67.5	69.2	64.6	56.6	47.8	40.5	39.1	
		MCWB	33.6	32.4	32.2	37.3	47.1	53.5	57.1	55.2	48.5	41.7	35.4	33.0	
	10%	DB	36.8	36.4	36.3	44.2	56.7	63.6	65.5	61.3	53.7	44.7	36.7	36.3	
		MCWB	31.7	31.0	31.1	36.0	44.8	51.8	55.6	53.8	47.1	39.4	33.1	31.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.0	37.9	37.3	44.3	53.2	60.8	62.6	62.7	53.5	48.2	42.1	39.4
			MCDB	47.1	43.7	43.4	52.7	67.8	73.4	75.5	73.7	61.2	53.2	44.0	44.1
2%		WB	37.3	35.5	34.8	40.2	50.7	57.3	60.0	59.2	51.2	44.3	38.3	35.3	
		MCDB	42.3	40.7	39.2	47.6	63.8	68.7	70.8	67.8	57.6	49.3	42.3	40.4	
5%		WB	34.1	33.2	33.1	38.0	48.4	55.0	58.0	56.8	49.7	42.0	35.6	33.5	
		MCDB	38.9	37.3	37.6	45.3	59.6	65.1	66.8	62.5	54.8	46.5	40.1	38.0	
10%		WB	32.0	31.6	31.4	36.4	46.0	52.9	56.4	54.7	48.2	40.0	32.9	31.8	
		MCDB	36.3	35.8	36.2	43.2	55.3	61.5	64.1	60.2	52.7	43.8	36.5	35.8	
Mean Daily Temperature Range		5% DB	MDBR	13.4	13.0	13.4	13.2	14.8	15.2	13.0	11.5	10.8	9.6	12.2	13.1
			MCDBR	11.7	11.8	12.0	14.9	21.2	20.1	19.0	17.3	14.5	10.6	12.2	12.1
	MCWBR		7.9	8.4	8.0	8.4	10.5	9.1	8.7	8.7	8.1	6.6	8.2	8.3	
	5% WB	MCDBR	11.3	11.1	10.6	14.2	19.5	18.3	17.0	15.5	12.9	9.2	11.6	11.5	
		MCWBR	8.1	8.3	7.4	8.2	9.9	8.8	8.5	8.3	7.9	6.3	8.6	8.7	
Clear-Sky Solar Irradiance	taub	0.214	0.255	0.268	0.320	0.343	0.346	0.341	0.342	0.302	0.275	0.220	0.189		
	taud	2.105	2.282	2.288	2.227	2.385	2.423	2.476	2.471	2.566	2.480	2.106	1.926		
	Ebn at Noon	172	239	275	276	279	280	279	269	264	232	163	116		
	Edh at Noon	12	19	27	36	33	33	30	28	21	16	11	8		
All-Sky Solar Radiation	RadAvg	111	341	916	1452	1600	1633	1365	1074	732	353	139	57		
	RadStd	15	43	100	125	182	126	138	139	109	41	22	6		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	+5.69	+5.00	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page