

PILOT POINT, AK, USA

WMO: 702626

Lat: 57.580N

Lon: 157.580W

Elev: 56

StdP: 14.67

Time Zone: -9.00 (NAK)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-11.9	-7.7	-19.5	1.9	-11.7	-14.8	2.5	-7.4	33.5	20.0	30.8	20.5	5.9	40	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	65.8	57.0	63.2	56.0	60.9	55.2	59.2	63.9	57.4	61.5	55.9	59.6	11.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.8	68.9	60.9	55.2	64.9	59.3	53.9	61.9	57.9	25.8	63.7	24.7	61.6	23.7	59.7	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.3	27.5	24.7	DB	-16.6	71.9	6.9	3.2	-21.5	74.2	-25.5	76.0	-29.4	77.8	-34.4	80.1	(4)
(5)			WB	-17.1	62.0	6.6	3.3	-21.8	64.3	-25.7	66.3	-29.4	68.2	-34.2	70.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.2	21.6	23.6	21.5	33.8	41.6	48.0	52.4	53.7	48.7	38.6	26.8	23.7	(6)	
	DBStd	15.25	14.79	12.46	11.51	7.42	5.44	4.99	4.52	3.92	4.95	7.74	11.73	13.42	(7)	
	HDD50	5328	881	738	883	486	264	93	28	8	78	358	697	814	(8)	
	HDD65	10500	1346	1158	1348	936	727	511	390	350	489	819	1147	1279	(9)	
	CDD50	303	0	0	0	0	2	32	103	123	39	4	0	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	1	0	0	0	0	0	0	0	1	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	11.2	10.6	10.7	10.4	12.2	11.9	11.0	10.6	11.2	11.5	11.3	11.0	11.5	(14)
	Precipitation	PrecAvg	33.2	2.8	2.3	2.1	1.7	1.9	2.2	2.9	3.2	4.0	3.4	3.2	(15)	
(16)		PrecMax	48.0	6.5	4.6	6.1	3.1	4.2	3.7	4.8	5.2	8.0	6.2	7.2	(16)	
(17)		PrecMin	21.3	0.6	0.4	0.2	0.3	0.3	1.1	1.5	0.8	0.3	0.5	0.7	(17)	
(18)		PrecStd	6.1	1.3	1.1	1.4	0.7	0.9	0.6	0.8	1.1	1.5	1.3	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.1	43.4	46.0	51.5	63.1	68.6	70.5	70.3	65.7	56.2	50.3	45.5	(19)	
		MCWB	40.6	39.7	40.8	43.2	49.9	56.0	59.9	60.6	57.4	50.7	47.5	42.2	(20)	
	2%	DB	42.5	41.3	42.1	48.4	56.1	63.2	65.9	64.6	60.7	54.0	47.7	42.9	(21)	
		MCWB	39.5	38.3	37.9	41.7	47.4	53.5	57.7	58.1	55.0	49.8	45.7	39.7	(22)	
	5%	DB	40.1	38.9	38.9	46.2	52.9	59.3	63.0	62.6	57.5	51.9	44.8	40.5	(23)	
		MCWB	37.8	36.4	35.9	40.7	46.1	51.7	56.0	57.0	52.7	48.6	42.1	38.1	(24)	
	10%	DB	38.4	37.0	36.6	44.7	50.0	56.3	60.4	60.6	55.4	49.6	41.4	38.5	(25)	
		MCWB	36.2	34.8	34.3	39.8	44.8	50.1	55.2	56.1	51.4	46.4	39.7	36.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	40.4	41.4	44.4	50.6	57.2	61.0	62.2	59.6	52.2	48.0	42.5	(27)	
		MCDB	44.4	42.7	45.1	48.9	59.4	65.4	67.8	67.5	63.9	55.0	49.6	45.0	(28)	
	2%	WB	39.7	38.6	38.4	42.5	48.4	54.6	58.8	59.5	56.0	50.5	45.9	40.3	(29)	
		MCDB	41.9	40.9	41.4	47.0	55.1	61.4	64.4	63.4	58.9	53.2	47.7	42.6	(30)	
	5%	WB	38.1	36.7	36.4	41.3	46.7	52.6	57.0	57.9	53.9	48.7	42.3	38.3	(31)	
		MCDB	40.0	38.7	38.5	45.7	51.9	58.3	61.5	61.5	56.9	51.4	44.4	40.1	(32)	
	10%	WB	36.5	35.1	34.4	40.0	45.3	50.8	55.4	56.4	52.1	46.4	39.4	36.8	(33)	
		MCDB	38.4	36.9	36.4	44.3	49.5	55.5	59.3	59.8	55.2	49.0	41.6	38.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.5	11.7	13.0	12.6	11.9	11.6	10.0	9.4	10.3	11.0	11.0	10.9	(35)	
		MCDBR	8.9	10.9	13.4	15.1	17.7	19.2	16.8	14.2	13.1	11.6	8.7	9.1	(36)	
		MCWBR	7.1	9.2	10.1	9.9	10.3	10.7	9.7	8.7	8.3	8.6	7.5	7.6	(37)	
	5% WB	MCDBR	8.6	10.9	12.5	13.8	15.8	17.3	14.3	12.6	12.6	10.8	8.4	8.6	(38)	
		MCWBR	7.2	9.5	9.9	9.1	9.8	10.0	8.8	8.1	8.8	8.6	7.6	7.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.295	0.321	0.324	0.374	0.386	0.371	0.368	0.366	0.346	0.317	0.311	0.284	(40)	
	taud		2.137	2.224	2.259	2.192	2.267	2.398	2.453	2.452	2.466	2.415	2.135	2.069	(41)	
	Ebn at Noon		171	225	261	264	269	275	274	266	254	229	159	134	(42)	
	Edh at Noon		17	25	31	39	39	35	32	30	25	20	17	14	(43)	
(44) All-Sky Solar Radiation	RadAvg		140	302	769	1151	1432	1585	1319	1089	759	413	176	89	(44)	
	RadStd		20	51	138	134	154	156	127	114	82	41	22	8	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page