

PILOT POINT, AK, USA

WMO: 702626

Lat: 57.580N

Lon: 157.580W

Elev: 17

StdP: 101.12

Time Zone: -9.00 (NAK)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-24.4	-22.0	-28.6	0.3	-24.3	-26.0	0.4	-21.9	15.0	-6.7	13.8	-6.4	2.6	40	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	18.8	13.9	17.3	13.3	16.1	12.9	15.1	17.7	14.1	16.4	13.3	15.4	5.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	9.8	16.1	12.9	9.3	15.2	12.2	8.8	14.4	42.1	17.6	39.5	16.4	37.3	15.4	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.3	11.0	DB	-27.0	22.2	3.8	1.8	-29.7	23.4	-32.0	24.5	-34.1	25.5	-36.9	26.7	(4)
(5)			WB	-27.3	16.6	3.7	1.8	-29.9	18.0	-32.1	19.0	-34.1	20.1	-36.8	21.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-5.8	-4.7	-5.8	1.0	5.3	8.9	11.3	12.1	9.3	3.7	-2.9	-4.6	(6)	
	DBStd	8.47	8.21	6.92	6.39	4.12	3.02	2.77	2.51	2.18	2.75	4.30	6.51	7.45	(7)	
	HDD10.0	2960	489	410	491	270	147	52	16	4	43	199	387	452	(8)	
	HDD18.3	5833	748	643	749	520	404	284	217	194	272	455	637	711	(9)	
	CDD10.0	168	0	0	0	0	1	18	57	68	22	2	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	0	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.0	4.7	4.8	4.7	5.4	5.3	4.9	4.7	5.0	5.2	5.1	4.9	5.1	(14)	
(15) Precipitation	PrecAvg	843	70	58	53	42	49	57	74	82	101	86	87	82	(15)	
	PrecMax	1220	164	116	154	78	106	93	123	133	202	158	196	184	(16)	
	PrecMin	540	16	10	4	7	28	37	34	21	8	12	17	17	(17)	
	PrecStd	154	32	28	36	19	23	15	21	27	39	33	42	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	6.3	7.8	10.8	17.3	20.4	21.4	21.3	18.7	13.5	10.1	7.5	(19)	
		MCWB	4.8	4.3	4.9	6.2	9.9	13.4	15.5	15.9	14.1	10.4	8.6	5.7	(20)	
	2%	DB	5.9	5.2	5.6	9.1	13.4	17.4	18.8	18.1	16.0	12.2	8.7	6.1	(21)	
		MCWB	4.2	3.5	3.3	5.4	8.5	12.0	14.3	14.5	12.8	9.9	7.6	4.3	(22)	
	5%	DB	4.5	3.8	3.8	7.9	11.6	15.2	17.2	17.0	14.2	11.1	7.1	4.7	(23)	
		MCWB	3.2	2.5	2.1	4.8	7.9	10.9	13.3	13.9	11.5	9.2	5.6	3.4	(24)	
	10%	DB	3.5	2.8	2.5	7.0	10.0	13.5	15.8	15.9	13.0	9.8	5.2	3.6	(25)	
		MCWB	2.4	1.5	1.3	4.3	7.1	10.1	12.9	13.4	10.8	8.0	4.3	2.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	4.7	5.2	6.9	10.3	14.0	16.1	16.8	15.3	11.2	8.9	5.8	(27)	
		MCDB	6.9	6.0	7.3	9.4	15.2	18.6	19.9	19.7	17.7	12.8	9.8	7.2	(28)	
	2%	WB	4.3	3.7	3.6	5.8	9.1	12.6	14.9	15.3	13.3	10.3	7.7	4.6	(29)	
		MCDB	5.5	4.9	5.2	8.3	12.8	16.4	18.0	17.4	14.9	11.8	8.7	5.9	(30)	
	5%	WB	3.4	2.6	2.4	5.2	8.2	11.4	13.9	14.4	12.2	9.3	5.7	3.5	(31)	
		MCDB	4.5	3.7	3.6	7.6	11.0	14.6	16.4	16.4	13.8	10.8	6.9	4.5	(32)	
	10%	WB	2.5	1.7	1.3	4.5	7.4	10.5	13.0	13.6	11.2	8.0	4.1	2.6	(33)	
		MCDB	3.6	2.7	2.4	6.8	9.7	13.0	15.2	15.4	12.9	9.5	5.4	3.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.5	7.2	7.0	6.6	6.5	5.5	5.2	5.7	6.1	6.1	6.1	(35)	
		MCDBR	4.9	6.0	7.4	8.4	9.8	10.7	9.3	7.9	7.3	6.5	4.8	5.1	(36)	
	5% WB	MCWBR	4.0	5.1	5.6	5.5	5.7	6.0	5.4	4.8	4.6	4.8	4.2	4.2	(37)	
		MCWBR	4.8	6.0	6.9	7.7	8.8	9.6	7.9	7.0	6.0	4.7	4.7	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.295	0.321	0.324	0.374	0.386	0.371	0.368	0.366	0.346	0.317	0.311	0.284	(40)	
		taud	2.137	2.224	2.259	2.192	2.267	2.398	2.453	2.452	2.466	2.415	2.135	2.069	(41)	
	Ebn at Noon		538	708	823	832	847	868	863	838	801	721	502	421	(42)	
		Edh at Noon	54	78	97	122	122	109	101	94	80	64	54	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.44	0.95	2.42	3.63	4.51	5.00	4.16	3.43	2.39	1.30	0.56	0.28	(44)	
	RadStd		0.06	0.16	0.43	0.42	0.48	0.49	0.40	0.36	0.26	0.13	0.07	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page