

CORDOVA, AK, USA

WMO: 702960

Lat: 60.492N

Lon: 145.476W

Elev: 10

StdP: 101.21

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26410

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.5	-15.5	-23.3	0.5	-13.4	-20.8	0.6	-11.8	11.0	4.6	9.3	4.2	0.2	100	0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	21.7	14.7	19.6	14.1	17.7	13.4	16.1	19.9	15.0	18.2	14.0	16.7	2.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	10.2	17.8	13.3	9.5	16.1	12.6	9.1	15.1	44.9	20.0	41.6	18.3	39.0	16.8	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.4	5.9	DB	-21.1	25.6	3.3	2.7	-23.4	27.5	-25.4	29.0	-27.2	30.5	-29.6	32.5	(4)
(5)			WB	-21.3	18.2	3.2	2.0	-23.7	19.6	-25.6	20.8	-27.4	21.9	-29.7	23.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-2.7	-1.5	-0.5	3.4	7.5	10.8	12.6	12.3	9.3	4.7	-0.3	-1.6	(6)	
	DBStd	6.74	6.02	4.93	4.07	2.71	2.46	2.14	1.67	1.75	2.30	3.24	4.99	5.36	(7)	
	HDD10.0	2215	395	323	327	198	85	13	1	2	38	164	308	361	(8)	
	HDD18.3	5041	653	556	585	448	336	225	178	188	272	422	558	619	(9)	
	CDD10.0	217	0	0	0	1	7	38	81	73	17	1	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	26	0	0	0	0	1	13	5	8	0	0	0	0	(12)	
	CDH26.7	3	0	0	0	0	0	2	1	1	0	0	0	0	(13)	
(14) Wind	WSAvg	1.9	1.8	2.0	2.2	2.2	2.0	1.6	1.3	1.4	1.9	1.9	1.8	2.1	(14)	
(15) Precipitation	PrecAvg	2422	194	179	142	129	142	119	158	259	382	293	207	217	(15)	
	PrecMax	3347	404	323	412	254	305	257	238	521	730	520	489	411	(16)	
	PrecMin	1440	66	40	39	58	44	35	67	83	183	90	44	86	(17)	
	PrecStd	420	84	74	84	51	68	49	45	107	140	105	109	85	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	9.3	11.1	17.5	21.9	25.0	23.4	24.2	20.0	13.5	10.2	8.7	(19)	
		MCWB	5.3	4.1	6.0	9.9	12.2	16.3	16.8	16.0	13.8	9.4	6.8	5.7	(20)	
	2%	DB	7.1	6.5	7.8	12.8	18.9	21.3	20.3	20.8	17.2	12.0	8.6	7.1	(21)	
		MCWB	4.8	4.0	4.4	6.8	11.0	13.9	15.7	15.3	12.0	8.6	6.2	5.0	(22)	
	5%	DB	5.9	5.5	6.3	10.4	16.2	18.2	18.3	18.5	15.3	10.8	7.4	5.9	(23)	
		MCWB	3.9	3.5	3.4	5.7	10.1	13.3	14.7	14.5	11.3	8.0	5.3	4.2	(24)	
	10%	DB	4.8	4.5	5.1	8.6	13.7	16.0	16.8	16.9	13.9	9.7	6.2	4.9	(25)	
		MCWB	3.3	2.9	2.7	5.0	9.1	12.1	13.7	13.5	10.8	7.3	4.3	3.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	5.5	6.6	10.6	13.6	17.1	17.6	17.8	14.3	11.2	8.0	6.4	(27)	
		MCDB	8.2	7.5	9.8	16.6	19.3	23.9	22.4	22.0	17.3	12.5	9.3	7.7	(28)	
	2%	WB	5.1	4.6	5.1	7.8	11.8	15.0	16.1	16.0	13.0	9.8	6.7	5.4	(29)	
		MCDB	6.7	6.1	7.1	11.7	17.4	19.7	19.6	19.4	15.9	11.1	8.2	6.9	(30)	
	5%	WB	4.1	3.8	4.0	6.3	10.5	13.6	15.0	14.8	12.1	8.7	5.6	4.4	(31)	
		MCDB	5.5	5.2	5.6	9.3	15.0	17.5	17.9	17.7	14.4	10.2	7.1	5.7	(32)	
	10%	WB	3.4	3.1	3.1	5.4	9.5	12.4	14.0	13.9	11.3	7.7	4.5	3.5	(33)	
		MCDB	4.7	4.4	4.7	8.0	12.9	15.5	16.3	16.2	13.3	9.3	6.0	4.7	(34)	
(35) Mean Daily Temperature Range	MDBR		7.2	7.7	8.4	8.5	8.8	7.9	6.9	7.9	8.1	7.5	6.8	6.3	(35)	
	5% DB	MCDBR	6.3	6.5	9.1	13.0	16.2	14.9	11.9	13.0	12.1	8.9	6.3	5.3	(36)	
		MCWBR	4.6	4.5	6.1	8.1	9.6	9.0	8.0	8.6	7.9	5.9	4.5	3.9	(37)	
	5% WB	MCDBR	5.9	5.6	7.3	11.2	13.6	12.5	10.4	10.9	9.6	6.2	5.5	4.8	(38)	
		MCWBR	4.5	4.0	5.2	7.3	8.5	8.0	7.3	7.7	6.8	4.7	4.3	3.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.254	0.294	0.310	0.352	0.366	0.373	0.366	0.368	0.334	0.316	0.259	0.233	(40)	
	taud		2.132	2.251	2.270	2.206	2.267	2.330	2.417	2.410	2.486	2.339	2.128	1.988	(41)	
	Ebn at Noon		499	699	815	839	856	855	854	821	792	663	474	337	(42)	
	Edh at Noon		41	67	90	116	119	114	102	95	74	61	40	29	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.30	1.00	2.53	4.28	5.31	5.45	4.71	3.58	2.40	1.11	0.42	0.17	(44)	
	RadStd		0.03	0.16	0.26	0.39	0.29	0.24	0.30	0.41	0.34	0.14	0.06	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page