

KING COVE, AK, USA

WMO: 703059

Lat: 55.116N

Lon: 162.270W

Elev: 154

StdP: 14.61

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.5	12.1	0.0	5.5	11.0	2.8	6.4	13.3	51.6	14.1	44.6	22.2	15.9	280	0.874

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	62.1	55.8	59.1	54.3	57.0	53.3	57.1	60.4	55.4	57.6	54.3	56.3	11.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	65.6	57.5	54.4	63.2	56.5	53.3	60.8	55.5	24.5	60.5	23.5	57.6	22.8	56.3	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.2	33.5	28.7	7.1	67.4	4.3	4.8	4.0	70.9	1.4	73.7	-1.0	76.3	-4.1	79.8		
(5)			7.1	59.7	4.8	3.6	3.6	62.3	0.8	64.4	-2.0	66.4	-5.5	69.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.0	29.8	31.8	30.4	34.5	40.8	46.6	51.3	52.9	49.1	42.6	35.9	33.3		
	DBStd	9.78	8.18	6.93	7.55	5.26	4.27	3.13	3.24	3.30	3.63	4.78	6.04	6.66		
	HDD50	3861	626	508	606	464	287	109	21	9	57	232	424	518		
	HDD65	9138	1091	928	1071	914	751	552	426	375	478	695	874	983		
	CDD50	198	0	0	0	0	1	7	60	99	29	2	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.1	11.6	14.2	13.7	14.6	13.1	13.2	11.8	11.9	13.1	13.2	14.2	13.0		
	PrecAvg	42.6	3.3	3.1	3.0	2.8	2.7	2.7	2.5	3.7	4.6	4.8	4.9	4.5		
(15) Precipitation	PrecMax	83.3	6.1	7.6	7.1	6.1	6.9	8.0	5.3	6.5	7.1	9.9	12.4	13.5		
	PrecMin	28.5	0.6	0.6	1.1	0.3	0.3	0.5	0.5	1.5	2.2	1.5	1.3	1.8		
	PrecStd	10.4	1.5	1.9	1.5	1.5	1.5	1.7	1.1	1.4	1.4	2.0	2.4	2.4		
	PrecStd	10.4	1.5	1.9	1.5	1.5	1.5	1.7	1.1	1.4	1.4	2.0	2.4	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	44.3	44.2	44.9	48.0	60.5	60.8	65.1	66.1	59.6	53.8	51.2	46.2			
	0.4% MCWB	40.0	40.3	40.2	41.5	49.2	52.6	56.3	59.5	53.9	49.9	47.2	44.1			
	2% DB	42.3	42.2	42.4	44.9	52.3	56.6	61.3	62.8	57.2	52.0	48.1	44.6			
	2% MCWB	39.7	39.5	39.3	40.5	45.0	50.0	55.3	57.4	53.5	49.1	46.2	42.4			
	5% DB	40.6	40.7	40.6	42.9	48.3	54.2	58.2	59.9	55.7	50.6	46.0	42.9			
	5% MCWB	38.3	38.5	37.7	39.6	43.4	48.5	53.8	55.5	52.3	47.8	43.9	40.6			
	10% DB	39.0	39.4	38.9	41.1	46.1	52.0	56.0	57.3	54.4	49.0	44.4	41.1			
	10% MCWB	36.8	37.2	36.1	38.6	42.5	47.6	52.6	54.2	51.3	46.2	41.9	38.9			
	0.4% WB	41.8	42.1	41.8	43.7	49.9	53.7	58.2	61.3	57.0	51.6	49.0	45.1			
	0.4% MCDB	43.1	43.8	43.2	45.2	58.9	59.2	63.4	64.6	57.8	52.1	50.4	45.7			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	40.4	40.5	40.2	41.8	46.1	51.0	56.1	58.0	54.8	50.2	46.5	43.0			
	2% MCDB	41.7	41.6	41.9	43.8	50.5	55.0	59.7	61.7	56.0	51.4	47.6	44.3			
	5% WB	38.7	39.0	38.2	40.1	44.5	49.6	54.5	56.2	53.3	48.3	44.5	41.2			
	5% MCDB	40.1	40.1	40.0	42.4	47.1	53.0	57.4	58.7	54.8	49.8	46.0	42.9			
	10% WB	37.3	37.5	36.8	38.6	43.5	48.1	53.3	55.0	51.9	46.7	42.1	39.4			
	10% MCDB	38.7	38.7	38.5	40.8	45.7	51.1	55.6	56.8	53.8	48.5	44.3	41.0			
(35) Mean Daily Temperature Range	MDBR	8.4	8.0	9.6	8.4	8.9	8.4	7.8	7.8	7.4	7.3	7.5	7.2			
	5% DB	7.2	8.5	9.4	9.7	13.5	13.8	12.1	11.8	9.2	7.9	8.2	7.4			
	5% WB	5.9	7.3	7.2	7.2	8.4	8.5	7.4	7.6	6.5	6.4	7.4	6.7			
	MCDBR	6.5	7.3	8.3	8.7	11.0	11.8	11.0	9.6	7.2	7.1	7.6	6.4			
	MCWBR	6.1	6.9	7.1	6.8	7.3	7.8	7.3	6.8	6.0	6.5	7.9	6.6			
	MCWBR	6.1	6.9	7.1	6.8	7.3	7.8	7.3	6.8	6.0	6.5	7.9	6.6			
(40) Clear-Sky Solar Irradiance	taub	0.287	0.335	0.342	0.389	0.396	0.382	0.377	0.384	0.365	0.344	0.324	0.298			
	taud	2.367	2.257	2.290	2.192	2.242	2.386	2.454	2.420	2.397	2.320	2.188	2.197			
	Ebn at Noon	210	232	262	263	268	274	273	264	252	225	179	165			
	Edh at Noon	16	26	31	40	40	36	33	32	29	24	19	16			
(44) All-Sky Solar Radiation	RadAvg	160	338	769	1129	1389	1452	1276	1075	803	463	202	114			
	RadStd	19	37	109	78	139	145	148	98	66	28	19	12			

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	+2.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page