

KING COVE, AK, USA

WMO: 703059

Lat: 55.116N

Lon: 162.270W

Elev: 47

StdP: 100.76

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-11.1	-17.8	0.8	-11.6	-16.2	0.9	-10.4	23.1	-10.0	19.9	-5.4	7.1	280	0.874

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	16.7	13.2	15.1	12.4	13.9	11.8	13.9	15.8	13.0	14.2	12.4	13.5	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	9.4	14.2	12.4	9.0	13.6	11.8	8.7	13.1	39.0	15.8	36.9	14.2	35.1	13.5	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.0	15.0	12.8	DB	-13.9	19.7	2.4	2.7	-15.6	21.6	-17.0	23.1	-18.3	24.6	-20.1	26.6	(4)
			WB	-13.8	15.4	2.7	2.0	-15.8	16.8	-17.4	18.0	-18.9	19.1	-20.8	20.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-1.2	-0.1	-0.9	1.4	4.9	8.1	10.7	11.6	9.5	5.9	2.2	0.7	
	DBStd	5.43	4.54	3.85	4.20	2.92	2.37	1.74	1.80	1.83	2.02	2.65	3.36	3.70	
	HDD10.0	2145	348	282	337	258	159	61	12	5	32	129	236	288	
	HDD18.3	5077	606	516	595	508	417	307	237	208	266	386	486	546	
	CDD10.0	110	0	0	0	0	1	4	33	55	16	1	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	5.9	5.2	6.4	6.1	6.5	5.8	5.9	5.3	5.3	5.8	5.9	6.3	5.8	
Precipitation	PrecAvg	1082	85	78	76	70	68	68	64	93	117	121	125	115	
	PrecMax	2117	156	192	180	155	174	204	135	165	181	252	315	343	
	PrecMin	723	15	14	27	7	8	12	12	37	57	37	32	45	
	PrecStd	264	39	48	38	39	38	42	27	36	35	50	60	61	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	6.8	7.2	8.9	15.8	16.0	18.4	18.9	15.4	12.1	10.7	7.9	
		MCWB	4.5	4.6	4.6	5.3	9.5	11.4	13.5	15.3	12.2	9.9	8.5	6.7	
	2%	DB	5.7	5.7	5.8	7.2	11.3	13.7	16.3	17.1	14.0	11.1	8.9	7.0	
		MCWB	4.3	4.2	4.1	4.7	7.2	10.0	12.9	14.1	12.0	9.5	7.9	5.8	
	5%	DB	4.8	4.9	4.8	6.0	9.0	12.3	14.6	15.5	13.1	10.3	7.8	6.1	
		MCWB	3.5	3.6	3.2	4.2	6.3	9.2	12.1	13.1	11.3	8.8	6.6	4.8	
	10%	DB	3.9	4.1	3.9	5.1	7.9	11.1	13.3	14.1	12.4	9.5	6.9	5.0	
		MCWB	2.7	2.9	2.3	3.7	5.8	8.7	11.4	12.3	10.7	7.9	5.5	3.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	5.6	5.5	6.5	9.9	12.1	14.6	16.3	13.9	10.9	9.5	7.3
			MCDB	6.2	6.5	6.2	7.4	14.9	15.1	17.4	18.1	14.3	11.2	10.2	7.6
2%		WB	4.6	4.7	4.5	5.4	7.8	10.6	13.4	14.5	12.6	10.1	8.1	6.1	
		MCDB	5.4	5.3	5.5	6.5	10.3	12.8	15.4	16.5	13.3	10.8	8.7	6.9	
5%		WB	3.7	3.9	3.5	4.5	6.9	9.8	12.5	13.4	11.9	9.0	6.9	5.1	
		MCDB	4.5	4.5	4.4	5.8	8.4	11.7	14.1	14.8	12.7	9.9	7.8	6.0	
10%		WB	3.0	3.1	2.6	3.7	6.4	9.0	11.8	12.8	11.1	8.2	5.6	4.1	
		MCDB	3.7	3.7	3.6	4.9	7.6	10.6	13.1	13.8	12.1	9.1	6.8	5.0	
Mean Daily Temperature Range		5% DB	MDBR	4.7	4.5	5.3	4.6	4.9	4.7	4.3	4.3	4.1	4.0	4.2	4.0
			MCDBR	4.0	4.7	5.2	5.4	7.5	7.7	6.7	6.6	5.1	4.4	4.5	4.1
	MCWBR		3.3	4.1	4.0	4.0	4.7	4.7	4.1	4.2	3.6	3.5	4.1	3.7	
	5% WB	MCDBR	3.6	4.0	4.6	4.8	6.1	6.6	6.1	5.3	4.0	3.9	4.2	3.6	
		MCWBR	3.4	3.8	3.9	3.8	4.1	4.3	4.1	3.8	3.3	3.6	4.4	3.7	
Clear-Sky Solar Irradiance	taub	0.287	0.335	0.342	0.389	0.396	0.382	0.377	0.384	0.365	0.344	0.324	0.298		
	taud	2.367	2.257	2.290	2.192	2.242	2.386	2.454	2.420	2.397	2.320	2.188	2.197		
	Ebn at Noon	661	730	825	829	845	865	862	831	795	710	564	520		
	Edh at Noon	52	82	99	126	127	112	103	100	90	76	60	49		
All-Sky Solar Radiation	RadAvg	0.51	1.06	2.42	3.56	4.38	4.58	4.02	3.39	2.53	1.46	0.64	0.36		
	RadStd	0.06	0.12	0.34	0.24	0.44	0.46	0.47	0.31	0.21	0.09	0.06	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	+1.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page