

EGEGIK, AK, USA

WMO: 703334

Lat: 58.185N

Lon: 157.386W

Elev: 28

StdP: 100.99

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 25519

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.0	(c) -22.7	(d) -30.9	(e) 0.2	(f) -25.0	(g) -27.2	(h) 0.3	(i) -22.5	(j) 16.6	(k) 1.8	(l) 15.0	(m) 1.7	(n) 2.8	(o) 20	(p) 0.840

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.3	(c) 18.9	(d) 14.0	(e) 17.4	(f) 13.3	(g) 16.1	(h) 12.7	(i) 14.8	(j) 17.8	(k) 14.1	(l) 16.7	(m) 13.3	(n) 15.7	(o) 5.2	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	9.5	15.6	12.6	9.1	15.0	12.2	8.9	14.6	41.2	17.8	39.3	16.7	37.3	15.5	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.5	11.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-24.7	16.4	3.3	1.3	-27.1	17.4	-29.0	18.1	-30.8	18.8	-33.2	19.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-8.1	-4.2	-4.4	0.7	5.9	9.6	11.8	12.4	9.6	3.3	-2.0	-5.3		
	DBStd	8.69	8.37	6.77	6.55	3.93	3.10	2.45	2.21	1.92	2.50	4.43	6.22	7.55		
	HDD10.0	2941	561	399	446	279	132	36	8	2	36	207	359	475		
	HDD18.3	5794	819	632	704	529	387	263	204	185	263	464	609	733		
	CDD10.0	189	0	0	1	0	3	23	63	76	22	1	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	1	0	0	0	0	0	1	1	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.1	5.0	5.4	5.1	5.2	5.2	4.9	5.0	4.9	5.1	5.2	5.2	5.3		
(15) Precipitation	PrecAvg	826	62	53	47	44	48	55	77	83	108	89	79	80		
	PrecMax	1043	152	97	89	69	100	83	122	142	180	156	184	148		
	PrecMin	625	19	12	11	6	17	18	39	27	45	13	10	36		
	PrecStd	112	28	19	25	15	20	17	21	27	33	31	41	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	6.3	12.7	12.1	18.7	20.9	22.2	21.3	17.2	12.4	9.8	7.3		
		MCWB	3.6	3.9	4.9	6.6	11.4	13.8	15.3	15.8	13.3	9.6	8.5	5.8		
	2%	DB	3.8	4.7	7.4	9.0	14.3	17.7	18.7	18.7	15.2	11.2	8.0	6.0		
		MCWB	2.7	3.0	4.3	5.4	9.2	12.5	14.1	14.7	12.1	9.1	6.6	4.0		
	5%	DB	2.9	3.7	4.5	7.5	12.5	16.1	17.2	17.2	14.0	10.1	7.1	4.1		
		MCWB	1.9	2.2	2.6	4.5	8.1	11.5	13.6	13.7	11.3	8.4	5.6	2.8		
	10%	DB	2.3	2.7	2.9	6.2	11.0	13.9	15.9	15.9	12.9	8.9	6.0	3.0		
		MCWB	1.4	1.4	1.4	3.6	7.5	10.3	13.1	13.2	10.8	7.4	4.7	2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	4.5	6.0	7.3	11.9	14.4	15.7	16.3	14.4	10.5	8.5	6.0		
		MCDB	4.8	6.0	10.1	10.8	17.8	18.7	20.0	19.9	16.5	11.6	9.4	7.3		
	2%	WB	3.0	3.4	4.2	5.7	9.9	13.1	14.7	15.0	12.9	9.6	7.1	4.2		
		MCDB	3.8	4.6	6.7	8.6	14.1	17.3	17.9	17.8	14.5	10.9	7.9	5.7		
	5%	WB	2.2	2.4	2.8	4.8	8.6	11.9	14.0	14.2	12.0	8.4	5.7	3.2		
		MCDB	2.9	3.5	4.6	7.3	11.8	15.3	16.7	16.6	13.3	9.8	6.9	4.4		
	10%	WB	1.1	1.6	1.7	3.9	7.7	10.8	13.2	13.4	11.3	7.7	4.6	2.3		
		MCDB	2.0	2.7	3.4	6.1	10.3	13.4	15.6	15.5	12.7	8.8	6.0	3.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	5.8	6.7	6.8	7.0	7.0	5.5	5.3	5.6	5.5	5.3	6.0		
		MCDBR	4.6	5.0	6.9	8.9	10.4	10.8	8.7	7.8	6.7	5.7	4.7	4.4		
	5% WB	MCWBR	4.2	4.1	5.2	6.1	6.1	6.2	5.2	4.7	4.5	4.3	4.0	3.9		
		MCWBR	4.5	5.1	6.6	8.3	9.3	9.7	7.8	7.0	5.9	5.2	4.6	4.5		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.307	0.317	0.361	0.382	0.369	0.367	0.366	0.340	0.311	0.301	0.272		
		taud	2.173	2.264	2.276	2.246	2.288	2.405	2.458	2.459	2.496	2.436	2.136	2.053		
	Ebn at Noon		560	722	828	843	850	868	862	836	806	722	497	408		
		Edh at Noon	49	73	94	115	119	107	100	93	77	61	51	40		
(44) All-Sky Solar Radiation	RadAvg		0.44	1.03	2.63	3.91	4.78	5.13	4.25	3.52	2.50	1.36	0.58	0.27		
	RadStd		0.06	0.17	0.41	0.43	0.48	0.50	0.43	0.39	0.29	0.14	0.07	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page