

SELDOVIA, AK, USA

WMO: 703621

Lat: 59.443N

Lon: 151.702W

Elev: 9

StdP: 101.22

Time Zone: -9.00 (NAK)

Period: 98-19

WBAN: 25516

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-12.6	-19.9	0.6	-10.8	-17.8	0.8	-10.1	9.0	-0.8	8.1	-2.6	1.7	180	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	19.7	14.6	17.9	13.6	16.9	12.9	15.1	18.8	14.2	17.3	13.4	16.1	2.8	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	9.3	16.3	12.5	9.0	15.5	12.1	8.8	14.9	41.8	18.9	39.6	17.4	37.5	16.1	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.4	5.4	-16.2	22.6	2.7	2.2	-18.1	24.1	-19.7	25.4	-21.2	26.7	-23.1	28.3		
(5)			-16.8	16.5	2.7	1.3	-18.8	17.4	-20.3	18.2	-21.9	18.9	-23.8	19.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-3.0	-1.7	-1.6	2.5	6.8	10.4	12.9	12.4	9.3	4.7	-0.3	-1.9		
	DBStd	6.68	5.14	4.45	4.01	2.56	2.29	2.01	1.91	1.89	2.23	3.25	4.08	4.59		
	HDD10.0	2322	403	329	359	224	102	18	1	2	38	167	309	369		
	HDD18.3	5146	662	562	617	473	358	239	168	183	272	424	559	628		
	CDD10.0	217	0	0	0	0	2	29	91	78	16	1	0	0		
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0		
	CDH23.3	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	1.7	1.5	1.6	1.8	1.6	1.8	1.8	1.8	1.5	1.5	1.5	1.7	1.7		
(15) Precipitation	PrecAvg	629	54	47	32	28	21	28	45	67	95	71	67	75		
	PrecMax	871	181	156	71	97	55	50	92	114	169	207	197	126		
	PrecMin	382	1	7	3	5	7	7	14	7	31	30	8	10		
	PrecStd	99	37	32	20	21	11	12	20	26	36	35	47	33		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	7.0	7.8	11.8	16.9	21.0	22.4	21.6	16.4	14.0	9.4	10.2		
		MCWB	5.2	4.7	5.3	7.4	10.2	14.5	15.9	16.1	12.2	10.7	7.2	6.8		
	2%	DB	5.9	5.2	6.1	9.3	14.3	18.0	20.1	19.0	14.9	11.3	7.7	6.7		
		MCWB	4.3	3.6	4.1	5.6	8.9	12.8	15.0	14.4	11.6	9.0	6.5	4.9		
	5%	DB	4.3	4.0	4.7	7.9	12.5	16.4	18.4	17.5	13.8	10.2	6.7	5.2		
		MCWB	3.3	2.7	3.0	4.9	8.1	11.7	14.1	13.5	11.1	8.1	5.6	3.7		
	10%	DB	2.9	3.0	3.5	7.0	11.2	14.8	17.2	16.3	12.8	9.2	5.4	3.8		
		MCWB	2.3	1.9	1.9	4.4	7.6	10.9	13.3	12.9	10.7	7.3	4.5	2.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	5.1	5.8	7.5	10.9	15.0	16.6	16.5	13.4	11.2	8.0	7.0		
		MCDB	7.5	6.5	7.5	10.6	15.2	19.7	21.8	21.1	15.2	12.2	8.7	9.3		
	2%	WB	4.5	4.0	4.4	6.2	9.6	13.4	15.2	15.0	12.3	9.6	6.9	5.3		
		MCDB	5.6	5.2	5.9	8.6	13.3	17.3	19.3	18.2	13.8	11.0	7.6	6.5		
	5%	WB	3.4	3.0	3.3	5.3	8.8	12.2	14.4	14.1	11.7	8.6	5.8	4.0		
		MCDB	4.3	3.8	4.4	7.5	11.9	15.6	17.9	16.8	13.1	9.9	6.7	5.1		
	10%	WB	2.4	2.2	2.3	4.6	7.9	11.3	13.6	13.4	11.1	7.8	4.5	3.0		
		MCDB	3.0	2.9	3.2	6.7	10.6	14.2	16.6	15.6	12.5	8.9	5.4	3.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	5.9	6.3	7.3	7.1	6.5	6.6	6.3	5.8	4.7	4.7		
		MCDBR	5.3	5.1	5.9	7.9	10.3	10.9	9.9	8.9	7.4	5.9	5.5	6.0		
		MCWBR	4.0	3.9	4.4	5.2	6.0	6.3	5.7	5.4	5.0	4.3	4.4	4.5		
		MCDBR	5.3	4.8	5.6	7.3	9.0	9.3	8.9	7.8	6.1	5.2	5.1	5.6		
	5% WB	MCWBR	4.2	3.9	4.4	5.0	5.4	5.7	5.3	5.0	4.6	4.2	4.3	4.4		
(40) Clear-Sky Solar Irradiance	taub		0.261	0.307	0.312	0.357	0.374	0.362	0.367	0.360	0.337	0.319	0.280	0.267		
	taud		2.237	2.301	2.383	2.299	2.316	2.439	2.471	2.489	2.518	2.400	2.180	2.026		
	Ebn at Noon		552	705	831	844	853	872	858	838	800	686	494	349		
	Edh at Noon		41	67	83	108	114	103	98	89	74	61	43	35		
(44) All-Sky Solar Radiation	RadAvg		0.35	0.93	2.24	3.60	4.87	5.35	4.75	3.78	2.46	1.21	0.49	0.21		
	RadStd		0.04	0.15	0.31	0.48	0.45	0.40	0.40	0.47	0.37	0.13	0.09	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.89	+1.91	N/A	N/A	+0.84	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.84	+2.34	+2.18	N/A	N/A	N/A	-225	-287	N/A	N/A

Nomenclature: See separate page