

HUSLIA, AK, USA

WMO: 703655

Lat: 65.698N

Lon: 156.351W

Elev: 55

StdP: 100.67

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 26552

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-43.0	-39.6	-34.1	0.2	-29.6	-33.6	0.2	-28.9	10.2	-11.9	9.2	-11.9	0.2	350	0.723

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	25.4	15.3	23.2	14.1	22.0	13.5	16.3	23.2	15.2	21.6	14.2	19.8	3.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.1	9.4	17.6	12.4	9.0	17.3	11.4	8.4	16.5	45.4	23.2	42.3	21.7	39.9	19.9	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.9	7.0	-42.2	28.0	5.8	1.7	-46.3	29.2	-49.7	30.2	-52.9	31.2	-57.1	32.5		
			-34.1	17.3	1.8	0.9	-35.4	18.0	-36.4	18.6	-37.4	19.1	-38.7	19.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.5	-19.1	-14.4	-13.5	-3.5	7.1	14.1	15.2	11.7	6.3	-4.1	-13.8	-16.9
	DBStd	14.22	11.79	8.49	7.67	6.95	5.72	3.61	3.31	3.27	4.07	6.13	7.70	9.06
	HDD10.0	4976	904	684	728	407	117	8	3	18	119	437	715	834
	HDD18.3	7627	1162	918	986	655	348	133	107	206	360	695	965	1093
	CDD10.0	406	0	0	0	2	28	131	164	72	9	0	0	0
	CDD18.3	16	0	0	0	0	1	6	9	1	0	0	0	0
	CDH23.3	184	0	0	0	0	9	64	100	10	0	0	0	0
	CDH26.7	29	0	0	0	0	1	9	19	1	0	0	0	0
Wind	WSAvg	2.7	2.8	3.0	3.1	3.1	2.7	2.4	2.4	2.3	2.7	2.5	2.6	2.7
Precipitation	PrecAvg	425	27	28	21	15	19	36	57	67	50	41	33	31
	PrecMax	547	63	76	63	54	34	98	100	156	107	114	85	70
	PrecMin	320	3	2	2	2	5	12	33	26	23	14	2	9
	PrecStd	68	16	18	13	11	9	16	17	25	24	21	24	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	2.5	3.9	17.4	24.1	27.5	28.9	24.8	18.0	9.1	2.3	1.2
		MCWB	0.5	0.5	1.0	8.5	12.2	15.5	17.5	15.9	11.1	6.3	0.7	0.4
	2%	DB	0.0	1.2	2.0	11.3	21.3	25.0	26.1	22.1	16.3	6.4	1.1	-0.7
		MCWB	-0.9	-0.2	-0.1	5.2	11.5	14.1	16.0	14.6	10.1	4.3	-0.3	-1.2
	5%	DB	-2.2	-0.9	-0.5	7.9	18.0	22.9	23.8	19.0	14.0	4.9	-0.9	-2.8
		MCWB	-3.3	-1.9	-2.0	3.2	9.9	13.4	15.0	13.1	9.2	3.1	-1.7	-3.8
	10%	DB	-4.1	-2.7	-2.5	6.0	16.2	21.4	22.2	17.6	12.4	3.2	-2.7	-5.6
		MCWB	-5.4	-4.0	-4.4	1.9	8.7	12.7	14.3	12.3	8.8	1.4	-3.9	-6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	0.9	1.8	8.5	13.1	16.8	18.3	16.6	12.1	7.6	0.8	0.4
		MCDB	1.8	1.9	3.1	17.5	23.8	25.1	26.7	22.4	16.0	8.3	1.5	0.9
	2%	WB	-0.7	-0.1	-0.2	5.4	11.8	15.2	16.9	15.1	10.9	4.9	-0.3	-1.1
		MCDB	0.2	1.0	1.4	11.0	20.1	23.3	24.1	19.8	14.7	6.5	0.5	-0.6
	5%	WB	-2.6	-1.8	-2.1	3.5	10.5	14.2	15.7	14.1	10.0	3.4	-1.6	-3.5
		MCDB	-2.0	-0.8	-0.6	7.6	17.4	21.1	22.4	18.5	13.7	4.8	-0.8	-2.7
	10%	WB	-4.6	-3.9	-4.2	2.1	9.3	13.3	14.8	13.0	9.1	1.8	-3.9	-5.9
		MCDB	-3.3	-2.6	-2.5	5.6	15.2	20.2	20.8	16.7	12.4	3.3	-2.6	-5.2
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.7	9.5	9.8	10.7	9.8	8.9	8.2	7.2	5.7	6.2	6.3
		MCDBR	6.1	6.8	8.9	10.5	13.7	12.8	12.7	11.2	10.3	5.5	5.1	5.6
		MCWBR	5.6	6.0	7.1	6.7	6.7	5.4	5.4	5.5	5.9	4.1	4.7	5.4
	5% WB	MCDBR	6.6	6.8	7.9	9.9	12.6	11.3	11.4	9.3	8.9	5.1	5.1	5.6
		MCWBR	6.1	6.1	6.5	6.4	6.2	5.2	5.0	4.9	5.4	3.9	4.7	5.4
Clear-Sky Solar Irradiance	taub	0.168	0.252	0.259	0.342	0.339	0.359	0.362	0.358	0.306	0.273	N/A	0.171	
	taud	1.931	2.140	2.265	2.094	2.388	2.389	2.415	2.440	2.543	2.354	N/A	1.937	
	Ebn at Noon	325	626	827	809	865	851	836	802	781	611	N/A	64	
	Edh at Noon	19	54	77	120	100	103	97	86	62	44	N/A	5	
All-Sky Solar Radiation	RadAvg	0.13	0.77	2.61	4.75	5.44	5.72	4.67	3.49	2.16	0.82	0.21	0.02	
	RadStd	0.01	0.07	0.16	0.27	0.55	0.48	0.36	0.40	0.26	0.12	0.03	0.00	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page