

KLAWOCK, AK, USA

WMO: 703894

Lat: 55.580N

Lon: 133.075W

Elev: 4

StdP: 101.28

Time Zone: -9.00 (NAK)

Period: 97-19

WBAN: 25367

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.1	-6.2	-16.2	0.9	-4.8	-13.1	1.2	-4.6	8.7	-0.3	7.8	0.3	3.1	30	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	21.5	15.1	19.6	14.6	18.0	13.9	16.3	19.8	15.5	18.3	14.8	17.2	3.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	10.6	16.7	14.2	10.1	16.2	13.6	9.7	15.7	45.3	19.7	43.3	18.3	41.2	17.1	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.0	5.2	DB	-10.7	26.3	2.1	3.5	-12.2	28.8	-13.4	30.9	-14.6	32.9	-16.1	35.5	(4)
(5)			WB	-11.5	17.7	2.1	1.2	-13.1	18.6	-14.3	19.3	-15.5	20.0	-17.0	20.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	2.5	2.3	3.3	6.0	9.3	12.1	13.9	14.3	12.0	8.0	4.2	2.4	(6)	
(7)		DBStd	5.26	3.99	3.26	3.13	2.32	2.50	2.07	1.69	1.61	1.90	2.42	3.28	3.60	(7)	
(8)		HDD10.0	1308	233	217	207	123	42	3	0	0	4	68	174	237	(8)	
(9)		HDD18.3	3935	491	450	465	371	278	188	138	126	190	319	424	494	(9)	
(10)		CDD10.0	417	1	0	1	2	22	66	120	133	64	7	1	1	(10)	
(11)		CDD18.3	1	0	0	0	0	0	1	0	1	0	0	0	0	(11)	
(12)		CDH23.3	34	0	0	0	1	4	18	2	8	1	0	0	0	(12)	
(13)		CDH26.7	6	0	0	0	0	0	6	0	1	0	0	0	0	(13)	
(14)	Wind	WSAvg	2.0	2.4	2.1	2.2	2.0	1.9	1.8	1.7	1.6	1.7	1.9	2.2	2.3	(14)	
(15)	Precipitation	PrecAvg	2661	293	218	213	163	117	96	121	171	271	341	328	329	(15)	
(16)		PrecMax	3625	544	451	401	249	293	179	225	372	489	531	587	716	(16)	
(17)		PrecMin	1912	89	78	76	16	8	35	11	43	100	149	151	151	(17)	
(18)		PrecStd	433	91	100	84	58	66	36	52	77	93	86	105	137	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	11.3	15.0	19.0	23.0	25.8	22.4	24.2	21.0	15.1	12.3	12.7	(19)	
(20)			MCWB	7.2	7.1	8.6	9.8	12.0	15.7	16.5	17.2	14.6	11.4	9.5	8.5	(20)	
(21)		2%	DB	9.4	9.3	10.8	14.4	18.1	19.9	20.1	21.1	18.3	13.5	10.8	9.6	(21)	
(22)			MCWB	7.7	6.3	6.6	8.6	11.5	14.2	15.5	15.9	13.6	10.9	9.3	7.6	(22)	
(23)		5%	DB	8.2	7.9	9.0	11.9	15.9	17.7	18.4	19.3	16.7	12.5	9.8	8.3	(23)	
(24)			MCWB	6.9	5.7	6.1	7.6	10.8	13.2	14.7	15.2	13.0	10.4	8.3	6.9	(24)	
(25)		10%	DB	7.3	6.8	7.7	10.3	14.0	16.0	17.2	17.7	15.3	11.5	8.7	7.2	(25)	
(26)			MCWB	6.1	5.1	5.4	6.8	10.0	12.2	14.1	14.6	12.9	9.9	7.3	6.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	8.7	9.3	11.5	13.5	16.7	17.2	17.7	16.0	13.0	10.6	9.5	(27)	
(28)			MCD B	10.6	9.8	12.7	17.0	18.1	23.5	21.4	22.8	19.1	13.8	11.2	11.2	(28)	
(29)		2%	WB	8.0	6.9	7.8	9.2	12.3	14.8	16.0	16.5	14.7	11.9	9.6	8.1	(29)	
(30)			MCD B	8.7	8.3	10.0	12.9	16.4	19.0	19.1	19.8	16.8	12.7	10.5	8.9	(30)	
(31)		5%	WB	7.1	6.1	6.7	8.2	11.3	13.7	15.2	15.7	14.0	10.9	8.5	7.2	(31)	
(32)			MCD B	7.9	7.5	8.5	11.2	14.8	16.8	17.6	18.4	15.7	11.8	9.6	8.0	(32)	
(33)		10%	WB	6.4	5.2	5.8	7.5	10.5	12.8	14.5	15.0	13.3	10.2	7.6	6.0	(33)	
(34)			MCD B	7.3	6.7	7.5	9.9	13.5	15.2	16.6	17.3	14.8	11.2	8.7	7.1	(34)	
(35)	Mean Daily Temperature Range			MDBR	4.2	5.6	6.5	7.7	7.6	6.9	6.0	6.5	6.4	5.7	4.5	4.2	(35)
(36)		5% DB	MCD BR	4.6	6.3	8.7	11.6	11.9	11.0	9.0	10.5	9.6	7.0	4.5	4.9	(36)	
(37)			MCWBR	3.7	4.4	5.5	6.8	6.5	5.9	5.0	6.0	5.6	4.8	3.8	3.9	(37)	
(38)			MCD BR	4.3	5.3	7.4	9.5	9.7	9.2	7.6	8.4	6.8	4.9	4.3	4.7	(38)	
(39)		5% WB	MCWBR	3.7	4.1	5.1	6.0	5.8	5.2	4.5	5.2	4.6	3.9	3.9	4.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.305	0.313	0.344	0.362	0.366	0.367	0.379	0.365	0.366	0.340	0.315	0.301	(40)	
(41)		taud		2.340	2.473	2.386	2.373	2.416	2.448	2.452	2.517	2.460	2.435	2.306	2.242	(41)	
(42)		Ebn at Noon		618	777	824	860	876	878	858	852	794	722	587	510	(42)	
(43)		Edh at Noon		52	66	90	105	107	105	103	91	84	68	53	45	(43)	
(44)	All-Sky Solar Radiation	RadAvg		0.46	1.22	2.23	3.65	4.61	4.80	4.27	3.70	2.41	1.31	0.60	0.35	(44)	
(45)		RadStd		0.06	0.23	0.32	0.25	0.49	0.43	0.56	0.39	0.34	0.18	0.08	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	+0.58	+0.60	N/A	-166	+86	N/A	
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64	N/A	

Nomenclature: See separate page