

SHEMYA ISLAND, AK, USA

WMO: 704140

Lat: 52.717N

Lon: 174.100E

Elev: 122

StdP: 14.63

Time Zone: -10.00 (NAH)

Period: 94-19

WBAN: 45715

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.1	23.2	4.9	7.1	28.7	9.1	8.8	27.0	53.5	36.1	49.7	36.0	15.8	300	1.008

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	55.5	51.6	54.2	51.1	53.0	50.7	53.2	54.0	52.3	53.0	51.5	52.1	16.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.5	58.9	53.1	51.9	57.5	52.6	51.0	55.6	51.8	22.1	54.2	21.6	52.9	21.2	52.3	58.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
45.8	40.3	35.7	17.8	57.7	1.8	2.5	16.5	59.4	15.5	60.9	14.4	62.3	13.1	64.1		
			15.9	55.4	2.1	1.8	14.3	56.7	13.1	57.8	11.9	58.8	10.3	60.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.6	31.4	31.8	32.5	35.3	39.1	43.0	48.0	50.7	49.5	43.0	37.5	32.7
	DBStd	7.53	4.27	3.59	3.77	2.33	1.91	1.90	2.66	2.06	2.32	3.42	3.28	4.30
	HDD50	3877	577	510	543	442	338	211	75	16	36	217	374	538
	HDD65	9281	1042	930	1008	892	803	661	527	444	466	681	824	1003
	CDD50	70	0	0	0	0	0	0	13	37	20	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	18.2	21.0	21.7	20.3	19.0	16.1	14.6	12.3	14.2	17.1	19.5	21.5	21.3
Precipitation	PrecAvg	31.7	2.4	1.9	1.9	1.8	1.7	1.7	2.7	3.8	3.0	3.8	3.9	3.0
	PrecMax	42.1	5.6	3.4	3.5	4.0	3.0	3.1	8.7	9.4	5.0	8.6	8.0	6.0
	PrecMin	17.3	1.2	0.7	0.4	0.4	0.7	0.2	0.7	0.7	1.7	1.9	1.0	1.0
	PrecStd	5.7	1.1	0.7	0.8	0.9	0.6	0.8	1.5	2.2	0.9	1.5	1.7	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.4	40.0	41.1	41.6	45.4	49.5	61.2	57.4	55.9	52.0	46.7	43.5
		MCWB	37.9	39.2	39.1	38.1	41.2	45.3	49.3	53.4	51.7	49.4	44.9	42.3
	2%	DB	39.2	38.4	39.7	40.2	43.7	47.7	56.4	55.4	54.4	50.2	44.7	41.3
		MCWB	37.3	37.2	37.6	37.4	40.2	44.6	48.1	52.3	51.0	47.7	42.6	40.3
	5%	DB	38.4	37.4	38.8	39.3	42.8	46.5	52.7	54.3	53.5	49.0	43.4	39.7
		MCWB	36.4	35.8	36.8	36.9	39.7	44.1	49.2	51.8	50.6	46.6	41.5	38.1
	10%	DB	37.3	36.5	37.7	38.4	41.8	45.5	51.2	53.3	52.5	48.0	42.4	38.4
		MCWB	35.4	34.7	35.7	36.2	39.4	43.7	49.1	51.3	50.1	45.6	40.4	36.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.5	39.5	40.2	39.6	43.1	47.7	52.7	55.0	53.6	50.5	46.1	42.4
		MCDB	39.8	39.5	40.5	40.0	44.1	48.6	54.2	56.2	54.2	50.8	46.4	42.8
	2%	WB	38.1	37.8	38.5	38.5	41.5	46.2	51.4	53.6	52.5	48.7	43.7	40.7
		MCDB	38.8	38.0	39.3	39.2	42.3	46.8	52.2	54.4	53.2	49.5	44.2	41.4
	5%	WB	37.0	36.6	37.4	37.9	40.8	45.4	50.5	52.9	51.7	47.6	42.3	38.6
		MCDB	38.0	37.1	38.5	38.7	41.6	45.9	51.3	53.6	52.5	48.7	43.0	39.5
	10%	WB	35.8	35.2	36.2	37.1	40.1	44.4	49.6	52.1	51.0	46.2	41.2	36.9
		MCDB	37.1	36.1	37.5	38.1	41.0	45.1	50.3	52.7	51.9	47.6	42.1	38.1
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.1	5.9	5.4	5.0	4.4	5.3	4.4	5.1	6.0	5.8	5.5
		MCDBR	4.5	5.4	5.7	6.0	5.9	5.4	8.8	5.6	5.8	6.3	6.6	5.8
		MCWBR	5.1	5.9	5.9	5.2	4.7	5.0	6.4	5.5	5.3	5.7	7.3	6.6
	5% WB	MCDWR	4.3	5.3	5.4	5.3	4.9	4.7	6.5	5.4	4.9	5.2	6.6	5.4
		MCWBR	5.0	6.3	6.1	5.3	4.4	5.1	6.0	5.5	5.2	5.7	7.7	6.5
Clear-Sky Solar Irradiance	taub	0.352	0.370	0.407	0.438	0.446	0.424	0.427	0.411	0.376	0.379	0.374	0.348	
	taud	2.129	2.144	2.091	2.044	2.081	2.235	2.277	2.326	2.377	2.195	2.086	2.102	
	Ebn at Noon	186	224	241	250	255	263	260	258	253	218	172	160	
	Edh at Noon	24	31	40	48	48	42	39	36	30	29	24	21	
All-Sky Solar Radiation	RadAvg	213	416	776	1079	1189	1140	1133	1017	874	581	259	162	
	RadStd	19	33	72	110	95	96	64	97	80	37	25	16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page