

CADOGAN AGCM, AB, Canada

WMO: 710120

Lat: 52.3342N

Lon: 110.5100W

Elev: 690

StdP: 93.31

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-30.8	-27.9	-34.2	0.2	-30.6	-31.1	0.2	-27.7	12.3	-0.5	11.0	-0.9	3.0	260	0.696

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	29.6	17.2	27.6	16.6	25.8	15.8	19.1	26.0	18.1	24.8	17.1	23.5	4.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	13.0	21.8	15.7	12.1	20.3	14.7	11.3	19.5	57.3	25.9	53.8	25.0	50.6	23.4	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.9	8.7	-35.0	33.2	2.5	2.0	-36.8	34.6	-38.3	35.8	-39.7	36.9	-41.4	38.4
			-35.1	21.3	2.5	1.5	-36.9	22.3	-38.4	23.2	-39.8	24.1	-41.5	25.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-10.8	-11.6	-4.5	3.5	11.0	15.1	17.7	16.9	12.0	4.5	-4.3	-11.8	(6)
	DBStd	12.48	8.61	8.09	7.78	5.27	4.42	3.27	2.78	3.24	4.68	5.08	7.12	8.03	(7)
	HDD10.0	3262	646	604	450	201	41	3	0	1	32	180	431	675	(8)
	HDD18.3	5573	904	837	708	443	228	104	45	66	196	428	680	933	(9)
	CDD10.0	792	0	0	0	7	73	157	239	213	91	11	1	0	(10)
	CDD18.3	62	0	0	0	0	2	8	26	21	5	0	0	0	(11)
	CDH23.3	1068	0	0	0	3	75	142	363	336	144	4	0	0	(12)
	CDH26.7	267	0	0	0	0	10	27	97	86	47	0	0	0	(13)
(14) Wind	WSAvg	4.2	4.5	4.3	4.5	4.9	4.4	4.1	3.7	3.5	3.9	4.3	4.3	4.3	(14)
(15) Precipitation	PrecAvg	385	19	11	15	25	40	73	67	50	29	18	14	13	(15)
	PrecMax	532	43	23	37	75	82	135	135	119	80	41	45	27	(16)
	PrecMin	240	4	3	0	5	11	13	30	6	0	2	1	3	(17)
	PrecStd	86	12	6	10	17	22	30	26	30	25	10	11	7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	6.7	15.1	22.8	28.1	29.9	31.8	31.5	31.2	23.2	14.4	6.8	(19)
		MCWB	3.0	3.2	7.6	10.1	13.6	16.5	18.7	17.6	15.8	12.7	7.1	3.0	(20)
	2%	DB	4.7	3.9	11.0	19.3	25.5	26.7	29.4	28.9	27.4	18.1	9.7	4.0	(21)
		MCWB	2.0	1.5	4.9	8.8	12.8	15.7	18.6	17.1	15.0	10.3	4.9	1.3	(22)
	5%	DB	3.2	2.0	7.9	15.8	23.1	24.8	27.1	27.0	24.2	15.2	6.6	1.3	(23)
		MCWB	0.9	0.0	3.8	6.9	12.0	15.2	17.6	16.9	14.0	8.6	3.0	-0.8	(24)
	10%	DB	1.2	0.1	4.9	12.9	20.5	22.8	25.1	25.0	21.1	12.5	4.3	-1.1	(25)
		MCWB	-0.5	-1.4	1.9	5.6	10.8	14.3	16.8	16.2	12.6	7.1	1.6	-2.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	3.9	8.1	10.7	15.0	18.7	21.4	20.2	17.0	13.6	7.9	3.5	(27)
		MCDB	6.5	6.6	15.2	21.7	25.0	26.0	28.3	27.2	26.8	22.0	13.3	6.2	(28)
	2%	WB	2.3	1.6	5.6	8.9	13.7	17.3	19.5	18.8	15.6	11.2	5.4	1.3	(29)
		MCDB	4.6	3.6	10.1	18.6	23.0	24.5	26.1	26.3	25.7	16.4	9.3	3.9	(30)
	5%	WB	1.0	0.2	3.9	7.4	12.6	16.1	18.5	17.7	14.3	9.2	3.4	-0.8	(31)
		MCDB	3.1	1.8	7.5	14.5	21.3	22.5	24.8	24.6	22.6	14.3	5.9	1.0	(32)
	10%	WB	-0.6	-1.5	2.1	6.1	11.5	15.1	17.5	16.8	13.1	7.5	1.9	-2.4	(33)
		MCDB	1.2	0.1	4.9	12.3	19.4	21.1	23.6	23.1	20.6	12.1	4.0	-1.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.9	10.0	11.8	13.6	12.2	12.9	13.1	13.5	11.3	9.0	8.7	(35)
		MCDBR	10.0	11.2	13.4	17.5	17.3	15.5	16.4	17.2	19.0	16.0	11.9	10.6	(36)
	5% WB	MCWBR	7.9	9.0	8.4	8.6	7.5	6.6	7.2	7.2	8.3	8.8	8.0	8.4	(37)
		MCWBR	10.2	11.1	12.9	16.1	15.6	13.3	14.5	14.7	17.4	15.1	10.9	10.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.251	0.293	0.290	0.337	0.362	0.373	0.365	0.378	0.321	0.284	0.259	0.241	(40)
		taud	2.347	2.256	2.436	2.343	2.322	2.331	2.394	2.327	2.458	2.539	2.461	2.355	(41)
	Ebn at Noon		771	819	914	899	889	879	881	846	866	842	764	721	(42)
		Edh at Noon	58	86	89	111	119	120	110	112	87	65	52	48	(43)
(44) All-Sky Solar Radiation	RadAvg		1.11	2.17	3.61	4.77	5.79	5.98	6.35	5.16	3.65	2.19	1.12	0.84	(44)
	RadStd		0.10	0.17	0.27	0.45	0.39	0.41	0.30	0.42	0.37	0.29	0.11	0.08	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page