

CRAIGMYLE AGCM, AB, Canada

WMO: 710130

Lat: 51.775N

Lon: 112.252W

Elev: 845

StdP: 91.58

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-30.5	-27.6	-33.5	0.2	-30.4	-30.7	0.2	-27.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	29.6	16.5	27.6	16.3	25.6	15.5	18.6	25.4	17.6	24.7	16.7	23.6	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	13.0	21.2	15.2	11.9	20.1	14.1	11.1	19.2	56.5	25.3	52.9	24.9	50.0	23.8	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-34.9	32.9	2.8	2.4	-36.9	34.6	-38.5	36.1	-40.1	37.4	-42.1	39.2		
(5)			-35.0	21.2	2.8	1.4	-37.0	22.2	-38.6	23.1	-40.2	23.8	-42.2	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-9.9	-11.0	-4.2	3.3	10.4	14.3	17.0	16.3	11.5	4.4	-4.0	-11.0		
	DBStd	11.98	8.31	8.01	7.94	5.29	4.40	3.15	2.89	3.31	4.71	5.08	7.29	7.89		
	HDD10.0	3199	616	589	441	207	50	4	0	1	37	183	420	652		
	HDD18.3	5579	874	822	699	452	248	126	59	79	208	432	669	910		
	CDD10.0	709	0	0	0	6	62	133	218	198	82	10	1	0		
	CDD18.3	47	0	0	0	0	1	5	19	17	4	0	0	0		
	CDH23.3	1017	0	0	0	4	54	98	380	347	129	4	0	0		
	CDH26.7	267	0	0	0	0	6	17	108	102	33	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	384	14	10	16	26	49	77	65	54	32	16	14	12		
	PrecMax	490	34	24	54	60	93	152	151	108	82	35	48	29		
	PrecMin	229	1	1	3	3	6	33	24	3	5	5	2	1		
	PrecStd	65	8	6	10	14	24	30	30	28	19	9	11	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	6.7	14.9	22.2	27.4	28.8	32.3	32.4	30.2	23.0	15.6	7.8		
		MCWB	3.4	2.9	7.8	10.2	13.4	16.3	17.8	16.6	15.0	11.4	8.3	4.0		
	2%	DB	4.8	3.7	11.6	19.0	24.8	25.9	29.6	29.3	27.0	18.6	11.0	4.4		
		MCWB	2.2	1.0	5.5	8.9	12.4	15.4	17.5	16.5	14.7	10.0	5.7	1.6		
	5%	DB	3.4	1.9	8.5	15.7	22.4	23.9	27.3	27.2	24.2	15.7	7.6	2.1		
		MCWB	1.3	0.2	3.8	6.9	11.7	14.8	17.2	16.3	13.7	8.6	3.4	-0.2		
	10%	DB	1.4	0.0	5.4	12.6	19.7	22.0	25.2	24.9	21.1	12.8	5.0	-0.3		
		MCWB	-0.4	-1.3	2.1	5.5	10.5	13.9	16.5	15.8	12.6	7.0	1.9	-2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.5	8.2	11.0	14.5	18.5	21.4	19.7	16.6	12.8	8.4	4.4		
		MCDB	6.7	6.7	14.5	20.9	24.6	25.2	27.8	25.4	26.4	21.0	14.9	7.5		
	2%	WB	2.3	1.3	5.9	9.0	13.3	16.8	19.2	18.3	15.3	10.8	5.9	1.6		
		MCDB	4.6	3.3	10.7	18.2	22.4	23.8	26.0	25.4	24.6	17.2	10.6	4.2		
	5%	WB	1.3	0.1	4.1	7.4	12.2	15.7	18.0	17.3	14.0	9.0	4.0	-0.1		
		MCDB	3.4	1.9	8.3	14.4	20.5	21.8	24.9	24.8	21.8	14.9	7.1	1.9		
	10%	WB	-0.4	-1.3	2.2	5.9	11.2	14.6	17.1	16.4	12.9	7.5	2.2	-2.0		
		MCDB	1.3	0.0	5.1	11.9	18.6	20.4	23.8	23.2	21.0	12.4	4.4	-0.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.2	10.7	12.3	13.4	12.5	13.8	14.0	13.9	12.4	10.1	9.5		
		MCDBR	10.3	10.6	14.2	18.0	17.4	16.0	17.9	18.5	19.4	16.7	13.6	11.1		
		MCWBR	8.1	8.6	8.5	9.3	7.8	7.3	7.8	7.8	8.6	9.1	8.7	8.6		
		MCDBR	10.1	10.4	13.7	16.8	15.2	13.9	15.4	16.0	17.6	15.6	12.6	11.0		
	5% WB	MCWBR	8.1	8.7	8.7	8.9	7.2	7.0	7.6	7.6	8.2	8.8	8.5	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.268	0.281	0.283	0.333	0.361	0.359	0.354	0.369	0.319	0.284	0.255	0.246		
	taud		2.313	2.361	2.466	2.348	2.316	2.365	2.414	2.349	2.458	2.537	2.483	2.357		
	Ebn at Noon		750	851	926	905	891	894	893	858	871	848	784	726		
	Edh at Noon		62	79	87	111	120	116	109	110	87	66	52	50		
(44) All-Sky Solar Radiation	RadAvg		1.11	2.15	3.53	4.76	5.76	6.11	6.50	5.27	3.72	2.24	1.18	0.85		
	RadStd		0.09	0.18	0.28	0.40	0.38	0.38	0.32	0.38	0.38	0.27	0.10	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (78 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page