

DEAD MEN VALLEY, NT, Canada

WMO: 710210

Lat: 61.260N

Lon: 124.470W

Elev: 928

StdP: 14.21

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.0	-34.1	-47.8	0.3	-39.7	-41.3	0.5	-33.8	19.5	9.9	17.9	8.4	0.6	260	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.6	83.7	60.9	80.1	59.5	76.7	58.3	63.6	77.6	61.8	75.6	60.2	72.7	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.7	76.4	65.8	57.0	71.6	64.2	55.3	67.3	63.0	29.4	77.8	28.1	75.6	26.9	72.9	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.3	11.6	-45.9	90.1	4.8	2.9	-49.3	92.2	-52.1	93.9	-54.7	95.5	-58.2	97.6
			-45.6	67.2	4.2	2.7	-48.7	69.2	-51.1	70.7	-53.5	72.3	-56.6	74.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.2	-5.4	0.3	10.8	32.9	48.5	57.8	62.0	57.9	47.4	32.3	7.9	-3.7	
	DBStd	27.15	15.82	14.33	14.76	10.32	8.14	5.90	4.93	6.27	7.59	9.07	14.03	14.67	
	HDD50	8594	1718	1390	1217	513	125	9	0	10	135	552	1262	1663	
	HDD65	13103	2183	1810	1681	963	511	224	119	231	527	1014	1712	2128	
	CDD50	1012	0	0	1	0	79	245	372	255	58	2	0	0	
	CDD65	49	0	0	0	0	1	10	26	11	1	0	0	0	
	CDH74	1364	0	0	0	0	126	363	573	288	14	0	0	0	
	CDH80	330	0	0	0	0	21	99	146	61	3	0	0	0	
Wind	WSAvg	3.8	3.4	3.9	4.2	4.5	4.5	3.8	3.6	3.6	3.6	3.9	3.8	3.3	
Precipitation	PrecAvg	16.3	0.9	0.7	0.7	0.6	1.3	2.5	2.8	2.2	1.7	1.2	1.0	0.9	
	PrecMax	22.9	1.7	1.8	1.7	1.2	2.4	5.1	7.3	4.3	4.0	2.1	2.2	2.0	
	PrecMin	10.1	0.1	0.1	0.0	0.1	0.3	0.7	0.4	0.4	0.5	0.6	0.2	0.2	
	PrecStd	2.8	0.4	0.4	0.4	0.3	0.6	1.3	1.3	0.8	0.8	0.5	0.4	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	44.8	55.3	66.0	82.5	88.3	89.7	86.1	75.4	62.7	49.2	45.6	
		MCWB	38.2	35.7	42.1	47.4	55.8	61.4	62.8	63.0	57.5	48.9	40.2	37.6	
	2%	DB	37.4	36.2	46.5	59.1	77.7	82.5	84.0	81.0	69.7	55.7	41.3	36.2	
		MCWB	31.4	30.0	36.9	43.9	54.8	59.6	61.9	61.1	53.6	44.7	34.1	30.5	
	5%	DB	24.6	27.8	41.4	55.4	72.6	77.7	80.1	76.9	66.0	51.5	33.5	25.2	
		MCWB	22.1	24.2	33.3	42.1	52.8	57.6	60.5	59.3	51.9	42.0	29.2	22.8	
	10%	DB	14.4	21.1	35.4	51.2	67.7	74.1	76.6	73.0	62.1	47.1	25.9	17.0	
		MCWB	12.8	18.8	29.3	39.7	50.3	56.4	59.6	57.7	50.0	40.0	23.5	15.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	35.9	42.6	48.3	58.0	64.3	66.0	65.8	58.4	50.2	40.0	37.0
			MCDB	46.1	44.2	54.9	63.7	78.7	80.2	80.6	79.6	72.4	61.1	48.7	44.8
2%		WB	31.5	30.2	37.3	45.0	55.7	61.8	64.0	62.8	54.7	45.5	34.5	30.4	
		MCDB	37.2	35.8	46.0	58.0	75.3	76.6	77.2	76.9	66.4	54.3	41.0	36.0	
5%		WB	22.1	24.2	33.6	42.4	53.5	59.9	62.5	60.7	52.9	42.6	29.4	22.9	
		MCDB	24.5	27.6	40.9	54.1	70.6	73.5	76.5	74.2	63.3	50.3	33.4	24.8	
10%		WB	13.0	18.7	29.6	40.2	51.2	58.0	60.8	58.7	51.1	40.1	23.5	15.6	
		MCDB	14.5	21.2	35.4	50.5	65.7	70.5	73.1	69.7	60.6	47.0	25.9	17.0	
Mean Daily Temperature Range	5% DB	MDBR	18.1	22.5	28.0	24.9	27.7	25.4	24.6	23.9	21.7	16.6	16.7	16.9	
		MCDBR	29.4	28.8	32.8	32.3	39.5	36.2	34.1	33.9	28.8	23.8	23.5	28.3	
		MCWBR	24.0	23.8	23.6	18.4	18.3	15.3	14.6	15.9	15.2	14.0	18.3	22.8	
	5% WB	MCDBR	29.0	27.6	31.7	31.1	37.0	31.1	30.4	30.6	26.9	22.9	23.1	26.9	
		MCWBR	23.6	22.8	22.8	18.0	17.3	13.7	14.1	15.2	15.0	14.2	17.9	22.0	
Clear-Sky Solar Irradiance	taub	0.215	0.256	0.281	0.362	0.383	0.396	0.409	0.386	0.322	0.289	0.226	0.179		
	taud	2.086	2.236	2.208	2.020	2.222	2.299	2.287	2.358	2.518	2.364	2.071	1.951		
	Ebn at Noon	168	235	266	259	265	263	256	252	255	219	154	123		
	Edh at Noon	12	20	30	44	39	37	37	32	23	18	12	8		
All-Sky Solar Radiation	RadAvg	108	379	908	1469	1700	1691	1605	1318	841	403	143	56		
	RadStd	9	25	50	69	106	128	130	89	82	30	12	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	+3.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page