

DEADMEN VALLEY, NT, Canada

WMO: 710210

Lat: 61.260N

Lon: 124.470W

Elev: 283

StdP: 97.97

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.0	-36.7	-44.3	0.0	-39.8	-40.7	0.1	-36.5	8.7	-12.3	8.0	-13.1	0.3	260	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	28.7	16.1	26.7	15.3	24.8	14.6	17.6	25.3	16.6	24.2	15.6	22.6	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	10.9	18.8	13.9	10.2	17.9	12.9	9.6	17.2	50.5	25.4	47.5	24.2	44.7	22.7	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.9	5.2	-43.3	32.3	2.6	1.6	-45.2	33.4	-46.7	34.4	-48.2	35.3	-50.1	36.4		
			-43.1	19.6	2.4	1.5	-44.8	20.6	-46.2	21.5	-47.5	22.4	-49.2	23.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.5	-20.8	-17.6	-11.8	0.5	9.2	14.4	16.7	14.4	8.6	0.2	-13.4	-19.8
	DBStd	15.09	8.79	7.96	8.20	5.73	4.52	3.28	2.74	3.48	4.22	5.04	7.80	8.15
	HDD10.0	4774	954	772	676	285	69	5	0	6	75	307	701	924
	HDD18.3	7279	1213	1006	934	535	284	124	66	128	293	563	951	1182
	CDD10.0	562	0	0	1	0	44	136	207	142	32	1	0	0
	CDD18.3	27	0	0	0	0	1	6	14	6	1	0	0	0
	CDH23.3	758	0	0	0	0	70	202	318	160	8	0	0	0
	CDH26.7	183	0	0	0	0	12	55	81	34	2	0	0	0
Wind	WSAvg	1.7	1.5	1.7	1.9	2.0	2.0	1.7	1.6	1.6	1.6	1.7	1.7	1.5
Precipitation	PrecAvg	413	22	17	17	15	32	64	71	55	42	30	26	22
	PrecMax	582	42	45	42	31	62	129	186	110	101	53	55	52
	PrecMin	256	2	3	1	2	7	17	11	10	12	14	4	6
	PrecStd	72	9	10	10	8	14	32	33	21	20	12	10	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	7.1	12.9	18.9	28.1	31.3	32.1	30.1	24.1	17.1	9.5	7.6
		MCWB	3.5	2.1	5.6	8.6	13.2	16.3	17.1	17.2	14.2	9.4	4.5	3.1
	2%	DB	3.0	2.3	8.1	15.1	25.4	28.1	28.9	27.2	21.0	13.1	5.2	2.3
		MCWB	-0.3	-1.1	2.7	6.6	12.7	15.3	16.6	16.2	12.0	7.0	1.2	-0.8
	5%	DB	-4.1	-2.3	5.2	13.0	22.6	25.4	26.7	24.9	18.9	10.8	0.8	-3.8
		MCWB	-5.5	-4.3	0.7	5.6	11.6	14.2	15.8	15.2	11.0	5.6	-1.6	-5.1
	10%	DB	-9.8	-6.0	1.9	10.7	19.8	23.4	24.8	22.8	16.7	8.4	-3.4	-8.4
		MCWB	-10.6	-7.3	-1.5	4.3	10.2	13.5	15.3	14.3	10.0	4.4	-4.7	-9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	2.2	5.9	9.1	14.4	17.9	18.9	18.8	14.7	10.1	4.5	2.8
		MCDB	7.9	6.8	12.7	17.6	25.9	26.8	27.0	26.5	22.5	16.2	9.3	7.1
	2%	WB	-0.3	-1.0	2.9	7.2	13.2	16.6	17.8	17.1	12.6	7.5	1.4	-0.9
		MCDB	2.9	2.1	7.8	14.5	24.1	24.8	25.1	24.9	19.1	12.4	5.0	2.2
	5%	WB	-5.5	-4.3	0.9	5.8	11.9	15.5	16.9	16.0	11.6	5.9	-1.5	-5.0
		MCDB	-4.2	-2.5	4.9	12.3	21.4	23.0	24.7	23.4	17.4	10.2	0.8	-4.0
	10%	WB	-10.6	-7.4	-1.3	4.5	10.7	14.4	16.0	14.8	10.6	4.5	-4.7	-9.1
		MCDB	-9.7	-6.0	1.9	10.3	18.7	21.4	22.9	20.9	15.9	8.3	-3.4	-8.3
Mean Daily Temperature Range	5% DB	MDBR	10.0	12.5	15.6	13.9	15.4	14.1	13.7	13.3	12.1	9.2	9.3	9.4
		MCDBR	16.3	16.0	18.2	18.0	21.9	20.1	19.0	18.9	16.0	13.2	13.1	15.7
		MCWBR	13.3	13.2	13.1	10.2	10.2	8.5	8.1	8.8	8.4	7.8	10.2	12.7
	5% WB	MCDBR	16.1	15.4	17.6	17.3	20.5	17.3	16.9	17.0	14.9	12.7	12.8	14.9
		MCWBR	13.1	12.7	12.7	10.0	9.6	7.6	7.8	8.5	8.4	7.9	9.9	12.2
Clear-Sky Solar Irradiance	taub	0.215	0.256	0.281	0.362	0.383	0.396	0.409	0.386	0.322	0.289	0.226	0.179	
	taud	2.086	2.236	2.208	2.020	2.222	2.299	2.287	2.358	2.518	2.364	2.071	1.951	
	Ebn at Noon	529	741	840	815	834	830	806	795	803	690	485	387	
	Edh at Noon	37	63	93	138	123	117	116	100	71	56	37	24	
All-Sky Solar Radiation	RadAvg	0.34	1.19	2.86	4.63	5.36	5.33	5.06	4.15	2.65	1.27	0.45	0.17	
	RadStd	0.03	0.08	0.16	0.22	0.34	0.41	0.41	0.28	0.26	0.10	0.04	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	+1.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page