

INGONISH BEACH, NS, Canada

WMO: 710270

Lat: 46.663N

Lon: 60.406W

Elev: 33

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.4	7.7	-4.4	4.3	5.7	-0.6	5.3	9.8	24.7	23.5	21.1	20.5	5.8	260	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.4	84.2	68.5	80.7	67.6	77.5	66.3	71.7	80.0	70.0	77.4	68.3	75.1	8.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	106.4	76.0	67.3	100.4	74.3	65.6	94.6	72.7	35.5	80.1	34.0	77.5	32.6	75.2	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	15.8	13.5	-2.5	90.6	5.3	3.2	-6.3	92.8	-9.4	94.7	-12.4	96.5	-16.2	98.8		
(5)			-3.2	74.7	5.2	1.6	-6.9	75.8	-9.9	76.8	-12.8	77.7	-16.5	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.2	24.9	23.6	28.7	37.5	46.5	55.6	65.8	66.5	59.4	49.1	40.4	31.3		
	DBStd	16.37	8.36	8.59	7.97	6.56	6.77	7.37	6.11	5.18	6.60	6.58	7.43	7.23		
	HDD50	3719	778	739	660	381	154	22	0	0	6	97	303	579		
	HDD65	7799	1242	1159	1125	826	573	300	65	42	193	492	739	1043		
	CDD50	1616	1	0	0	5	46	189	491	513	287	70	14	0		
	CDD65	223	0	0	0	0	1	16	91	90	24	1	0	0		
	CDH74	1580	0	0	0	0	28	164	670	567	142	9	0	0		
	CDH80	359	0	0	0	0	2	38	177	118	23	1	0	0		
(14) Wind	WSAvg	5.4	5.9	6.0	6.0	5.5	5.1	4.8	4.8	5.0	5.2	5.3	5.4	5.6		
(15) Precipitation	PrecAvg	66.7	6.6	5.6	5.4	5.1	4.0	4.1	3.6	4.6	5.4	8.1	6.5	8.0		
	PrecMax	78.4	12.6	9.4	12.0	8.7	7.7	9.3	8.0	13.9	13.6	13.1	13.6	18.7		
	PrecMin	47.7	2.1	2.6	2.0	2.6	1.7	1.5	1.4	1.8	1.8	3.2	3.6	3.8		
	PrecStd	7.3	2.2	1.9	2.2	1.8	1.8	2.0	1.4	2.4	3.0	2.8	2.2	3.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.1	51.6	55.4	66.6	78.0	84.6	89.0	88.6	82.9	74.4	66.7	58.3		
		MCWB	53.8	48.7	49.7	58.0	61.9	67.0	71.3	70.2	68.2	62.4	61.1	54.7		
	2%	DB	46.2	44.5	49.4	58.9	70.8	78.6	84.8	83.2	77.9	68.7	61.7	50.8		
		MCWB	42.8	40.8	44.2	51.3	57.4	65.0	69.3	68.4	66.5	61.1	57.3	48.0		
	5%	DB	39.7	38.0	43.7	53.2	64.4	73.7	81.2	79.9	74.3	64.2	57.2	44.9		
		MCWB	36.9	34.6	38.6	46.2	53.9	62.1	68.1	67.6	64.9	58.4	53.9	42.6		
	10%	DB	35.8	34.6	39.3	48.2	58.8	68.8	77.4	76.7	70.9	60.3	51.8	41.3		
		MCWB	33.7	32.1	34.7	42.2	49.7	59.3	66.6	66.6	63.3	54.7	49.1	39.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	49.3	50.5	58.6	64.7	71.1	74.6	73.5	71.5	66.3	61.9	55.1		
		MCDB	58.0	51.7	54.0	65.6	74.9	81.2	83.9	83.0	78.2	70.0	65.9	57.4		
	2%	WB	43.9	41.2	44.9	52.3	59.9	67.5	72.2	71.4	68.9	62.3	58.2	48.3		
		MCDB	45.9	43.9	49.5	57.1	67.7	75.1	80.7	79.1	75.3	66.9	61.3	50.9		
	5%	WB	37.2	35.3	38.9	47.3	54.7	63.5	70.3	69.7	66.8	59.0	53.8	43.0		
		MCDB	39.3	37.4	43.6	52.2	63.1	71.7	78.2	76.4	72.4	63.8	56.9	44.5		
	10%	WB	33.9	32.6	35.2	42.7	50.6	60.3	68.3	68.1	64.5	55.5	49.4	39.5		
		MCDB	35.4	34.1	38.4	47.1	57.5	67.0	75.6	74.4	69.5	59.4	51.4	41.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	15.0	15.3	14.9	16.5	16.5	17.6	17.4	17.9	15.0	12.7	11.0		
		MCDBR	18.3	20.4	21.7	24.3	27.7	25.0	23.3	22.2	21.6	21.0	20.3	17.8		
		MCWBR	17.5	18.0	17.2	17.6	16.9	13.8	11.3	11.1	12.7	15.0	17.8	16.9		
	5% WB	MCDBR	18.0	19.7	21.5	22.4	25.4	21.4	19.8	18.4	19.2	19.8	19.4	17.5		
		MCWBR	17.6	18.2	18.0	18.2	16.9	14.0	10.9	10.7	13.3	15.6	17.8	16.9		
(40) Clear-Sky Solar Irradiance	taub		0.306	0.299	0.334	0.363	0.374	0.395	0.424	0.400	0.368	0.350	0.326	0.308		
	taud		2.335	2.349	2.288	2.357	2.412	2.374	2.337	2.411	2.474	2.477	2.460	2.370		
	Ebn at Noon		246	277	282	283	283	276	266	269	268	256	240	232		
	Edh at Noon		24	29	35	36	36	37	38	34	30	25	21	21		
(44) All-Sky Solar Radiation	RadAvg		298	544	951	1331	1618	1737	1741	1540	1174	716	362	227		
	RadStd		23	73	101	113	134	160	118	100	95	66	43	19		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	-1.55	-1.08	N/A	N/A	N/A	N/A	-52
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A

Nomenclature: See separate page