

PRINCETON, BC, Canada

WMO: 710320

Lat: 49.4683N

Lon: 120.5143W

Elev: 2290

StdP: 13.52

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.8	-0.1	-13.0	3.0	-6.4	-5.4	4.5	0.9	11.7	28.5	9.3	27.1	0.8	0	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.8	91.4	62.3	87.6	61.3	83.6	60.1	64.4	85.8	62.6	83.0	61.0	80.6	7.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	76.5	66.2	55.0	70.0	65.8	53.0	65.0	65.7	30.7	86.2	29.3	83.4	28.0	80.9	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	12.8	10.7	DB	-16.5	97.5	8.0	3.1	-22.2	99.7	-26.9	101.5	-31.4	103.2	-37.3	105.4	(4)
(5)			WB	-16.9	68.6	8.4	3.0	-23.0	70.8	-27.9	72.5	-32.7	74.2	-38.8	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	22.6	26.6	35.9	43.9	52.5	58.4	65.5	64.6	56.3	43.5	31.4	22.2	(6)
(7)		DBStd	16.94	10.63	8.68	7.18	5.64	6.51	6.01	5.89	5.85	6.34	6.29	8.53	9.55	(7)
(8)		HDD50	3844	849	655	439	197	48	4	0	0	15	217	558	862	(8)
(9)		HDD65	7945	1314	1075	904	632	389	215	66	80	269	666	1008	1327	(9)
(10)		CDD50	1548	0	0	0	15	126	255	479	453	204	16	0	0	(10)
(11)		CDD65	174	0	0	0	0	2	16	81	68	7	0	0	0	(11)
(12)		CDH74	4107	0	0	0	16	190	475	1632	1435	354	5	0	0	(12)
(13)		CDH80	1662	0	0	0	2	50	170	717	611	112	0	0	0	(13)
(14)	Wind	WSAvg	2.7	1.2	1.7	2.7	3.7	3.8	3.9	4.0	3.4	2.7	2.1	1.5	1.2	(14)
(15)	Precipitation	PrecAvg	24.8	3.5	2.1	1.8	1.4	1.7	1.7	1.0	1.2	1.3	2.1	3.3	3.4	(15)
(16)		PrecMax	35.2	4.7	3.7	3.6	2.3	3.5	2.8	3.3	2.5	3.1	5.6	7.5	6.5	(16)
(17)		PrecMin	20.2	2.3	1.0	0.7	0.8	0.6	0.8	0.0	0.3	0.5	0.6	1.1	2.0	(17)
(18)		PrecStd	3.6	0.7	0.7	0.7	0.4	0.8	0.7	0.7	0.7	0.7	1.1	2.0	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	46.8	63.7	76.2	86.2	91.1	96.5	95.9	88.9	71.7	53.0	41.5	(19)
(20)			MCWB	37.6	39.4	47.4	54.1	59.5	62.6	64.4	63.2	60.4	55.0	45.5	36.7	(20)
(21)		2%	DB	37.7	42.5	55.7	68.1	79.4	85.0	92.0	90.9	83.1	63.7	47.5	37.0	(21)
(22)			MCWB	35.2	36.6	43.8	50.5	56.5	60.2	63.1	61.8	58.5	51.0	42.6	34.4	(22)
(23)		5%	DB	35.2	39.6	51.1	62.7	73.9	79.3	88.0	87.0	77.9	58.6	44.3	34.5	(23)
(24)			MCWB	33.6	35.1	41.5	47.7	54.9	57.9	61.9	61.0	57.5	48.2	40.6	33.0	(24)
(25)		10%	DB	33.3	37.0	47.4	57.5	68.5	74.0	83.7	82.5	71.9	54.6	41.4	32.7	(25)
(26)			MCWB	32.3	33.8	39.5	45.2	52.5	56.1	60.7	60.0	55.3	46.3	38.7	31.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	40.5	48.6	55.3	60.9	64.7	67.6	66.1	62.9	55.9	46.6	37.8	(27)
(28)			MCDWB	41.4	45.9	61.2	73.4	83.1	85.1	90.2	90.1	80.8	68.0	50.3	40.2	(28)
(29)		2%	WB	35.6	37.6	44.9	51.8	57.8	61.4	64.9	63.8	60.3	52.5	43.8	35.0	(29)
(30)			MCDWB	37.0	41.2	54.4	67.1	75.4	81.0	86.4	85.5	78.4	61.6	46.8	36.5	(30)
(31)		5%	WB	33.9	35.8	42.3	48.7	55.6	59.2	63.1	62.0	58.4	49.5	41.4	33.3	(31)
(32)			MCDWB	34.9	38.9	50.1	61.0	71.5	76.5	83.6	82.5	75.5	56.6	43.7	34.4	(32)
(33)		10%	WB	32.4	34.1	40.1	46.0	53.5	57.1	61.3	60.5	56.2	47.2	39.0	31.8	(33)
(34)			MCDWB	33.3	36.7	46.8	56.7	66.9	72.2	80.7	80.4	70.7	53.5	41.1	32.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.7	16.7	20.8	24.9	26.9	26.0	30.8	31.9	29.0	21.6	13.2	11.1	(35)
(36)			MCDBR	11.7	18.1	26.6	35.7	38.0	37.5	39.8	40.9	41.1	28.9	16.2	11.3	(36)
(37)			MCWBR	9.1	12.9	16.0	19.6	17.8	16.5	16.2	16.7	19.6	16.9	11.0	9.1	(37)
(38)		5% WB	MCDWB	10.7	16.0	25.3	33.0	33.5	33.1	35.8	36.8	37.0	25.7	14.2	11.0	(38)
(39)	MCWBR		8.6	11.8	15.7	18.7	16.3	15.6	15.7	15.7	18.2	15.6	10.3	8.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.279	0.277	0.295	0.328	0.356	0.338	0.331	0.335	0.320	0.318	0.293	0.271	(40)	
(41)		taud	2.406	2.456	2.480	2.409	2.384	2.473	2.514	2.512	2.533	2.519	2.495	2.441	(41)	
(42)		Ebn at Noon	248	281	293	292	286	292	292	286	281	261	243	237	(42)	
(43)		Edh at Noon	20	24	28	34	36	33	32	30	27	23	18	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	337	612	962	1442	1692	1773	2046	1746	1210	697	345	260	(44)	
(45)		RadStd	42	58	97	96	146	183	184	125	107	76	36	33	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page