

CAPE SCOTT, BC, Canada

WMO: 710328

Lat: 50.7823N

Lon: 128.4270W

Elev: 72

StdP: 100.47

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.4	(c) 0.0	(d) -7.3	(e) 2.0	(f) 0.2	(g) -4.9	(h) 2.5	(i) 1.5	(j) 20.5	(k) 8.6	(l) 18.0	(m) 8.7	(n) 4.7	(o) 50	(p) 0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.9	(c) 16.9	(d) 14.8	(e) 16.2	(f) 14.4	(g) 15.7	(h) 14.1	(i) 15.4	(j) 16.3	(k) 14.9	(l) 15.8	(m) 14.5	(n) 15.4	(o) 3.8	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.7	15.6	14.5	10.4	15.3	14.0	10.1	15.0	43.2	16.5	41.9	15.8	40.6	15.5	17.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	13.6	11.6		-2.4	19.3	2.3	1.7	-4.1	20.5	-5.4	21.5	-6.7	22.4	-8.4	23.6
			DB	-4.1	16.1	2.1	0.6	-5.6	16.5	-6.8	16.9	-8.0	17.2	-9.5	17.7
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	5.5	5.8	6.3	7.8	9.6	11.6	13.3	14.0	12.8	10.1	7.6	5.6
	DBStd	3.57	2.57	2.29	1.81	1.63	1.54	1.19	1.08	1.03	1.49	1.80	2.32	2.66
	HDD10.0	702	139	119	116	69	24	2	0	0	1	21	77	135
	HDD18.3	3338	398	351	374	317	269	202	154	134	166	256	323	393
	CDD10.0	406	0	1	1	2	13	51	104	124	84	23	3	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	4.4	5.4	5.0	4.1	4.3	4.0	3.3	3.4	3.5	3.8	4.9	5.8	5.9
(15) Precipitation	PrecAvg	2797	325	249	271	198	140	112	83	124	179	340	403	387
	PrecMax	3421	518	522	469	372	204	182	210	271	349	528	593	682
	PrecMin	2165	159	96	124	83	53	61	22	31	47	155	255	208
	PrecStd	283	76	81	70	57	36	31	44	60	70	109	97	98
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	13.0	12.3	14.1	15.3	16.1	17.3	18.0	18.6	15.5	13.2	11.1
		MCWB	8.0	10.5	8.1	9.7	12.9	13.5	15.1	15.7	14.4	12.4	10.8	9.4
	2%	DB	9.9	11.0	10.3	11.7	13.5	15.0	16.5	17.0	16.6	14.2	12.1	10.1
		MCWB	8.6	9.1	8.2	9.4	11.7	13.1	14.6	15.1	14.2	12.1	10.7	9.2
	5%	DB	9.2	9.7	9.5	10.7	12.7	14.2	15.8	16.3	15.7	13.4	11.2	9.4
		MCWB	8.1	8.0	8.0	8.8	11.1	12.3	14.1	14.8	14.0	11.8	9.8	8.5
	10%	DB	8.6	8.8	8.7	10.0	12.0	13.6	15.3	15.8	15.0	12.6	10.5	8.8
		MCWB	7.7	7.5	7.4	8.4	10.5	11.8	13.8	14.4	13.7	11.3	9.2	7.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	11.1	9.7	11.1	13.4	14.2	15.6	16.2	15.6	14.2	12.2	10.1
		MCDB	10.2	12.2	10.7	12.3	14.4	15.5	16.7	17.0	16.9	14.7	12.5	10.2
	2%	WB	9.1	9.6	9.0	10.0	12.2	13.4	14.8	15.6	15.1	13.2	11.1	9.4
		MCDB	9.4	10.5	9.8	11.0	13.1	14.5	15.9	16.4	16.1	13.8	11.6	9.9
	5%	WB	8.4	8.7	8.4	9.4	11.4	12.7	14.4	15.1	14.5	12.2	10.2	8.7
		MCDB	8.9	9.4	9.1	10.4	12.5	13.7	15.5	15.9	15.4	12.8	10.9	9.3
	10%	WB	7.8	7.8	7.8	8.7	10.7	12.1	14.0	14.7	13.9	11.5	9.5	8.0
		MCDB	8.4	8.5	8.5	9.8	11.8	13.1	15.0	15.5	14.7	12.2	10.3	8.6
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	3.1	3.3	3.5	3.4	3.2	3.1	2.9	3.1	2.9	2.8	2.9
		MCDBR	3.3	3.8	4.1	4.4	4.2	4.0	3.9	3.5	4.1	3.6	3.6	3.3
	5% WB	MCWBR	3.0	3.0	3.2	3.1	3.1	2.8	2.6	2.3	2.9	3.0	3.3	3.2
		MCDWR	3.0	3.4	3.3	3.9	4.0	3.7	3.6	3.2	3.6	3.3	3.4	3.2
(40) Clear-Sky Solar Irradiance	taub		0.318	0.324	0.348	0.377	0.378	0.368	0.360	0.364	0.359	0.345	0.326	0.313
		taud	2.449	2.503	2.442	2.355	2.394	2.461	2.529	2.523	2.515	2.491	2.418	2.391
	Ebn at Noon		714	817	855	865	878	889	891	870	835	777	689	650
		Edh at Noon	60	73	92	112	112	106	98	94	85	73	61	55
(44) All-Sky Solar Radiation	RadAvg		0.72	1.58	2.59	4.05	4.99	5.33	5.18	4.51	3.30	1.83	0.90	0.60
	RadStd		0.09	0.24	0.32	0.26	0.43	0.51	0.52	0.45	0.27	0.22	0.12	0.08

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page